

School Name: **Farrell Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8380-01-KC-003	Room 113 - Special Education	12/21/2016	0.99	BA
8380-01-KC-009	Kitchen - Backwall - Left	12/21/2016	4.6	BA
8380-01-KC-011	Kitchen - Backwall - Right	12/21/2016	1.9	BA
8380-01-DW-013	In Gymnasium	12/21/2016	0.25	BA
8380-01-DW-016	Outside of the Main Office - left	12/21/2016	1.0	BA
8380-01-DW-017	Outside of the Main Office - right	12/21/2016	0.92	BA
8380-01-BF-021	Nurse's Bathroom	12/21/2016	0.92	BA
8380-01-DW-029	Outside Girl's Room; Across from Room 105	12/21/2016	1.1	BA
8380-01-DW-038	Room 100 - Kindergarten	12/21/2016	1.4	BA
8380-01-DW-041	Room 101 - Kindergarten	12/21/2016	2.1	BA
8380-01-WC-044	Room A2	12/21/2016	92.4	AA
8380-01-WC-046	Inside of IMC	12/21/2016	0.17	BA
8380-01-WC-049	Room A4 - Learning Support	12/21/2016	17.0	AA
8380-01-WC-051	Room A6	12/21/2016	2.4	BA
8380-01-WC-053	Room A3	12/21/2016	1.4	BA
8380-02-DW-057	Across from Room 205	12/21/2016	2.5	BA
8380-02-DW-063	Outside Room 209 - left side (see outlet 076)	12/21/2016	0.94	BA
8380-03-DW-066	Outside Room 309 - left (see outlet 077)	12/21/2016	0.62	BA
8380-03-DW-072	Outside Room 305	12/21/2016	0.83	BA
8380-02-DW-076	Outside Room 209 - right side (see outlet 063)	12/21/2016	0.86	BA
8380-03-DW-077	Outside Room 309 - right (see outlet 066)	12/21/2016	0.56	BA
8380-01-CF-078	Room 110 - Teacher's Lounge	12/21/2016	1.1	BA
8380-01-DW-086	Inside of Lunchroom	12/21/2016	2.1	BA
8380-01-KC-090N	Room 112 - Special Education	12/21/2016	1.5	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb