

 PLN Nusantara Power	PT. PLN NUSANTARA POWER UPDK KENDARI INTEGRATED MANAGEMENT SYSTEM FORMULIR PENGUKURAN KUALITAS PELUMAS						Nomor Dokumen : FMKD-305-14.3.2.b-A3 Revisi : Tanggal Terbit : 31 - 07 - 2024 Halaman :				
UNIT/SENTRAL : ULPLTD WUA-WUA MESIN NO. : 1 MESIN : 1 TITIK SAMPEL : Sump Tank NO. SERI : -											
PARAMETER											
TANGGAL	TBN (mgKOH/g)	WATER CONTENT (ppm)	VISCOSITY (derajat)		AW Additive (%)	Glycol (%)	Nitration (abs/0.1mm)	Oxidation (abs/0.1mm)	Soot (%wt)	Sulfation (abs/1m)	KETERANGAN
			40	100							
14-Sep-26	23,80	974,00	-	-	157,00	0,00	0,00	16,00	0,18	19,10	No Alarm
STATUS											
- No Alarm Sign											
STANDARD											
- Water Content : 2000 ppm											
FOTO SAMPEL PELUMAS						ANALISA					
 28 Agu 2026 15:46:39 -3°59'46,05188"S 122°31'50,60101"E 154° SE Kecamatan Wua-Wua Kota Kendari Sulawesi Tenggara Akurasi 4.1 Index number: 2494						- All parameter normal - Alat ukur viskositas error					
CBA						REKOMENDASI					
N/A						N/A					
Plh. Manager Unit Layanan ULPLTD Wua-Wua SURYADI PRATAMA						Kendari, 31 Agustus 2026 Team Leader Pemeliharaan SURYADI PRATAMA Staff Pemeliharaan MUHAMMAD ABDUL LIIZAL					