

OISD-STD-118 Layouts

OISD-STD-118

LAYOUT FOR OIL AND GAS INSTALLATIONS

1.0 INTRODUCTION

This standard lays down the minimum requirements for layout of facilities at Oil and Gas installations to ensure safety of personnel and property.

4.0 GENERAL LAYOUT PHILOSOPHY

4.1 The layout of an installation shall be planned to minimize the risk of fire, explosion, and toxic release, and to facilitate firefighting and rescue operations.

4.2 Equipment spacing shall be based on the hazard distances, operational requirements, and maintenance access.

4.3 Compressors and pumps handling flammable fluids shall be located in well-ventilated areas.

4.4 High hazard areas shall be segregated from low hazard areas.

5.0 EQUIPMENT SPACING

5.1 Distance between two process units shall not be less than 30 meters.

5.2 Distance between a process unit and a storage tank shall not be less than 60 meters.

5.3 Fire water pumps shall be located at a safe distance from process and storage areas, typically not less than 60 meters.