



TC-5961

TEST REPORT

ULR-TC596124700001676F

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To :	Shree Saraswati Vidyalaya Sector- 3B , Gandhinagar, Gujarat Phone No : 9016102267 Email : agtvs412@gmail.com	Test Report No	: GTL/03240226004
		Date of Receipt	: 26/02/2024
		Date of Issue	: 27/02/2024
		Customer's Ref. No	: N.M

Sample Described as	: Drinking Water	Mfg. Date	: N.M.
Sample Qty	: 2.0 Ltr	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: N.M		
Sample Drawn By	: Customer		
Date of Starting of Test	: 26/02/2024	Date of Completion	: 27/02/2024

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS : 3025 (P-4) : 1983
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5):2018
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.88	1	IS : 3025 (P-11) : 2022
4	Taste	Agreeable	Agreeable	Agreeable	--	IS : 3025 (P-7 & 8) : 1984
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS : 3025 (P-10) : 2023
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	291	5	IS:3025(P-16):2023
7	Calcium (as Ca), mg/l	Max.75	Max.200	21.88	0.1	IS : 3025(P-40) : 1991
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	35.47	0.5	IS : 3025(P-32) : 1988
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.25	IS:3025(P-60):2008
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	10.71	0.1	IS:3025(P-46):1994
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34):1988
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43):1992
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS 3025 :Part 24:Sec 1:2022
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	96.60	1	IS:3025(P-21):1983



Gandhinagar Municipal Corporation

Pandit Dindayal Upadhyay Bhawan,
Behind Fire Station, Sector-11, Gandhinagar-382011,
Tel No.: (079) 232 84150 Fax No.: (079) 23221419,
Toll free Helpline no.1800 108 1818

Web site : <http://www.gandhinagarmunicipal.com> Email: gmc8gandhinagar@gmail.com

Outward: 6305

Date: 11/03/2024

Sanitary Certificate

I declare that I have inspected SHREE SARASWATI VIDHYALAYA, SECONDARY, SSV CAMPUS, SECTOR 3/B, GANDHINAGAR-382006, GUJARAT INDIA school building and premises on Date: 11/03/2024 and certify that the building is maintained neat and clean. The latrine arrangements are adequate and that in all other necessary aspect the sanitation is Satisfactory.

Period: March 2024 to April 2025

Place: Gandhinagar

Assistant Director (Sanitation) (I/C)
Gandhinagar Municipal Corporation

(Ref: As per approval by Deputy Municipal
Commissioner on dated: 12/03/2024)