Totally Integrated Automation Portal					
lab4 / PLC_1 [CPU 1214C DC/DC/DC] / Program blocks					

Dzielnik_4_1 [FC3]

Dzielnik_4_1 Properties									
General									
Name	Dzielnik_4_1	Number	3	Type	FC	Language	LAD		
Numbering	Automatic								
Information									
Title		Author		Comment		Family			
Version	0.1	User-defined ID							

Dzielnik_4_1			
Name	Data type	Default value	Comment
▼ Input			
Signal_IN	Bool		
▼ Output			
Signal_Out	Bool		
InOut			
Temp			
Constant			
▼ Return			
Dzielnik_4_1	Void		

Network 1:

```
%DB3
"IEC_Counter_0_
DB"
                               CTU
Int
   #Signal_IN
                                     Q
CV — 0
"IEC_Counter_0_
DB".QU
```

Network 2:

```
"IEC_Counter_0_
DB".CV
                                                                                    #Signal_Out
                       IN_RANGE
Int
                                                                                   #Signal_Out
"IEC_Counter_O_
DB".CV — VAL
               3 — MAX
```

Network 3: