

SCHEDULE OF MAIN DISTRIBUTION PANEL "MDP"										ELECTRICAL 118B									
MAINS:		3000		VOLT:		120/208		PHASE: 3		WIRE:		4		MIN BREAK A/C		65,000		MOUNT: PAD	
FEEDER/ BRANCH CIRCUITS					CONDUIT SIZE	TO FEED	CONNECTED LOAD KVA	DEMAND LOAD KVA	CIRCUIT BREAKERS			REMARKS							
DISIGNATION	SETS	WIRE SIZE	GRD COND.	FRAME					AMPS	POLES									
1		2 (4) #3/0	#3	2 1/2"	H	90.8	43.3	400	400	3									
2		1 (4) #3/0	#6	2"	K	93.8	31.5	225	200	3									
3		2 (4) #3/0	#3	2 1/2"	L	133.4	118.3	400	400	3									
4		1 (4) #3/0	#3	2 1/2"	A	148.4	84.16	400	400	3									
5		1 (4) #3/0	#6	2"	B	65.6	32.62	225	200	3									
6		1 (4) #3/0	#6	2"	P	39.5	35.62	225	200	3									
7		1 (4) #3/0	#3	2 1/2"	2A	193.6	111.12	400	400	3									
8		1 (4) #3/0	#3	2 1/2"	2B	152.8	84.99	400	400	3									
9		1 (4) #3/0	#3	2 1/2"	3A	193.6	111.12	400	400	3									
10		1 (4) #3/0	#3	2 1/2"	3B	152.8	84.99	400	400	3									
11		1 (4) #3/0	#3	2 1/2"	4A	193.6	111.12	400	400	3									
12		1 (4) #3/0	#3	2 1/2"	4B	152.8	84.99	400	400	3									
13		1 (4) #3/0	#6	2"	4C	84.4	78	225	200	3									
14		1 (4) #3/0	#6	2"	ELEVATOR	12.5 *	12.5 *	60 *	60 *	3	W/ SHUNT TRIP								
15		1 (4) #3/0	#6	2"	ELEVATOR	12.5 *	12.5 *	60 *	60 *	3	W/ SHUNT TRIP								
16																			
17																			
18																			
19																			
20																			
21																			
22																			
23																			
24																			
NOTES		* Verify with Elevator Manufacturer				TOTAL DEMAND KVA:		1011.83				TOTAL AMPS:		2812					

PANELBOARD SCHEDULE L LOCATION: ELECTRICAL 118B										ELECTRICAL 118B	
MAIN: 400 MLO	VOLTAGE: 208/120		PHASE: 3	WIRE: 4	MOUNTING SURFACE		AIC: 22,000.	NOTES:		AMP/ POLE	CCT
#	POLE	DESCRIPTION	LGT	REC	MTR	A/C	HTG	KIT	MISC	TRIP/ POLE	#
1	20/1	LAUNDRY DISCH. 114C	1	1.2							2
3	20/1	LAUNDRY DISCH. 114C									4
5	20/1	EMPLOYEE BREAK 106B	1	1.2							6
7	20/1	EMPLOYEE BREAK 106B									8
9	20/1	EMPLOYEE BREAK 106B									10
11	20/1	SPARE									12
13	20/1	LAUNDRY RM 11D	1	1.2							14
15	20/1	LAUNDRY RM 11D									16
17	20/2	DRYER					1.8				18
19							1.8				20
21	20/2	DRYER					1.8				22
23							1.8				24
25	20/3	WASHER					3.6				26
27	-	-					3.6				28
29	-	-					3.6				30
31	20/3	WASHER					3.6				32
33	-	-					3.6				34
35	-	-					3.6				36
37	20/2	VESTIBULE 115 HEATER					0.7				38
39	-	-					0.7				40
41	20/1	SPARE					1.2				42
SECTION TWO											
43	20/2	STAIR 1 HEATER 101					0.7				44
45	-	-					0.7				46
47	20/2	STAIR 2 HEATER 128					0.7				48
49	-	-					0.7				50
51	20/1	FURNACE 1					1.3				52
53	20/1	FURNACE 2					1.3				54
55	20/1	FURNACE 3					1.3				56
57	20/1	FURNACE 4					1.3				58
59	20/1	FURNACE 5					1.3				60
61	20/2	DMS-1					1.8				62
63	-	-					1.8				64
65	20/1	DRYER 108D	0.5								66
67	20/1	DRYER 108D					1.2				68
69	20/2	OUTDOOR STOR. HEATER					0.7				70
71	-	-					0.7				72
73	20/2	ACC-2					1.8				74
75	-	-					1.8				76
77	20/1	STORAGE 104B	0.5								78
79	20/1	STORAGE 104B					1.2				80
81	20/1	STORAGE 114F	0.5								82
83	20/1	SPARE					1.2				84
SECTION TWO											
LIGHTING:		6.5	4.5	10.8	42.5	0	5.6	0	0	2	133.4
RECEPTACLES:		12								2	118.3
MOTORS:		78.8								45.4	378.3
A/C:		23.8								44.3	369.2
HEATING:		5.6								43.7	364.2
KITCHEN:		0									
MISCELLANEOUS		0.7									
SECTION TWO											
LIGHTING:		6.5	4.5	10.8	42.5	0	5.6	0	0	2	133.4
RECEPTACLES:		12								2	118.3
MOTORS:		78.8								45.4	378.3
A/C:		23.8								44.3	369.2
HEATING:		5.6								43.7	364.2
KITCHEN:		0									
MISCELLANEOUS		0.7									

PANELBOARD SCHEDULE H LOCATION: ELECTRICAL 118B										ELECTRICAL 118B	
MAIN: 400 MLO	VOLTAGE: 208/120		PHASE: 3	WIRE: 4	MOUNTING SURFACE		AIC: 10,000.	NOTES:		AMP/ POLE	CCT
#	POLE	DESCRIPTION	LGT	REC	MTR	A/C	HTG	KIT	MISC	TRIP/ POLE	#
1	20/1	Stair #1 RM 101	1	1.2							2
3	20/1	Stair #1 RM 101									4
5	20/1	Stair #2 RM 130	1	1.2							6
7	20/1	Stair #2 RM 130									8
9	20/1	SALES 109D	0.5								10
11	20/1	SALES 109D									12
13	20/1	MECH 109C	0.5	1.2							14
15	20/1	MECH 109C									16
17	20/1	CLOSET	0.5								18
19	20/1	REGISTRATION 114A	1								20
21	20/1	REGISTRATION 114A									22
23	20/1	REGISTRATION 114A									24
25	20/1	REGISTRATION 114A									26
27	20/1	WORK STATIONS 112B	0.5						0.5		28
29	20/1	WORK STATIONS 112B							0.5		30
31	20/1	WORK STATIONS 112B							0.5		32
33	20/1	MARKET 112A	0.5								34
35	20/1	MARKET 112A									36
37	20/1	MARKET 112A									38
39	20/1	MARKET 112A									40
41	20/2	SPARE									42
SECTION TWO											
43	20/1	MANAGER 114B	0.5								44
45	20/1	MANAGER 114B									46
47	20/1	UNISEX 118A	0.5								48
49	20/1	UNISEX 118A									50
51	20/1	MAINTENANCE STOR. 120A	0.5								52
53	20/1	MAINTENANCE STOR. 120A									54
55	20/2	MAINTENANCE STOR. 120A									56
57	-	-									58
59	20/1	OUTDOOR STOR. 118C	0.5								60
61	20/1	OUTDOOR STOR. 118C									62
63	20/1	WOMEN 109A	0.5								64
65	20/1	WOMEN 109A									66
67	20/1	MEN 109B	0.5								68
69	20/1	MEN 109B									70
71	20/1	VESTIBULE 115	0.5								72
73	20/1	VESTIBULE 115									74
75	20/1	VESTIBULE DOOR 115									76
77	20/1	VESTIBULE DOOR 115									78
79	20/1	HYDRATION STATION									80
81	20/1	SPARE									82
83	20/1	SPARE									84
SECTION TWO											
LIGHTING:		20.5	9	29	3.6	4.2	0	0	0	11.5	90.8
RECEPTACLES:		62									43.3
MOTORS:		3.6									
A/C:		4.2									
HEATING:		0									
KITCHEN:		0									
MISCELLANEOUS		0.5									

PANELBOARD SCHEDULE										A		Location: ELECTRICAL 118B					
MAIN: 400 MLO		VOLTAGE: 208/120			PHASE: 3		WIRE: 4		MOUNTING SURFACE			M 42,000 A		NOTES:			
CKT #	TRIP/ POLE	DESCRIPTION	LGT	REC	LOAD (KVA)	A/C	MTR	A/C	HTG	KIT	MISC	DESCRIPTION	TRIP/ POLE	CKT #			
1	60/2	RM 100	1	1.2	2.1	2.5	1.4	A	1	1.2	1.6	2.5	RM 103	60/2	2		
3	-	-							1	1.6	1.6	1.4	-	-	4		
5	60/2	RM 102	1	1.2	1.6	2.5	1.4	A	C	1	1.2	1.6	2.5	RM 123	60/2	6	
7	-	-							1	1.6	1.6	1.4	-	-	8		
9	60/2	RM 122	1.5	1.2	3.2	2.5	1.4	A	B	1	1.2	1.6	2.5	RM 125	60/2	10	
11	-	-							C	1	1.6	1.6	1.4	-	-	12	
13	60/2	RM 124	1	1.2	1.6	2.5	1.4	A	1	1.2	1.6	2.5	RM 127	60/2	14		
15	-	-							B	1	1.6	1.6	1.4	-	-	16	
17	60/2	RM 126	1	1.2	1.6	2.5	1.4	A	C	1.5	1.2	3.2	2.5	RM 129	60/2	18	
19	-	-							A	2.6	3.2	1.4	-	-	-	20	
21	60/2	RM 128	1	1.2	1.6	2.5	1.4	A	B	1	1.2	1.6	2.5	RM 131	60/2	22	
23	-	-							C	1	1.6	1.6	1.4	-	-	24	
25	20/1	SPARE	1.2					A	C	1	1.2	1.6	2.5	RM 133	60/2	26	
27	20/1	SPARE	1.2					B	1	1.6	1.6	1.4	-	-	-	28	
29	20/1	SPARE	1.2					C	1.2				SPARE	20/1	30		
31	20/1	SPARE	1.2					A	1.2				SPARE	20/1	32		
33		SPACE						B	1.2				SPACE	20/1	34		
35		SPACE						C					SPACE		36		
37		SPACE						A					SPACE		38		
39		SPACE						B					SPACE		40		
41		SPACE						C					SPACE		42		
LIGHTING:			14	6.5	22.6	0	23.4	0	7.5	24.2	0	25.6	0	27.3	0	160.5	
RECEPTACLES:			46.8													90.53	
MOTORS:			0						55.6	471.7							
			0						53.2	443.3							
HEATING:			0						50.7	422.5							
KITCHEN:			50.7						KVA	AMPS							
MISCELLANEOUS			0														
															CONNECTED LOAD (AMPS):		446.09
															DEMAND LOAD (AMPS):		251.58
															AMPCACITY REQUIRED:		251.58