

PANELBOARD SCHEDULE 2A Location: ELECTRICAL 218C																			
MAIN: 400 MLO		VOLTAGE: 208/120			PHASE: 3			WIRE: 4			PHASE			MOUNTING SURFACE			M 42,000 A		
CTK	TRIP/ POLE	DESCRIPTION	LGT	REC	MTR	A/C	HTG	KIT	MISC	PHASE	LGT	REC	MTR	A/C	HTG	KIT	MISC	DESCRIPTION	TRIP/ POLE
#	#																		#
1	60/2		1	1.2	2.1	2.5		A			1	1.2	1.6	1.6	2.5			RM 203	60/2
3	-		1	1.6	2.1	1.4		B			1	1.2	1.6	1.6	1.4			-	4
5	60/2	RM 204	1	1.2	2.1	2.5		C			1	1.2	1.6	1.6	2.5			RM 205	60/2
7	-		1	1.6	2.1	1.4		A			1	1.6	1.6	1.6	1.4			-	8
9	60/2	RM 204	1	1.2	1.6	2.5		B			1	1.2	1.6	1.6	2.5			RM 207	60/2
11	-		1	1.6	1.6	1.4		C			1	1.6	1.6	1.6	1.4			-	10
13	60/2	RM 206	1	1.2	2.1	2.5		A			1	1.2	2.1	2.5				RM 209	60/2
15	-		1	1.6	2.1	1.4		B			1	1.6	2.1	1.4				-	16
17	60/2	RM 208	1	1.2	2.1	2.5		C			1	1.2	2.1	2.5				RM 211	60/2
19	-		1	1.6	2.1	1.4		A			1	1.6	2.1	1.4				-	20
21	60/2	RM 210	1	1.2	2.1	2.5		B			1	1.2	2.1	2.5				RM 213	60/2
23	-		1	1.6	2.1	1.4		C			1	1.6	2.1	1.4				-	24
25	60/2	RM 212	1	1.2	2.1	2.5		A			1	1.2	2.1	2.5				RM 215	60/2
27	-		1	1.6	2.1	1.4		B			1	1.6	2.1	1.4				-	28
29	60/2	RM 214	1	1.2	2.1	2.5		C			1	1.2	2.1	2.5				RM 217	60/2
31	-		1	1.6	2.1	1.4		A			1	1.6	2.1	1.4				-	32
33	20/1	SPARE		1.2				B			1	1.2	1.6	1.6	2.5			RM 233	60/2
35	20/1	SPARE		1.2				C			1	1.6	1.6	1.6	1.4			-	36
37	20/1	SPARE		1.2				A			1	1.2						SPARE	20/1
39	SPACE							B										SPACE	40
41	SPACE							C										SPACE	42
LIGHTING:		52.4	17	8	26	0	32.6	0	31.2	0		9	26.4	0	33.8	0	35.1	0	202.1
RECEPTACLES:		52.4																	116.05
MOTORS:		0																	
A/C:		66.4								PHASE A								CONNECTED LOAD (AMPS):	561.64
HEATING:		0								PHASE B								DEMAND LOAD (AMPS):	322.5
KITCHEN:		66.3								PHASE C									
MISCELLANEOUS		0																AMPACITY REQUIRED:	322.5

PANELBOARD SCHEDULE 3A Location: ELECTRICAL 318C																			
MAIN: 400 MLO		VOLTAGE: 208/120			PHASE: 3			WIRE: 4			PHASE			MOUNTING SURFACE			M 42,000 A		
CTK	TRIP/ POLE	DESCRIPTION	LGT	REC	MTR	A/C	HTG	KIT	MISC	PHASE	LGT	REC	MTR	A/C	HTG	KIT	MISC	DESCRIPTION	TRIP/ POLE
#	#																		#
1	60/2	RM 300	1	1.2	2.1	2.5		A			1	1.2	1.6	1.6	2.5			RM 303	60/2
3	-		1	1.6	2.1	1.4		B			1	1.6	1.6	1.6	1.4			-	4
5	60/2	RM 302	1	1.2	2.1	2.5		C			1	1.2	1.6	1.6	2.5			RM 305	60/2
7	-		1	1.6	2.1	1.4		A			1	1.6	1.6	1.6	1.4			-	8
9	60/2	RM 304	1	1.2	1.6	2.5		B			1	1.2	1.6	1.6	2.5			RM 307	60/2
11	-		1	1.6	1.6	1.4		C			1	1.6	1.6	1.6	1.4			-	12
13	60/2	RM 306	1	1.2	2.1	2.5		A			1	1.2	2.1	2.5				RM 309	60/2
15	-		1	1.6	2.1	1.4		B			1	1.6	2.1	1.4				-	16
17	60/2	RM 308	1	1.2	2.1	2.5		C			1	1.2	2.1	2.5				RM 311	60/2
19	-		1	1.6	2.1	1.4		A			1	1.6	2.1	1.4				-	20
21	60/2	RM 310	1	1.2	2.1	2.5		B			1	1.2	2.1	2.5				RM 313	60/2
23	-		1	1.6	2.1	1.4		C			1	1.6	2.1	1.4				-	24
25	60/2	RM 312	1	1.2	2.1	2.5		A			1	1.2	2.1	2.5				RM 315	60/2
27	-		1	1.6	2.1	1.4		B			1	1.6	2.1	1.4				-	28
29	60/2	RM 314	1	1.2	2.1	2.5		C			1	1.2	2.1	2.5				RM 317	60/2
31	-		1	1.6	2.1	1.4		A			1	1.6	2.1	1.4				-	32
33	20/1	SPARE		1.2				B			1	1.2	1.6	1.6	2.5			RM 333	60/2
35	20/1	SPARE		1.2				C			1	1.6	1.6	1.6	1.4			-	36
37	20/1	SPARE		1.2				A			1	1.2						SPARE	20/1
39	SPACE							B										SPACE	40
41	SPACE							C										SPACE	42
LIGHTING:		52.4	17	8	26	0	32.6	0	31.2	0		9	26.4	0	33.8	0	35.1	0	202.1
RECEPTACLES:		52.4																	116.05
MOTORS:		0																	
A/C:		66.4								PHASE A								CONNECTED LOAD (AMPS):	561.64
HEATING:		0								PHASE B								DEMAND LOAD (AMPS):	322.5
KITCHEN:		66.3								PHASE C									
MISCELLANEOUS		0																AMPACITY REQUIRED:	322.5

PANELBOARD SCHEDULE																		4A		Location: ELECTRICAL 418C					
MAIN: 400 MLO			VOLTAGE: 208/120				PHASE: 3			WIRE: 4			PHASE			MOUNTING SURFACE			M 42,000 A			NOTES:			
CTK	TRIP/		LOAD (KVA)									LOAD (KVA)									TRIP/		CTK		
#	POLE	DESCRIPTION	LGT	REC	MTR	A/C	HTG	KIT	MISC		LGT	REC	MTR	A/C	HTG	KIT	MISC	DESCRIPTION	POLE	#					
1	60/2	RM 400	1	1.2		2.1		2.5		A	1	1.2	1.6	2.1				RM 403	60/2	2					
3	-	-		1.6		2.1		1.4		B	C	1	1.6	1.6	1.4			-	-	4					
5	60/2	RM 402	1	1.2		2.1		2.5		A	C	1	1.2	1.6	2.1			RM 405	60/2	6					
7	-	-		1.6		2.1		1.4		A	B	1	1.6	1.6	1.4			-	-	8					
9	60/2	RM 404	1	1.2		1.6		2.5		B	C	1	1.2	1.6	2.1			RM 407	60/2	10					
11	-	-		1.6		1.6		1.4		C	B	1	1.6	1.6	1.4			-	-	12					
13	60/2	RM 406	1	1.2		2.1		2.5		A	1	1.2	2.1	2.1	2.5			RM 409	60/2	14					
15	-	-		1.6		2.1		1.4		B	B	1	1.6	2.1	1.4			-	-	16					
17	60/2	RM 408	1	1.2		2.1		2.5		C	1	1.2	2.1	2.1	2.5			RM 411	60/2	18					
19	-	-		1.6		2.1		1.4		A	B	1	1.6	2.1	1.4			-	-	20					
21	60/2	RM 410	1	1.2		2.1		2.5		B	1	1.2	2.1	2.1	2.5			RM 413	60/2	22					
23	-	-		1.6		2.1		1.4		C	C	1	1.6	2.1	1.4			-	-	24					
25	60/2	RM 412	1	1.2		2.1		2.5		A	1	1.2	2.1	2.1	2.5			RM 415	60/2	26					
27	-	-		1.6		2.1		1.4		B	A	1	1.6	2.1	1.4			-	-	28					
29	60/2	RM 414	1	1.2		2.1		2.5		C	B	1	1.2	2.1	2.1	2.5		RM 417	60/2	30					
31	-	-		1.6		2.1		1.4		A	C	1	1.6	2.1	1.4			-	-	32					
33	20/1	SPARE		1.2						B	1	1.2	1.6	1.6	2.5			RM 433	60/2	34					
35	20/1	SPARE		1.2						C	C	1	1.6	1.6	1.4			-	-	36					
37	20/1	SPARE		1.2						A	A	1	1.2					SPARE	20/1	38					
39	SPACE									B								SPACE		40					
41	SPACE									C	C							SPACE		42					
LIGHTING:			17	8	26	0	32.6	0	31.2	0		9	26.4	0	33.8	0	35.1	0			202.1				
RECEPTACLES:			52.4																		116.05				
MOTORS:			0																						
A/C:			66.4																		561.64				
HEATING:			0																		322.5				
KITCHEN:			66.3																						
MISCELLANEOUS			0																		322.5				