

THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR A NEAT 'WORKMAN-LIKE' PLUMBING SYSTEM INSTALLATION THAT IS COMPLETE IN EVERY RESPECT. BY ACT OF SUBMITTING A BID FOR THE PROPOSED WORK, THIS CONTRACTOR AGREES TO PROVIDE ALL LABOR, TOOLS, EQUIPMENT AND APPROVED MATERIALS NECESSARY TO PROVIDE THE OWNER A SERVICEABLE AND COMPLETE SYSTEM AS INDICATED WITHIN THE SCOPE OF THESE PLANS AND SPECIFICATIONS.

THE ENTIRE PLUMBING SYSTEM SHALL BE INSTALLED IN STRICT ACCORDANCE WITH THE STATE PLUMBING CODE PROVISIONS AND LOCAL REGULATIONS OR CODES HAVING JURISDICTION. THE CODE OR SPECIFICATIONS WHICH CONFLICT WITH THIS SET OF CONSTRUCTION DOCUMENTS ARE INTENDED TO ILLUSTRATE THE SCOPE OF WORK REQUIRED FOR A COMPLETE PLUMBING INSTALLATION. HOWEVER, THE INFORMATION SHOWN SHALL IN NO WAY SUPERCEDE THE CODE PROVISIONS OR IN ANY WAY GIVE PERMISSION TO THE PLUMBING CONTRACTOR TO INSTALL A SYSTEM FOUND TO BE IN NON-COMPLIANCE.

THIS CONTRACTOR SHALL REVIEW THE ENTIRE SET OF CONSTRUCTION DOCUMENTS FOR AREAS OF WORK THAT DIRECTLY AFFECT THE PLUMBING DESIGN, INSTALLATION METHODS, FIRE STOPPING, PATCHING REQUIREMENTS, SPECIAL INSULATION REQUIREMENTS AND SCHEDULING OF ACTUAL INSTALLATION, GENERAL LAYOUTS, DETAILS AND SCHEMATICS NECESSARY TO PERFORM A COMPLETE SERVICEABLE JOB. (EVEN IF NOT SPECIFICALLY SHOWN) SHALL, BY ACT OF SUBMITTING A BID, BE UNDERSTOOD TO BE A PART OF THIS BID. QUESTIONS OR CLARIFICATIONS WHICH NEED TO BE ADDRESSED SHALL BE DONE PRIOR TO BIDDING OR SIGNING ANY FORM OF CONTRACT FOR THE RESPECTIVE WORK. NO ALLOWANCE SHALL BE MADE FOR ITEMS UNDERSTOOD TO BE A REASONABLE PART OF THIS WORK AFTER SUCH CONTRACT IS SIGNED.

THE PLUMBING CONTRACTOR IS RESPONSIBLE FOR THE COORDINATION OF WORK WITH OTHER TRADES. IT IS REQUIRED BY CONTRACT TO ATTEND PROGRESS MEETINGS AND AT ALL TIMES TO KEEP THE JOBSITE SUPERINTENDENT OR PROJECT MANAGER INFORMED OF ANY SCHEDULE DELAYS AND APPARENT CAUSES AND THE REMEDIAL ACTION TO BE TAKEN TO ACCOMPLISH THE COMPLETED PROJECT ACCORDING TO SCHEDULE. THIS CONTRACTOR AGREES TO TAKE NECESSARY STEPS TO KEEP HIS WORK IN CONTROL, INSPECTED AND FINISHED IN A TIMELY MANNER AS TO NOT HOLD UP OTHER TRADES BY THE CONTRACTOR'S PROJECTS THAT ARE IN COMPLETION.

THE PLUMBING CONTRACTOR SHALL OBTAIN AND FOR ALL REQUIRED PERMITS, BONDS AND OTHER NECESSARY LICENSES OR APPLICATIONS AS REQUIRED BY THE LOCAL AND STATE BUILDING DEPARTMENTS. THE CONTRACTOR SHALL CALL FOR ALL NECESSARY INSPECTIONS AND PERFORM SAME IN ACCORDANCE WITH THE LOCAL REQUIREMENTS. THIS CONTRACTOR SHALL NOT ALLOW ANY PORTION OF HIS WORK TO BE COVERED OR CONCEALED PRIOR TO REQUIRED INSPECTIONS AND WRITTEN NOTICE OF APPROVAL.

THIS CONTRACTOR IS REQUIRED TO MAINTAIN A MANUAL ON SITE CONTAINING THE REQUIRED MSDS SHEETS FOR PRODUCTS, CLEANERS AND OTHER MATERIALS USED ON THIS PROJECT. THE INFORMATION MAY BE GIVEN TO THE JOBSITE OFFICE FOR RECORDS AND REVIEW. THIS CONTRACTOR SHALL FURNISH TO THE JOBSITE SUPERINTENDENT THE NAME OF HIS APPOINTED SAFETY OFFICER AND PHONE NUMBER FOR USE IN THE EVENT OF AN EMERGENCY.

THE FIXTURE SCHEDULE ASSOCIATED WITH THE PLUMBING WORK IS INTENDED TO ESTABLISH THE TYPE AND QUALITY OF FIXTURE REQUESTED BY THE OWNER AND ENGINEER. EQUALS MAY BE USED IF APPROVED BY THE OWNER/ARCHITECT. THIS CONTRACTOR IS REQUIRED TO MEET THE ESTABLISH QUALITY IN ANY CASE, AND WILL BE REQUIRED TO PROVIDE SAME IF THE MATERIAL THEY USED IN THEIR PROPOSAL WAS NOT APPROVED PRIOR TO BIDDING OR IS VIEWED AFTER THE BIDDING NOT TO MEET THE QUALITY REQUIREMENT. IT IS THIS CONTRACTOR'S RESPONSIBILITY TO OBTAIN THE APPROVAL PRIOR TO BID OR RISK IF NOT APPROVED AFTERWARD.

THIS CONTRACTOR SHALL INCLUDE ALL PIPING, DOMESTIC HOT AND COLD WATER, SANITARY SEWER, VENTING, ALL FIXTURES, TRIMS, VALVES, SHUT-OFFS, FAUCETS, PIPE INSULATIONS, AIR OR GAS TRAPS BETWEEN CONDENSATE DISCHARGE, WATER SOFTENER, DISHWASHERS ETC. MUST BE THE SIZE AND LOCATION PER CODE REQUIREMENTS. DRAIN OFFS FROM CONDENSER TYPE FURNACES SHALL BE INSTALLED BY THE MECHANICAL CONTRACTOR FROM APPLIANCE TO FLOOR DRAIN.

ALL WATER SUPPLY PIPING BELOW GROUND SHALL BE TYPE 'K' COPPER TUBING WITHOUT JOINTS. ALL WATER SUPPLY ABOVE GROUND SHALL BE CPVC TUBING. ROOMS SHALL BE PEX (NO DRILLED FITTINGS ALLOWED).

THIS CONTRACTOR SHALL INSULATE ALL ABOVE FLOOR COLD AND HOT WATER PIPING WITH ARMSTRONG COMPANY 'ARMAFLEX' PIPE INSULATION OR EQUAL. SEAL JOINTS WITH ARMTITE. INSULATE ALL PIPING INSTALLED IN THE ATTIC SPACE OR EXTERIOR WALLS WITH A MINIMUM 1" BLANKED FIBER INSULATION TO PROTECT FROM FREEZING ORDER OR BETWEEN UNHEATED SPACES AND THE FINAL PIPE INSTALLATION. THIS CONTRACTOR MUST ASSURE HIMSELF OF THIS PROTECTION BY PROVIDING OR SEE THAT THIS INSULATION IS PROVIDED BY OTHERS WITHIN THE CONSTRUCTION DOCUMENTS.

GAS PIPING FOR HEATING APPLIANCES, FURNACES, WATER HEATERS (IF APPLICABLE) SHALL BE FURNISH AND INSTALLED BY THE PLUMBING CONTRACTOR. REFER TO HVAC PLANS FOR SIZE AND APPROXIMATE LOCATION AND DISTRIBUTION REQUIREMENTS. GAS PIPING SHALL BE STANDARD WEIGHT, BLACK STEEL PIPE, SCHEDULE 40. ANY PIPING EXPOSED TO CORROSIVE ATMOSPHERE OR RUN BELOW GRADE SHALL HAVE POLYETHYLENE PLASTIC COATING. ALL GAS PIPING, FITTINGS AND INSTALLATION SHALL BE IN ACCORDANCE WITH THE SERVING UTILITY COMPANY AND ALL OTHER APPLICABLE CODES.

ALL DOMESTIC WATER PIPING SHALL BE SIZED ACCORDING TO CODE FOR THE FIXTURE UNITS BEING SERVED. 3/4" DIA. PIPING TO THE NEXT TO LAST FIXTURE ON ANY RUN SHALL BE MAINTAINED. THE PLUMBING CONTRACTOR SHALL PROVIDE ADEQUATE VOLUME OR PRESSURE TO ALL FLUSH VALVE OPERATED FIXTURES. A MINIMUM 1" X 1/2" VERTICAL AIR COMPRESSION CHAMBER SHALL BE INSTALLED AT THE END OF EACH SUPPLY RUN TO ARREST HAMMERING WHEN FAUCETS ARE TURNED OFF.

PROVIDE STOPS ON WATER SUPPLIES TO EACH FIXTURE.

ALL FIXTURE FITTINGS AND GASKETS FOR FIXTURE PIPING SHALL BE BRASS CHROMIUM PLATED. ALL EXPOSED TRAPS SHALL BE CHROME PLATED. ALL FIXTURES UNLESS SPECIFICALLY ADDRESSED OTHERWISE, SHALL BE WHITE. WATER CLOSET SEATS SHALL BE ELONGATED, OPEN FRONT TYPE.

EXTERIOR WALL HYDRANTS SHALL BE FROST-PROOF 'KEYED' TYPE.

UPON COMPLETION OF HIS RESPECTIVE WORK, THIS CONTRACTOR SHALL FURNISH OPERATING MANUALS, FIXTURE CUTS, CATALOG INFORMATION CONTAINING REPLACEMENT PARTS INFORMATION AND MAINTENANCE REQUIREMENTS, RECORD DRAWING INDICATING VARIATIONS FROM PLANS, AND 3 COPIES OF FIXTURE CUTS, MANUFACTURER, PRODUCT INFORMATION TO THE ENGINEER FOR PLACEMENT IN THE CLOSEOUT MAINTENANCE MANUAL.

THE PLUMBING CONTRACTOR SHALL BE RESPONSIBLE FOR THE TESTING AND SUCH DEVICES AS TO ASSURE THE OWNER OF A QUALITY INSTALLATION. THE WORK, ONCE ACCEPTED BY THE OWNER (OR OCCUPIED) SHALL BE GUARANTEED FOR A PERIOD OF ONE (1) YEAR AGAINST DEFECTS IN MATERIAL OR WORKMANSHIP. ANY MATERIAL OR INSTALLATION FOUND TO BE FAULTY OR IN NON-COMPLIANCE WITH THE CODES (EXCEPT FOR OWNER ABUSE) SHALL BE REPAIRED/REPLACED OR CORRECTED TO THE SATISFACTION OF THE ENGINEER/ OWNER AT NO ADDITIONAL COST TO THE OWNER.

RELATED WORK TO BE PROVIDED BY OTHERS:

- EXTERIOR STORM-WATER SEWER WORK, (INTERIOR WORK BY P.C.)
- TOILET PARTITION AND ACCESSORIES MATERIAL AND LABOR
- KITCHEN EQUIPMENT MATERIAL ONLY, (HOOK-UP OF PLUMBING BY P.C.)
- VANITIES AND SINK CASEWORK MATERIAL AND INSTALLATION

SPECIAL WATER TREATMENT DEVICES, SERVICES, (I.E. WATER SOFTENERS) SHALL BE COORDINATED WITH SYSTEM SUPPLIER. THE EQUIPMENT AND INSTALLATION SHALL BE IN ACCORDANCE WITH CODES AND MANUFACTURER'S RECOMMENDATIONS, PROVIDE PIPING WHERE APPLICABLE, INCLUDING UNIONS, HARNESSES, YOKES, ETC. AS REQUIRED.

THE PLUMBING CONTRACTOR SHALL CONFIRM THE WATER PRESSURE AT THE MAIN CONNECTION WITH THE CITY, AND RELAY THAT INFORMATION TO THE ARCHITECT TO SIZE THE BOOSTER PUMP.

SPECIAL WATER TREATMENT DEVICES, SERVICES, (I.E. WATER SOFTENERS) SHALL BE COORDINATED WITH SYSTEM SUPPLIER. THE EQUIPMENT AND INSTALLATION SHALL BE IN ACCORDANCE WITH CODES AND MANUFACTURER'S RECOMMENDATIONS, PROVIDE PIPING WHERE APPLICABLE, INCLUDING UNIONS, HARNESSES, YOKES, ETC. AS REQUIRED.

GAS WATER HEATER SCHEDULE

HOT WATER RETICULATING PUMP SCHEDULE

ELEVATOR SUMP PUMP (SP-1) SCHEDULE

MARK	MANUFACTURER	SIZE	MODEL NUMBER	BODY	GRATE	NOTES
FD-1	JOSAM	2" DIAMETER	30002	C.I.	-	-
FD-2	JOSAM	4" DIAMETER	30504	C.I.	-	SEE 9/5102 AND 10/5102
TD-1	JOSAM	2" DIAMETER	100C	SMC/GRP	STN STL OR PLMR	OR SIMILAR
FS-1	JOSAM	4" DIAMETER	49324-NB	NIKALOY	STAINLESS STL	-
DS	JOSAM	4" DIAMETER	25014	NICKEL BRONZE	-	DOWNSPOUT NOZZLE OVERFLOW
RD	JOSAM	4" DIAMETER	22504	C.I.	-	-
OD	JOSAM	4" DIAMETER	22504	C.I.	-	-
CI - CAST IRON B - BRONZE PVC - POLY VINYL CHLORIDE			VP - VANDAL PROOF SMC/GRP - SHEET MOLDED COMPOUND/ GLASS-FIBER REINFORCED POLYESTER PLMR - POLYMER			

BOOSTER PUMP SCHEDULE

NOTE:

ALL GUESTROOM SHOWER HEADS (FIXED OR HAND-HELD) MUST BE MULTI-FUNCTION WITH ADJUSTABLE FLOW RATE WITH FINE & COURSE SPRAY. ACCESSIBLE ADA GUEST BATHROOMS MUST HAVE BOTH FIXED SHOWER HEADS AND HAND-HELD SHOWERS OFFERING THE SAME FUNCTIONS

ALL GUEST BATHROOM VANITY FAUCETS MUST HAVE LEVER ACTIVATED WASTE STOPPERS

ROUGH-IN HEIGHT FOR THE SHOWERED HEAD MUST BE A MINIMUM OF 6'-10" ABOVE THE BATHROOM FINISH FLOOR

ABOVE FLOOR PLUMBING TRAPS FOR TUBS ARE NOT PERMITTED

ANY DRAIN PIPE, P-TRAP, AND/OR SUPPLY LINES EXPOSED TO VIEW BENEATH THE VANITY OR BEHIND THE WATER

PROVIDING SAME TYPE SHOWER HEAD FOR BOTH FIXED AND HAND-HELD - TYP. AT ALL GUESTROOM BATHROOM
CLOCKERS / TUBS

PROVIDES SINGLE-LEVER OR DUAL-LEVER HANDLE 5.5 INCHES WITH LEVER 1.5 INCHES LONG, 1.5 INCHES STOPPED, 1.5 INCHES AT ALL

GUEST ROOM BATHROOM FAUCETS

OPTIONAL BUT RECOMMENDED AT DRINKING FOUNTAINS - PROVIDE A WALL MOUNTED WATER COOLER WITH BUILT-IN WATER BOTTLE FILLING STATION FOR GUEST USE. SIMILAR TO ELKAY EZH2O 1.75L Btl ISSR

GENERAL NOTES:

ALL BUILDING REQUIREMENTS TO FOLLOW SPECIFICATIONS PER HILTON LATEST STANDARDS. CONTRACTOR MUST MAKE THEIR COMPANY FAMILIAR WITH THOSE STANDARDS SET FORTH BY HILTON.

ALL DRAWINGS SUBJECT TO CHANGE IF DRAWINGS CONFLICT WITH HILTON STANDARDS.

MARK	FIXTURE	SOIL	WASTE	VENT	H.W.	C.W.	REMARKS
WC-1	HANDICAP WATER CLOSET GUEST ROOM	3'	_____	2'	_____	1/2"	KOHLER K-20197 ADA BETELLO COMFORT HEIGHT TWO-PIECE TOILET, ELONGATED BOWL LEFT HANDED TRIP LEVER SEAT NOT INCLUDED, 1.28 GALLONS PER FLUSH, PROVIDE QUITE-CLOSE SEAT.
WC-2	WATER CLOSET GUEST ROOM	3'	_____	2'	_____	1/2"	AMERICAN STANDARD MODEL #2514.1015.020, PROVIDE QUITE-CLOSE SEAT.
WC-1P	HANDICAP WATER CLOSET PUBLIC AREA	3'	_____	2'	_____	1"	KHOLER K-96057-0 WHITE ADA COMPLIANT ELONGATED, FLOOR MOUNT, FLUSHOMETER BOWL VITREOUS CHINA, HIGHLIGHT ULTRA BOWL, 26-3/8" X 14-5/8" X 16-7/8", 1.1 TO 1.6 GPF, COMMERICAL TOILET SEAT K-4731-GC-01 FLUSHOMETER K-7631 TRIP ONT HES 1.28 GPM WC, MUST HAVE A COMMERCIAL GRADE WHITE, SLOW-CLOSE OPEN FRONT PLASTIC SEAT, THE SEAT MUST REMAIN IN AN UPRIGHT POSITION WITHOUT BEING HELD
T-1	HANDICAP BATHTUB GUEST ROOM	_____	2'	1-1/2'	1/2"	1/2"	AMERICAN STANDARD 2390.202 (RIGHT OR LEFT HAND AS REQUIRED), 60X30X14", ACID RESISTANT TUB, WITH TILTING FLANGE AND FRONT APRON, MOEN #3233EPN SHOWER HEAD, MOEN #72131BN SINGLE LEVER VALVE #3353 DIVERTER TUB SPOUT #62370 ROUGH-IN VALVE, #74171BN DIVERTER VALVE TRIM, #3372 TRANSFER VALVE, A730ST BRACKET, A725BN DROP ELBOW, MOEN #3355BEPN HAND HELD SHOWER UNIT, LIFT & TURN WASTE CONNECTION, BRUSHED NICKEL TRIM. CEILING HEIGHT SURROUND REQUIRED AT BATHTUB
LAV-1	HANDICAP LAVATORY GUEST ROOM	_____	2'	1-1/2'	1/2"	1/2"	LENOVA #PU-01-1W, 19 1/2 X 15 1/2 UNDERMOUNT RECTANGULAR VITREOUS CHINA LAVATORY MODEL #6400BN EVA SINGLE LEVER, BRUSHED NICKEL FAUCET, COMPRESSION STOPS, 1 P-TRAP, TRUBO CR. #102IN ADA INSULATION KIT, IN GUEST ROOMS WITH FLOOR DRAINS IN TOILET AREA, FURNISH P-TRAP WITH PRIMER CONNECTION AND 3/4" PRIMER LINE TO FLOOR DRAIN. OMNI 1/2 GPM OR EQUAL FLOW RESTRICTOR.
LAV-2	LAVATORY GUEST ROOM	_____	2'	1-1/2'	1/2"	1/2"	LENOVA #PU-01-1W, 19 1/2 X 15 1/2 UNDERMOUNT RECTANGULAR VITREOUS CHINA LAVATORY MODEL #6400BN EVA SINGLE LEVER, BRUSHED NICKEL FAUCET, COMPRESSION STOPS, 1 P-TRAP, OMNI 1/2 GPM OR EQUAL FLOW RESTRICTOR.
LV3	HANDICAP WALL HUNG LAVATORY	_____	2'	1-1/2'	1/2"	1/2"	KOHLER #K-2084 BN 20X18 WALL HUNG ADA APPROVED LAVATORY AND CHAIR CARRIER, K-104536-SANA KOHLER TOUCH LESS FAUCET, K-84948-CP KOHLER P-TRAP AND TRUBO ADA INSULATION KIT. OMNI 1/2 GPM OR EQUAL FLOW RESTRICTOR.
SH-1	HANDICAP SHOWER STALL	_____	2'	1-1/2'	1/2"	1/2"	34"x60" HIGH GLOSS VIKRELL WHITE SINGLE PC. SHOWER PAN WITH DRAIN IN CENTER OF PAN, SURROUNDS "MINEY MARBLE MANUFACTURING INC." #75-DS PANELS MUST EXTEND CEILING, EXACT SIZE TO BE FIELD VERIFIED, FINISH TO BE AURORA OR LINEN, MATTE FINISH 1/4" 'OLD WORLD STYLE' OR DIAMOND DESIGN SURROUND 1/4" 2 SURFACE MOUNT SOAP DISHES (INCLUDING CORNER) & 2" TRIM PIECES (OPT.) MUST HAVE GRAB BARS AND ADA COMPLIANT. MOEN #3233EPN SHOWER HEAD SHOWER HEAD, BRUSHED NICKEL MOEN #72131BN SHOWER VALVE #3353 DIVERTER TUB SPOUT #62370 POSI-TEMP VALVE #74171BN DIVERTER VALVE TRIM #3372 TRANSFER VALVE #A726ST, MOEN #3355BEPN HAND HELD SHOWER UNIT SURROUNDS MAY NOT HAVE SEAMS OR FILLER STRIPS AND FINISH MUST COOR. WITH VANITY COUNTERTOP. CONFIRM PATTERN WITH OWNER.
SH-2	SHOWER UNIT	_____	2'	1-1/2'	1/2"	1/2"	34"x60" HIGH GLOSS VIKRELL WHITE SINGLE PC. SHOWER PAN WITH DRAIN IN CENTER OF PAN, SURROUNDS "MINEY MARBLE MANUFACTURING INC." #75-DS PANELS MUST EXTEND CEILING, EXACT SIZE TO BE FIELD VERIFIED, EXPOSED AND VISIBLE EDGES OF SURROUND PANELS MUST HAVE A FACTORY-FINISHED EDGE, FINISH TO BE AURORA OR LINEN, MATTE FINISH 1/4" 'OLD WORLD STYLE' OR DIAMOND DESIGN SURROUND 1/4" 2 SURFACE MOUNT SOAP DISHES (INCLUDING CORNER) & 2" TRIM PIECES (OPT.) MOEN #3233EPN SHOWER HEAD SHOWER HEAD, BRUSHED NICKEL MOEN #74171BN SHOWER ARM WITH FLANGE, MOEN #72131 SINGLE LEVER VALVE AND #62370 POSI-TEMP ROUGH-IN VALVE. SURROUNDS MAY NOT HAVE SEAMS OR FILLER STRIPS AND FINISH MUST COOR. WITH VANITY COUNTERTOP. CONFIRM PATTERN WITH OWNER.
SK-1	HANDICAP KITCHEN SINK GUEST ROOM	_____	2'	1-1/2'	1/2"	1/2"	ELKAY #ELLH4D211545P UNDERMOUNT STAINLESS STEEL ADA SINK, FAUCET KOHLER K-780-V5 CRUETTE THREE HOLE KITCHEN SINK FAUCET WITH PULL DOWN SPOUT AND LEVER HANDLE, AND WHIRLAWAY #191PC 3/4 HP DISPOSAL UNIT. OMNI 1/2 GPM OR EQUAL FLOW RESTRICTOR. COMPRESSION STOPS, P-TRAP
SK-2	KITCHEN SINK GUEST ROOM	_____	2'	1-1/2'	1/2"	1/2"	ELKAY #ELLH4D2115 UNDERMOUNT STAINLESS STEEL SINK, FAUCET KOHLER K-780-V5 CRUETTE THREE HOLE KITCHEN SINK FAUCET WITH PULL DOWN SPOUT AND LEVER HANDLE, AND WHIRLAWAY #191PC 3/4 HP DISPOSAL UNIT. OMNI 1/2 GPM OR EQUAL FLOW RESTRICTOR. COMPRESSION STOPS, P-TRAP
SK-3	BREAK ROOM DOUBLE COMPARTMENT KITCHEN SINK	_____	1-1/2'	1-1/2'	1/2"	1/2"	TOP MOUNT DOUBLE BOWL SINK BY KOHLER #K-3361-4-NA, SINK FAUCET BY KOHLER BRUSHED NICKEL #K-15172-WF-CP, K-8801-CP BASKET STRAINER, COMPRESSION STOPS, 1 1/2" P-TRAP AND WHIRLAWAY #191PC 3/4 HP DISPOSAL UNIT. OMNI 1/2 GPM OR EQUAL FLOW RESTRICTOR.
SK-4	3-COMP SINK BY OWNER	_____	(3) 2'	1-1/2'	(2) 3/4"	(2) 3/4"	STAINLESS STEEL SINK & FAUCETS PROVIDED BY OWNER, CONTRACTOR SHALL INSTALL SINK & FAUCET & PROVIDE ROUGH-IN WITH ALL RELATED PIPING WITH SHUT-OFF VALVES AT WALL. ADVANCE TABCO 94-24-60-24RL 3 BAY SINK, 115L W/ (2) 24" DRAIN BOARDS, ONE WALL MOUNTED PRE RINSE FAUCET, ONE WALL MOUNT FAUCET WITH SWING NOZZLE
SK-5	KITCHEN SINK BY OWNER	_____	2'	1-1/2'	1/2"	1/2"	KITCHEN SINK & FAUCETS PROVIDED BY OWNER, CONTRACTOR SHALL INSTALL SINK AND FAUCET & PROVIDE ROUGH-IN WITH ALL RELATED PIPING WITH SHUT-OFF VALVES AT WALL.
SK-6	HYDRATION STATION LOBBY	_____	2'	1-1/2'	1/2"	1/2"	HYDRATION STATION IS PART OF THE FOOD SERVICE EQUIPMENT SPECS; PROVIDE MARCO FRIDA HCS & COORDINATE W/ ELECTRICAL
SK-7	KITCHEN SINK	_____	2'	1-1/2'	1/2"	1/2"	WORKTABLE WITH SINK SHALL BE SHAPED AND SIZED AS DETAILED ON THE DRAWINGS APPROXIMATELY 6'-3X2'-3" X 3'-0" HIGH TO INCLUDE: ONE (1) 1'-0" X 1'-4" X6" DEEP SINKS WITH ONE (1) T & S MODEL B-0231-CR-KIT FAUCET WITH MODEL B-0149-01-NOS, 5 GPM LOW FLOW FAUCET AND ONE (1) T & S MODEL B-3450 ROTARY WASTE DRAIN PROVIDE BACK SPLASH AS SHOWN ON
LT-1	DOUBLE LAUNDRY TUB	_____	2'	1-1/2'	1/2"	1/2"	FIAT #FLD111 MOLDED STONE DOUBLE BOWL LAUNDRY SINK WITH LEGS, LAUNDRY TRAY, A-1 FAUCET, P-TRAP AND ANGLE STOPS HARDWARE PACKAGE.
DF-1	DRINKING FOUNTAIN	_____	2'	2'	_____	1/2"	MOST DEPENDABLE FOUNTAIN MODEL NO. 475 (DUAL) COOLER, MCGUIRE #872 P-TRAP, MCGUIRE 165 SUPPLY AND STOP, PROVIDE IN WALL P-TRAPS, CUT-OFF VALVE AND DRAIN VALVE ALL IN ACCESSIBLE PANEL.
PS	POOL SHOWER	_____	_____	_____	1/2"	1/2"	DELTA #R-10000-LINK-S ROUGH-IN VALVE, DELTA #T13H163 SHOWER TRIM WITH FIXED VANDAL RESISTANT HEAD.
MGB-1	MOP SINK	_____	2'	1-1/2'	3/4"	3/4"	FIAT #TBS 3000 24"x24"x12" DEEP FLOOR MOUNTED MOP BASIN, T & S BRASS B-665-BSTR WALL MOUNTED SINK FAUCET W/ V.B. 55 MOP HANGER, HOSE & BRACKET, WITH 55 WALL GUARDS.
EW	WALL HUNG EYE WASH	_____	1-1/4"	1-1/2'	1/2"	1/2"	GUARDIAN #G1814P WITH YELLOW PLASTIC EYE/FACE WASH HEADS, WITH DUST COVERS, 3/4" NPT CHROME PLATED BRASS 55AY OPEN BALL VALVE WITH 55 PUSH HANDLE, DRAIN TAIL PIECE TO WITHIN 6" OF FINISHED FLOOR AND IN-LINE STRAINER. GUARDIAN G3600 MIXING VALVE SET FOR 85 DEGREE WATER.
WB-1	WASHER CONNECTION BOX	_____	2'	_____	3/4"	3/4"	GUY GRAY #32048 WITH WATER HAMMER ARRESTOR, INSTALL BACKFLOW CHECK VALVES FOR VALVES IN HW & CW LINES WITH ACCESS PANEL
TMV	THERMAL MIXING VALVE	_____	_____	_____	_____	_____	
CP-1	CIRCULATING PUMP	_____	_____	_____	_____	_____	BELL & GOSSETT 100 SERIES SEE SCHED. THIS SHEET IN-LINE BRONZE CIRCULATING P

GENERAL NOTES

GENERAL NOTES

* Architects
* Planners
* Consultants
* Construction Mgmt.
* Rule 5 and MS4 Filing

PHONE (574) 537-8500
FAX (574) 537-0808

M MAUST
ARCHITECTURAL
SERVICES
DIVISION OF
L.E.M., INC.
112 NORTH MAIN STREET
GOSHEN, INDIANA 46526



SHEET SIZE 24x36

FT. WAYNE, INDIANA

REVISIONS:

PRELIMINARY - NOT
FOR CONSTRUCTION

DATE: 05/01/20

JOB NO.: MAS-26-105

PLUMBING NOTES AND

GUEST:

P001