

GENERAL NOTES

1.00 GENERAL

1.01

ALL CONSTRUCTION SHALL CONFORM TO THE INDIANA BUILDING CODE -2012 (IGC, 2012 EDITION). REFERENCES TO OTHER STANDARD SPECIFICATIONS OR CODES SHALL MEAN THE LATEST STANDARD OR CODE ADOPTED.

1.02

DRAWINGS SHOW TYPICAL AND CERTAIN SPECIFIC CONDITIONS ONLY. FOR DETAILS NOT SPECIFICALLY SHOWN, PROVIDE DETAILS SIMILAR TO THOSE SHOWN.

1.03

VERIFY ALL EXISTING CONDITIONS, DIMENSIONS AND ELEVATIONS BEFORE STARTING WORK. NOTIFY STRUCTURAL ENGINEER OF ANY DISCREPANCY.

1.04

NOTIFY THE STRUCTURAL ENGINEER IN WRITING OF CONDITIONS ENCOUNTERED IN THE FIELD CONTRADICTORY TO THOSE SHOWN ON THE STRUCTURAL CONTRACT DOCUMENTS.

1.05

THE CONTRACTOR IS SOLELY RESPONSIBLE FOR THE DESIGN, ADEQUACY, AND SAFETY OF ERECTION BRACING, SHORING, TEMPORARY SUPPORTS, ETC.

1.06

COORDINATE STRUCTURAL CONTRACT DOCUMENTS WITH ARCHITECTURAL, MECHANICAL, ELECTRICAL, PLUMBING AND CIVIL. NOTIFY STRUCTURAL ENGINEER OF ANY CONFLICT AND/OR OMISSION.

1.07

COORDINATE AND VERIFY FLOOR AND ROOF OPENING SIZES AND LOCATIONS WITH ARCHITECTURAL, MECHANICAL, PLUMBING AND ELECTRICAL DRAWINGS. FOR ADDITIONAL OPENINGS NOT SHOWN ON THE STRUCTURAL DRAWINGS SEE ARCHITECTURAL AND MECHANICAL DRAWINGS.

1.08

FOR DIMENSIONS NOT SHOWN SEE ARCHITECTURAL DRAWINGS.

1.09

REVIEW OF SUBMITTALS AND/OR SHOP DRAWINGS BY THE STRUCTURAL ENGINEER DOES NOT RELIEVE THE CONTRACTOR OF THE RESPONSIBILITY TO REVIEW AND CHECK SHOP DRAWINGS BEFORE SUBMITTAL TO THE STRUCTURAL ENGINEER. THE CONTRACTOR REMAINS SOLELY RESPONSIBLE FOR ERRORS AND OMISSIONS ASSOCIATED WITH THE PREPARATION OF SHOP DRAWINGS AS THEY PERTAIN TO MEMBER SIZES, DETAILS, AND DIMENSIONS SPECIFIED IN THE CONTRACT DOCUMENTS. CONTRACTOR IS RESPONSIBLE FOR MEANS, METHODS, TECHNIQUES, SEQUENCES, AND PROCEDURES OF CONSTRUCTION.

1.10

THE STRUCTURAL DESIGN OF BUILDING IS BASED ON THE FULL INTERACTION OF ALL ITS COMPONENT PARTS, WITH NO PROVISION FOR CONDITIONS OCCURRING DURING CONSTRUCTION. THEREFORE, CONTRACTOR SHALL PROVIDE ADEQUATE BRACING DURING CONSTRUCTION.

1.11

SUPERIMPOSED DESIGN LIVE LOADS:

TYPICAL ROOF

45 PSF LL / 25 DL

ROOF SUPPORTING A/C UNITS

30 PSF (OR WEIGHT OF EQUIP. IF GREATER)

DWELLING ROOMS

40 PSF

CORRIDORS

100 PSF

INDOOR ASSEMBLY ROOMS & PUBLIC TERRACES

100 PSF (1.33 LDF FOR WOOD PERMITTED)

STAIR

100 PSF (1.33 LDF FOR WOOD PERMITTED)

REDUCTION OF UNIFORM LIVE LOAD BASED ON TRIBUTARY IS TAKEN AS ALLOWED BY CODE SECTION 1607.9

WIND DESIGN CRITERIA:

o BASIC WIND SPEED (3 SECOND GUST)

115 MPH

o BUILDING OCCUPANCY CATEGORY

II

o WIND IMPORTANCE FACTOR

Iw=1.0

o WIND EXPOSURE CATEGORY

B

o WIND BASE SHEAR, X-DIR:

V=111 KIPS

o WIND BASE SHEAR, Y-DIR:

V= 43 KIPS

SEISMIC DESIGN CRITERIA:

o BUILDING OCCUPANCY CATEGORY

II

o SEISMIC IMPORTANCE FACTOR

Ie=1.0

o DESIGN SPECTRAL RESPONSE ACCELERATION, 0.2 SECONDS

Sds= 0.195 g

o DESIGN SPECTRAL RESPONSE ACCELERATION, 1.0 SECONDS

Sd1= 0.108 g

o SITE CLASS

D

o SEISMIC DESIGN CATEGORY

B

o SEISMIC RESISTING SYSTEM:

LIGHT FRAMED WALLS WITH SHEAR PANELS
SHEATHED WITH WOOD STRUCTURAL PANELS - RATED FOR SHEAR

o RESPONSE MODIFICATION COEFFICIENT

R=2

o DEFLECTION AMPLIFICATION FACTOR

Cd=2

ANALYSIS PROCEDURE: EQUIVALENT LATERAL FORCE PROCEDURE

o SEISMIC BASE SHEAR:

V= 47.2 KIPS

SNOW DESIGN CRITERIA:

o GROUND SNOW LOAD

Pg= 30 PSF

o FLAT ROOF SNOW LOAD

Pf= 21 PSF

o SLOPED ROOF SNOW LOAD

Ps= 21 PSF

2.00 FOUNDATIONS AND SLAB-ON-GROUND

2.01

CONSULT WITH OWNER'S GEOTECHNICAL ENGINEER AND SEE PROJECT'S REPORT OF SUBSURFACE EXPLORATION AND GEOTECHNICAL ENGINEERING EVALUATION FOR SITE PREPARATION REQUIREMENTS, SOIL MODIFICATION REQUIREMENTS, RECOMMENDED GROUND IMPROVEMENT TECHNIQUES, FILL PLACEMENT REQUIREMENTS, SPECIFIC FOUNDATION SUBGRADE PREPARATION REQUIREMENTS, UNDER-SLAB DRAINAGE REQUIREMENTS, SITE DEWATERING REQUIREMENTS, AND OTHER EARTHWORK REQUIREMENTS.

2.02

THE DESIGN OF CONCRETE FOUNDATIONS IS BASED ON A MINIMUM ALLOWABLE NET SOIL BEARING PRESSURE OF 2,000 PSF.

2.03

GEOTECHNICAL ENGINEER SHALL VERIFY CONDITION AND ADEQUACY OF ALL SUBGRADES, FILLS, AND BACKFILLS BEFORE PLACEMENT OF FOUNDATIONS, SLABS, AND WALLS.

2.04

ALL STRUCTURAL FILL PLACED WITHIN 10 FT OF PROPOSED FOUNDATIONS AND SLABS SHALL BE COMPACTED TO AT LEAST 95% OF STANDARD PROCTOR MAX DRY DENSITY, AS DETERMINED BY ASTM D-698. THE UPPER FOOT OF ANY FILL SHOULD BE COMPACTED TO AT LEAST 98% OF STANDARD PROCTOR MAX DRY DENSITY. STRUCTURAL FILL SHALL BE FREE OF ORGANIC MATERIAL, HAVE A PLASTICITY INDEX (PI) LESS THAN 20 AND CONTAIN ROCK SIZES NO LARGER THAN 4".

2.05

SEE REFERENCED GEOTECHNICAL REPORT FOR SOIL SCARIFICATION AND RECOMPACTION REQUIREMENTS.

2.06

SIDES OF FOUNDATIONS SHALL BE FORMED UNLESS CONDITIONS PERMIT EARTH FORMING. FOUNDATIONS POURED AGAINST EARTH REQUIRE THE FOLLOWING PRECAUTIONS: SLOPE SIDES OF EXCAVATIONS AS APPROVED BY GEOTECHNICAL ENGINEER AND CLEAN UP SLOUGHING BEFORE AND DURING CONCRETE PLACEMENT.

2.07

FOOTING STEPS SHALL BE NO STEEPER THAN ONE VERTICAL TO TWO HORIZONTAL, UNLESS NOTED.

2.08

DO NOT BACKFILL AGAINST FOUNDATION WALLS UNTIL THE WALL HAS REACHED 65% OF DESIGN STRENGTH, FRAMED SLAB BEARING ON WALLS IS CAST, OR TEMPORARY WALL BRACING HAS BEEN PLACED.

2.09

UNLESS NOTED OTHERWISE, TYPICAL SLAB-ON-GRADE SHALL BE MINIMUM 4" THICK CONCRETE, OVER VAPOR BARRIER, OVER MIN. 4" LAYER OF SANDY GRAVEL, OVER COMPACTED SUBGRADE APPROVED BY THE GEOTECHNICAL ENGINEER.

2.10	VAPOR BARRIER SHALL BE MINIMUM 10-MIL THICK AND CONFORM TO ASTM E1745, CLASS A. CONTRACTOR SHALL TAKE CARE TO PROTECT VAPOR BARRIER FROM DAMAGE PRIOR TO AND DURING PLACEMENT OF CONCRETE. 2" SAND LAYER MAY BE PROVIDED ABOVE VAPOR BARRIER TO PROVIDE PROTECTION. TAPE VAPOR BARRIER JOINTS AND REPAIR ANY DAMAGED SECTIONS OF VAPOR BARRIER PER MANUFACTURER'S SPECIFICATIONS.	
2.11	UNLESS NOTED OTHERWISE, REINFORCE SLAB WITH ONE LAYER 6x6-#2, 14x2, 1 1/4x4, POSITIONED 1.5' CLEAR FROM TOP OF SLAB. 1/4x4 SHALL BE POSITIVELY SUPPORTED; "HOOKING" OF 1/4x4 IS NOT PERMITTED. PROVIDE #4 SUPPORT BARS, CHAIRS, AND CONCRETE BRICKS AS MAY BE REQUIRED TO POSITION 1/4x4. SLABS ON GROUND REINFORCED WITH FIBERFESH IS AN ACCEPTABLE ALTERNATIVE TO THE USE OF WELDED WIRE FABRIC.	
2.12	UNLESS NOTED OTHERWISE, PLACE CONTROL JOINTS AT SLAB-ON-GRADE SUCH THAT AREA OF EACH PANEL DOES NOT EXCEED 225 SQUARE FEET. CONTROL JOINTS SHALL BE SAW-CUT AS SOON AS PRACTICAL AND WITHIN 12 HOURS OF PLACING CONCRETE. LOCATE CONSTRUCTION JOINTS AT CONTROL JOINTS, SUBJECT TO PRIOR APPROVAL.	
2.13	CONTRACTOR TO INCLUDE THE COST OF TESTING BY AN INDEPENDENT TESTING AGENCY. OWNER AND CONTRACTOR TO RECEIVE ALL REPORTS.	
	<u>3.00 REINFORCED CONCRETE</u>	
3.01	ALL CONCRETE WORK SHALL CONFORM TO ACI 301, SPECIFICATIONS FOR STRUCTURAL CONCRETE FOR BUILDINGS.	
3.02	UNLESS NOTED OTHERWISE, ALL CONCRETE SHALL BE NORMAL WEIGHT AND HAVE THE FOLLOWING MINIMUM 28-DAY COMPRESSIVE STRENGTHS:	
	o SLAB-ON-GRADE	3500 PSI NORMAL WEIGHT
	o FOUNDATIONS AND WALLS	3500 PSI NORMAL WEIGHT
3.03	THE PROPOSED MATERIALS AND MIX DESIGNS SHALL BE FULLY DOCUMENTED AND REVIEWED BY THE OWNER'S TESTING LABORATORY AND THE STRUCTURAL ENGINEER. THE CONTRACTOR IS RESPONSIBLE FOR OBTAINING THE REQUIRED DESIGN STRENGTH.	
3.04	USE OF CALCIUM CHLORIDE, CHLORIDE IONS, OR OTHER SALTS IN CONCRETE IS NOT PERMITTED.	
3.05	HORIZONTAL CONSTRUCTION JOINTS ARE PERMITTED ONLY WHERE INDICATED. THE LOCATION OF VERTICAL CONSTRUCTION JOINTS SHALL BE APPROVED BY THE STRUCTURAL ENGINEER. CONSTRUCTION JOINTS SHALL BE THOROUGHLY ROUGHENED BY MECHANICAL MEANS AND CLEANED.	
3.06	CHAMFER OR ROUND ALL EXPOSED CORNERS MINIMUM 3/4".	
3.07	DETAIL CONCRETE REINFORCEMENT AND ACCESSORIES IN ACCORDANCE WITH ACI DETAILING MANUAL, LATEST EDITION. SUBMIT SHOP DRAWINGS FOR APPROVAL, SHOWING ALL FABRICATION DIMENSIONS AND LOCATIONS FOR PLACING REINFORCING STEEL AND ACCESSORIES. DO NOT BEGIN FABRICATION UNTIL SHOP DRAWINGS ARE COMPLETED AND REVIEWED.	
3.08	REINFORCING STEEL SHALL CONFORM TO ASTM A615, GRADE 60, UNLESS NOTED OTHERWISE.	
3.09	WELDED WIRE FABRIC SHALL CONFORM TO ASTM A185 AND SHALL BE PLACED AS FLAT SHEETS. ROLLS OF WELDED WIRE FABRIC ARE NOT PERMITTED. LAP W/WF SHEETS MINIMUM 6".	
3.10	TIE ALL REINFORCING STEEL AND EMBEDMENTS SECURELY IN PLACE PRIOR TO PLACING CONCRETE. PROVIDE SUFFICIENT SUPPORTS TO MAINTAIN THE POSITION OF REINFORCEMENT WITHIN SPECIFIED TOLERANCES DURING ALL CONSTRUCTION ACTIVITIES. "HOOKING" WELDED WIRE FABRIC DURING CONCRETE PLACEMENT IS NOT PERMITTED. "STICKING" DOWELS INTO WET CONCRETE IS NOT PERMITTED.	
3.11	PROVIDE CONTINUOUS REINFORCEMENT WHEREVER POSSIBLE; SPLICE ONLY AS SHOWN OR APPROVED; STAGGER SPLICES WHERE POSSIBLE; USE TENSION SPLICE (CLASS 'B') UNLESS NOTED OTHERWISE. DOWELS SHALL MATCH THE SIZE AND SPACING OF THE SPECIFIED REINFORCEMENT AND SHALL BE LAPPED WITH TENSION SPLICES (CLASS 'B') UNLESS NOTED OTHERWISE.	
3.12	REINFORCING STEEL SHALL HAVE THE FOLLOWING CONCRETE COVER UNLESS NOTED OTHERWISE:	
	CONCRETE AGAINST EARTH (NOT FORMED)	3"
	FORMED CONCRETE EXPOSED TO EARTH OR WEATHER	
	#6 THROUGH #10 BARS	2"
	#5 BARS AND SMALLER	1 1/2"
	CONCRETE NOT EXPOSED TO EARTH OR WEATHER	
	SLABS AND WALLS	3/4"
3.13	DO NOT WELD OR TACK WELD REINFORCING STEEL UNLESS APPROVED OR DIRECTED BY THE STRUCTURAL ENGINEER.	

4.00 WOOD FRAMING

4.01	WOOD FRAMING CONNECTIONS SHALL BE MADE WITH GALVANIZED STEEL JOIST HANGERS UNLESS NOTED OTHERWISE.	
4.02	THE MINIMUM REQUIRED ALLOWABLE DESIGN STRESSES FOR ENGINEERED LUMBER BEAMS (LVL AND PSJ) SHALL BE AS FOLLOWS:	
	F _c =	2,510 PSI
	F _c =	750 PSI
	F _b =	2,600 PSI
	F _v =	285 PSI
	E =	1,900,000 PSI
4.03	ALL VERTICAL FRAMING MEMBERS (STUDS & POSTS) SHALL BE No. 2 DOUGLAS FIR OR #2 SPRUCE PINE FIR, UNO. ALL HORIZONTAL MEMBERS (JOISTS, BEAMS, PLATES, & BLOCKING) SHALL BE No. 2 SYP, UNO.	
4.04	ALL LUMBER IN CONTACT WITH GROUND, CONCRETE, OR EXPOSED TO WEATHER SHALL BE PRESSURE TREATED. ALL METAL EXPOSED TO WEATHER OR IN CONTACT WITH PRESSURE TREATED LUMBER SHALL BE STAINLESS STEEL, HOT-DIPPED GALVANIZED (MIN. G180) OR OTHERWISE PROTECTED AGAINST CORROSION.	
4.05	BRACE STUD WALLS UNTIL ALL PLYWOOD SUB-FLOOR, FLOOR TRUSSES, ROOF TRUSSES, AND SHEAR PANELS ARE IN PLACE.	
4.06	TYPICAL SUB-FLOOR SHALL BE 3/4" TONGUE & GROOVE APA RATED STURDI-FLOOR PLYWD NAILED W/ 10d @ 6" OC AT SHEET EDGES AND @ 12" OC FIELD. S.A.D. FOR GYPCRETE TOPPING.	
4.07	TYPICAL ROOF SHEATHING SHALL BE MIN 5/8" THICK APA SPAN RATED CD-X PLYWD NAILED W/ 10d @ 6" OC AT SHEET EDGES AND @ 12" OC FIELD.	
4.08	SEE PLANS FOR WALL STUD AND SHEARWALL SCHEDULES.	
4.09	SEE PLANS FOR HEADER SCHEDULE.	
4.10	SEE PLANS FOR LOAD BEARING WOOD WALL SCHEDULE.	
4.11	ALL FASTENING NOT SHOWN SHALL CONFORM TO TABLE 2304.9.1 OF THE IBC.	

5.00 PRE-ENGINEERED WOOD TRUSS NOTES

5.01

TRUSSES TO BE PLACED ON 2'-0" MAXIMUM CENTERS UNLESS SHOWN OTHERWISE. REDUCED SPACING MAY BE USED AS REQUIRED BY TRUSS DESIGNER TO MEET STRENGTH & DEFLECTION CRITERIA. SEE PLANS FOR TRUSS LOCATIONS AND SPANS.

5.02

MINIMUM TRUSS DESIGN LOADS PER CODE AND AS FOLLOWS:

ROOF

45 PSF

TOP CHORD LIVE LOAD

15 PSF

TOP CHORD DEAD LOAD

10 PSF

BOTTOM CHORD DEAD LOAD

10 PSF

MINIMUM NET UPLIFT

20 PSF

GROUND SNOW LOAD

5.03

TRUSSES TO BE DESIGNED AND FABRICATED BY TRUSS MANUFACTURER'S STRUCTURAL ENGINEER REGISTERED IN THE PROJECT STATE.

5.04

CONFIGURATION AND SIZE OF WEB MEMBERS TO BE DETERMINED BY TRUSS MANUFACTURER.

5.05

SHOP DRAWINGS OF TRUSSES TO BE SUBMITTED FOR APPROVAL PRIOR TO FABRICATION.

5.06

TOP CHORD DEAD LOAD SHOWN ABOVE INCLUDES 3 PSF (6 PLF) FOR TRUSS SELF-WEIGHT.

5.07

UNIFORM LOADS INDICATED ABOVE TO BE USED FOR DESIGN OF HIP AND/OR GIRDER TRUSSES AS REQUIRED.

5.08

MAXIMUM ROOF LIVE LOAD DEFLECTION SHALL BE SPAN/360.

5.09

TRUSS BRIDGING SHALL BE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.

5.10

TRUSSES SHALL BE DESIGNED FOR APPLICABLE WIND LOADS IN ACCORDANCE WITH IBC CHAPTER 16 AND WIND DESIGN CRITERIA STATED ABOVE. APPLICABLE CODE PRESSURE FACTORS SHALL BE USED IN ARRIVING AT LOADS FOR THIS LOCATION.

5.11

THE FOLLOWING INFORMATION SHALL BE SHOWN ON THE TRUSS SHOP DRAWINGS. ALL TRUSS SHOP DRAWINGS, INCLUDING ERECTION STABILITY BRACING AND PERMANENT BRACING, SHALL BE AVAILABLE ON JOB SITE DURING THE TIMES OF INSPECTION AND SHALL BEAR CLEAR INDICATION THAT THEY HAVE BEEN REVIEWED AND APPROVED BY THE STRUCTURAL ENGINEER:

A) SPECIES OF THE LUMBER USED TO FABRICATE ALL TRUSS TYPES.

B) NOMINAL DIMENSIONS OF ALL TRUSS MEMBERS.

C) UNIFORM LIVE AND DEAD LOAD MAGNITUDE, INCLUDING ALL CONCENTRATED LOAD MAGNITUDES (FROM COLUMNS, BEARING PARTITIONS, ETC.) AND THEIR LOCATION.

D) MAGNITUDE OF FORCES IN ALL MEMBERS FOR EACH CRITICAL LOAD CASE.

E) BRIDGING AND BRACING DETAILS AND LOCATIONS.

F) INTERMEDIATE AND END BEARING DETAILS AND OTHER DETAILS OF STRUCTURAL CONNECTIONS NOT ADDRESSED ON STRUCTURAL OR ARCHITECTURAL PLANS.

G) ERECTION PLANS IDENTIFYING INDIVIDUAL TRUSSES SHOWN AND DETAILED ON SHOP DRAWINGS.

H) ALL HARDWARE (BOLTS, HANGERS, STRAPS, ETC.) REQUIRED FOR CONNECTIONS BETWEEN TRUSSES AND TRUSS ELEMENTS.

5.12

TRUSS MANUFACTURER TO PROVIDE END-WALL TRUSSES AT EACH SIDE OF VAULTED CEILINGS, AT GABLE ENDS, AT BUILDING STEP DOWNS, AND AT CHANGE OF ROOF LINES.

5.13

ROOF FRAMING IS NOT DESIGNED TO SUPPORT FUTURE MECHANICAL EQUIPMENT, CRANES, ETC.

5.14

TRUSS LAYOUT PLANS SHALL BE SUBMITTED ON 24x36 INCH OR LARGER SHEETS SHOWING COMPLETE FLOOR PLANS ON EACH SHEET, TO THE EXTENT POSSIBLE. SCALE FOR PLAN LAYOUTS SHALL NOT BE REDUCED TO LESS THAN 1/8 INCH = 1 FOOT. SUBMITTAL OF INDIVIDUAL UNIT PLANS IS NOT ACCEPTABLE.

6.00 STRUCTURAL STEEL

6.01

STRUCTURAL STEEL SHALL BE DETAILED, FABRICATED AND ERECTED ACCORDING TO AISC LOAD AND RESISTANCE FACTOR DESIGN (LRFD) SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS.

6.02

SUBMIT SHOP DRAWINGS PREPARED IN ACCORDANCE WITH AISC MANUAL, 'DETAILING FOR STEEL CONSTRUCTION'. DO NOT BEGIN FABRICATION UNTIL SHOP DRAWINGS ARE COMPLETED AND REVIEWED.

6.03

STRUCTURAL STEEL SHALL CONFORM TO ASTM A36, UNLESS NOTED OTHERWISE. ALL WIDE FLANGE SHAPES SHALL CONFORM TO ASTM A992 GRADE 50.

6.04

STRUCTURAL TUBING SHALL CONFORM TO ASTM A500, GRADE B, UNLESS NOTED OTHERWISE.

6.05

STEEL PIPE SHALL CONFORM TO ASTM A501 OR ASTM A53, TYPE E OR S, GRADE B.

6.06

BOLTS SHALL CONFORM TO ASTM A325, MINIMUM 3/4 INCH DIAMETER UNLESS NOTED OTHERWISE.

6.07

BOLTS AT WOOD CONNECTIONS ARE PERMITTED TO BE ASTM A307. ANCHOR RODS SHALL BE ASTM F1554, GRADE 36.

6.08

USE PREQUALIFIED WELDED JOINTS PER ANSI/A45 D1.1, 'STRUCTURAL WELDING CODE-STEEL.' USE ONLY CERTIFIED WELDERS, MINIMUM E70XX ELECTRODES UNLESS NOTED OTHERWISE.

6.09

DO NOT USE GAS CUTTING TORCHES FOR CORRECTING FABRICATION ERRORS IN THE STRUCTURAL FRAMING.

6.10

WHEN SPECIFICALLY NOT DETAILED ON THE DESIGN DRAWINGS PROVIDE THE FOLLOWING BEAM CONNECTIONS:

o WHERE BEAM REACTIONS ARE SHOWN, CONNECTIONS SHALL DEVELOP THE REACTION GIVEN.

o WHEN BEAM REACTIONS ARE NOT SHOWN, CONNECTIONS SHALL BE DESIGNED TO SUPPORT ONE-HALF THE TOTAL UNIFORM LOAD CAPACITY SHOWN IN THE ALLOWABLE UNIFORM LOAD TABLES OF THE AISC MANUAL, FOR THE GIVEN BEAM, SPAN, AND GRADE OF STEEL SPECIFIED.

o WHERE REACTIONS ARE SUBJECT TO ECCENTRICITY, SUCH ECCENTRICITY SHALL BE TAKEN INTO ACCOUNT.

6.11

PROVIDE TEMPORARY BRACING OF STRUCTURAL FRAMING UNTIL ALL PERMANENT BRACING, MOMENT CONNECTIONS, AND FLOOR AND ROOF DECKS (DIAPHRAGMS) ARE COMPLETELY INSTALLED, AND ALL TRUSS, TRUSS ASSEMBLY, AND COLUMN/BEAM CONNECTIONS ARE COMPLETED.

6.12

BOLTED CONNECTIONS SHALL BE ASSEMBLED AND INSPECTED ACCORDING TO 'SPECIFICATIONS FOR STRUCTURAL JOINTS USING ASTM A325 BOLTS.'

7.00 STEEL BRICK LINTELS

7.01

UNLESS NOTED OTHERWISE IN PLANS AND/OR SECTIONS ALL BRICK LINTELS SHALL BE LOOSE LINTELS (NOT ATTACHED TO STRUCTURE).

7.02

ALL LINTELS SHALL HAVE AT LEAST 6' BEARING LENGTH AT EACH END.

GENERAL NOTES

ALTHOUGH DRAWINGS ARE DRAWN TO SCALE, THE ACCURACY OF THE DRAWINGS CANNOT BE GUARANTEED. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND CONDITIONS BEFORE CONSTRUCTION. DIMENSIONS SHALL BE DELETED FROM DIMENSIONED PLANS.
ALL DIMENSIONS INCLUDE OPENING SIZES AND FINISHES. THE CONTRACTOR SHALL VERIFY THE FINISHES AND MATERIALS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DISCREPANCIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DISCREPANCIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DISCREPANCIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DISCREPANCIES.

MAUIST ARCHITECTURAL SERVICES

M

DIVISION OF L.E.M., INC.

112 NORTH MAIN STREET
GOSHEN, INDIANA 46526

* Architects
* Planners
* Engineers
* Construction Mgmt.
* Rule 5 and MS4 Filing

PHONE: (574) 537-8500
FAX: (574) 537-0808

These drawings are the property of Maui Architectural Services and may not be reprinted, copied, or used in any manner without the express written consent of Maui Architectural Services.

HOME 2

SUITES BY HILTON

SHEET SIZE 24x36

FT. WAYNE, INDIANA

REVISIONS :

PRELIMINARY - NOT FOR CONSTRUCTION

DATE: 05/01/26
JOB NO.: MAS-26-105
NAME: GENERAL NOTES
SHEET: 5001