

# CONTROLLER LOG

Occurrence Time	Event Full Description
12/5/2016 11:08:21 AM	Controller "AUM.4A-FF" Offline. 12/5/2016 12:04:38 PM Habeeb, George processed the alarm <no comment>
12/5/2016 11:13:40 AM	Controller "AUM.4A-FF" Online.
12/5/2016 11:16:10 AM	Controller "AUM.4A-FF" Offline. 12/5/2016 11:18:51 AM Bassil, Paul Operator viewed alarm properties from Alarm Viewer  12/5/2016 12:04:38 PM Habeeb, George processed the alarm <no comment>
12/5/2016 11:17:22 AM	AUM.4A-FF - Compile. May 29 2016 20:01:12 GGLBUILD
12/5/2016 11:17:22 AM	AUM.4A-FF - Version v7.50//b144. v7.50//b144 v3.10//b4 v1.01//b6033 Unavailable v2.30//b6 sc:255
12/5/2016 11:17:22 AM	Controller "AUM.4A-FF" restarted after power failed. sc:255
12/5/2016 11:17:29 AM	AUM.4A-FF - Command Centre comms established
12/5/2016 11:17:30 AM	Controller "AUM.4A-FF" Online.
12/5/2016 11:17:31 AM	AUM.4A-FF is no longer tampered, case closed (front tamper).
12/5/2016 11:17:31 AM	AUM.4A-FF is no longer tampered, mounted on wall (rear tamper).
12/5/2016 11:17:36 AM	AUM.4A-FF - Plug-in Module responding
12/5/2016 11:17:38 AM	AUM.4A-FF - Plug-in Module Version v3.00//b2. v3.00//b2
12/5/2016 11:24:37 AM	Controller "AUM.4A-FF" Offline. 12/5/2016 12:04:38 PM Habeeb, George processed the alarm <no comment>
12/5/2016 11:24:56 AM	AUM.4A-FF - Version v7.50//b144. v7.50//b144 v3.10//b4 v1.01//b6033 Unavailable v2.30//b6 sc:255
12/5/2016 11:24:59 AM	Controller "AUM.4A-FF" Online.
12/5/2016 11:26:39 AM	Controller "AUM.4A-FF" Offline. 12/5/2016 11:33:42 AM Habeeb, George Operator viewed alarm properties  12/5/2016 12:04:38 PM Habeeb, George processed the alarm <no comment>
12/5/2016 11:27:12 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:27:26 AM	Operator "Habeeb, George" started communication with "AUM.4A-FF"
12/5/2016 11:27:40 AM	Operator "Habeeb, George" Synchronised Databases on "AUM.4A-FF"
12/5/2016 11:27:47 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:28:29 AM	Operator "Habeeb, George" Modified Controller 6000 "AUM.4A-FF"

# CONTROLLER LOG

Occurrence Time	Event Full Description
12/5/2016 11:29:32 AM	Operator "Habeeb, George" started communication with "AUM.4A-FF"
12/5/2016 11:30:11 AM	Operator "Habeeb, George" Modified Controller 6000 "AUM.4A-FF" Changed: "Disable Front Tamper" from "Yes" to "No" Changed: "Disable Rear Tamper" from "Yes" to "No"
12/5/2016 11:30:18 AM	Operator "Habeeb, George" Modified Controller 6000 "AUM.4A-FF" Changed: "Disable Front Tamper" from "No" to "Yes" Changed: "Disable Rear Tamper" from "No" to "Yes"
12/5/2016 11:30:28 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:31:46 AM	Operator "Habeeb, George" Synchronised Databases on "AUM.4A-FF"
12/5/2016 11:36:14 AM	Controller "AUM.4A-FF" Online.
12/5/2016 11:36:14 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:36:55 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:37:06 AM	AUM.4A-FF - Compile. May 29 2016 20:01:12 GGLBUILD
12/5/2016 11:37:06 AM	AUM.4A-FF - Version v7.50//b144. v7.50//b144 v3.10//b4 v1.01//b6033 Unavailable v2.30//b6 sc:255
12/5/2016 11:37:06 AM	Controller "AUM.4A-FF" restarted after power failed. sc:255
12/5/2016 11:37:12 AM	AUM.4A-FF - Command Centre comms established
12/5/2016 11:37:15 AM	AUM.4A-FF is no longer tampered, case closed (front tamper).
12/5/2016 11:37:15 AM	AUM.4A-FF is no longer tampered, mounted on wall (rear tamper).
12/5/2016 11:37:24 AM	AUM.4A-FF - Plug-in Module Version v3.00//b2. v3.00//b2
12/5/2016 11:37:25 AM	AUM.4A-FF - Plug-in Module responding
12/5/2016 11:39:14 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:39:26 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:39:39 AM	Controller "AUM.4A-FF" Offline. 12/5/2016 12:04:38 PM Habeeb, George processed the alarm <no comment>
12/5/2016 11:39:39 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:40:05 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:40:16 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:40:50 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:41:24 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:41:44 AM	Operator "Habeeb, George" started communication with "AUM.4A-FF"
12/5/2016 11:41:52 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:48:08 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:48:26 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:48:32 AM	Operator "Habeeb, George" Synchronised Databases on "AUM.4A-FF"
12/5/2016 11:48:49 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"

CONTROLLER LOG

Occurrence Time	Event Full Description
12/5/2016 11:48:55 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:48:58 AM	Controller "AUM.4A-FF" has not connected to the server yet. 12/5/2016 12:04:38 PM Habeeb, George processed the alarm <no comment>
12/5/2016 11:49:11 AM	Operator "Habeeb, George" started communication with "AUM.4A-FF"
12/5/2016 11:49:30 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:50:19 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:50:39 AM	Operator "Habeeb, George" Modified Controller 6000 "AUM.4A-FF" Changed: "Disable Front Tamper" from "Yes" to "No" Changed: "Disable Rear Tamper" from "Yes" to "No"
12/5/2016 11:50:45 AM	Operator "Habeeb, George" Modified Controller 6000 "AUM.4A-FF" Changed: "Disable Front Tamper" from "No" to "Yes" Changed: "Disable Rear Tamper" from "No" to "Yes"
12/5/2016 11:50:48 AM	Operator "Habeeb, George" started communication with "AUM.4A-FF"
12/5/2016 11:50:53 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:50:58 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:53:16 AM	Operator "Bassil, Paul" Synchronised Databases on "AUM.4A-FF"
12/5/2016 11:53:23 AM	Operator "Habeeb, George" started communication with "AUM.4A-FF"
12/5/2016 11:53:34 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:53:37 AM	Operator "Habeeb, George" Synchronised Databases on "AUM.4A-FF"
12/5/2016 11:54:12 AM	Operator "Habeeb, George" started communication with "AUM.4A-FF"
12/5/2016 11:54:20 AM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 11:57:41 AM	AUM.4A-FF - Compile. May 29 2016 20:01:12 GGLBUILD
12/5/2016 11:57:41 AM	AUM.4A-FF - Version v7.50//b144. v7.50//b144 v3.10//b4 v1.01//b6033 Unavailable v2.30//b6 sc:255
12/5/2016 11:57:41 AM	Controller "AUM.4A-FF" restarted after power failed. sc:255
12/5/2016 11:57:43 AM	AUM.4A-FF - Command Centre comms established
12/5/2016 11:57:44 AM	Controller "AUM.4A-FF" Online.
12/5/2016 11:57:50 AM	AUM.4A-FF database \YAFFS\FT\Diary.CDB - new \YAFFS\FT\Diary.CDB
12/5/2016 11:57:50 AM	AUM.4A-FF is no longer tampered, case closed (front tamper).
12/5/2016 11:57:50 AM	AUM.4A-FF is no longer tampered, mounted on wall (rear tamper).
12/5/2016 11:57:51 AM	AUM.4A-FF database \YAFFS\FT\Card.CDB - new \YAFFS\FT\Card.CDB
12/5/2016 11:57:51 AM	AUM.4A-FF database \YAFFS\FT\Club.CDB - new \YAFFS\FT\Club.CDB
12/5/2016 11:57:59 AM	AUM.4A-FF - Plug-in Module responding
12/5/2016 11:58:01 AM	AUM.4A-FF - Plug-in Module Version v3.00//b2. v3.00//b2

CONTROLLER LOG

Occurrence Time	Event Full Description
12/5/2016 11:58:12 AM	AUM.4A-FF database \YAFFS\FT\CardName.CDB - new \YAFFS\FT\CardName.CDB
12/5/2016 12:04:38 PM	Operator "Habeeb, George" Processed Alarm 12/5/2016 11:08:21 AM Controller "AUM.4A-FF" Offline. <no comment>
12/5/2016 12:04:38 PM	Operator "Habeeb, George" Processed Alarm 12/5/2016 11:16:10 AM Controller "AUM.4A-FF" Offline. <no comment>
12/5/2016 12:04:38 PM	Operator "Habeeb, George" Processed Alarm 12/5/2016 11:24:37 AM Controller "AUM.4A-FF" Offline. <no comment>
12/5/2016 12:04:38 PM	Operator "Habeeb, George" Processed Alarm 12/5/2016 11:26:39 AM Controller "AUM.4A-FF" Offline. <no comment>
12/5/2016 12:04:38 PM	Operator "Habeeb, George" Processed Alarm 12/5/2016 11:39:39 AM Controller "AUM.4A-FF" Offline. <no comment>
12/5/2016 12:04:38 PM	Operator "Habeeb, George" Processed Alarm 12/5/2016 11:48:58 AM Controller "AUM.4A-FF" has not connected to the server yet. <no comment>
12/5/2016 12:09:50 PM	Controller "AUM.4A-FF" Offline. 12/6/2016 9:05:23 AM Habeeb, George processed the alarm <no comment>
12/5/2016 12:12:23 PM	Operator "Habeeb, George" pushed configuration of "AUM.4A-FF"
12/5/2016 12:17:39 PM	AUM.4A-FF - Compile. May 29 2016 20:01:12 GGLBUILD
12/5/2016 12:17:39 PM	AUM.4A-FF - Version v7.50//b144. v7.50//b144 v3.10//b4 v1.01//b6033 Unavailable v2.30//b6 sc:255
12/5/2016 12:17:39 PM	Controller "AUM.4A-FF" restarted after power failed. sc:255
12/5/2016 12:17:43 PM	AUM.4A-FF - Command Centre comms established
12/5/2016 12:17:44 PM	Controller "AUM.4A-FF" Online.
12/5/2016 12:17:48 PM	AUM.4A-FF is no longer tampered, case closed (front tamper).
12/5/2016 12:17:48 PM	AUM.4A-FF is no longer tampered, mounted on wall (rear tamper).
12/5/2016 12:17:57 PM	AUM.4A-FF - Plug-in Module Version v3.00//b2. v3.00//b2
12/5/2016 12:17:58 PM	AUM.4A-FF - Plug-in Module responding
12/5/2016 12:24:36 PM	Controller "AUM.4A-FF" Offline. 12/6/2016 9:05:23 AM Habeeb, George processed the alarm <no comment>
12/5/2016 12:33:10 PM	AUM.4A-FF - Compile. May 29 2016 20:01:12 GGLBUILD

CONTROLLER LOG

Occurrence Time	Event Full Description
12/5/2016 12:33:10 PM	AUM.4A-FF - Version v7.50//b144. v7.50//b144 v3.10//b4 v1.01//b6033 Unavailable v2.30//b6 sc:255
12/5/2016 12:33:10 PM	Controller "AUM.4A-FF" restarted after power failed. sc:255
12/5/2016 12:33:12 PM	AUM.4A-FF - Command Centre comms established
12/5/2016 12:33:13 PM	Controller "AUM.4A-FF" Online.
12/5/2016 12:33:19 PM	AUM.4A-FF is no longer tampered, case closed (front tamper).
12/5/2016 12:33:19 PM	AUM.4A-FF is no longer tampered, mounted on wall (rear tamper).
12/5/2016 12:33:25 PM	AUM.4A-FF - Plug-in Module Version v3.00//b2. v3.00//b2
12/5/2016 12:33:26 PM	AUM.4A-FF - Plug-in Module responding
12/5/2016 12:35:36 PM	AUM.4A-FF - power low. 12/6/2016 9:05:23 AM Habeeb, George processed the alarm <no comment>
12/5/2016 12:36:43 PM	Controller "AUM.4A-FF" Offline. 12/6/2016 9:05:23 AM Habeeb, George processed the alarm <no comment>
12/5/2016 12:37:57 PM	AUM.4A-FF - Compile. May 29 2016 20:01:12 GGLBUILD
12/5/2016 12:37:57 PM	AUM.4A-FF - Version v7.50//b144. v7.50//b144 v3.10//b4 v1.01//b6033 Unavailable v2.30//b6 sc:2
12/5/2016 12:37:57 PM	Controller "AUM.4A-FF" restarted after power failed. sc:2
12/5/2016 12:38:03 PM	AUM.4A-FF - Command Centre comms established
12/5/2016 12:38:04 PM	Controller "AUM.4A-FF" Online.
12/5/2016 12:38:06 PM	AUM.4A-FF is no longer tampered, case closed (front tamper).
12/5/2016 12:38:06 PM	AUM.4A-FF is no longer tampered, mounted on wall (rear tamper).
12/5/2016 12:38:08 PM	AUM.4A-FF - Plug-in Module Version v3.00//b2. v3.00//b2
12/5/2016 12:38:09 PM	AUM.4A-FF - Plug-in Module responding
12/5/2016 12:38:27 PM	AUM.4A-FF Network - transaction timeout. 192.168.14.100 12/5/2016 2:02:08 PM Habeeb, George Operator viewed alarm properties from Alarm Viewer  12/6/2016 9:05:23 AM Habeeb, George processed the alarm <no comment>
12/5/2016 12:39:00 PM	AUM.4A-FF - Command Centre comms interrupted 12/6/2016 9:05:23 AM Habeeb, George processed the alarm <no comment>

## CONTROLLER LOG

---

Occurrence Time	Event Full Description
12/5/2016 12:39:30 PM	AUM.4A-FF - Command Centre comms established