

Project: ETAP
Location: 19.0.1C
Contract:
Engineer:
Filename: gauss
Study Case: LF

Page: 1
Date: 26-05-2026
SN:
Revision: Base
Config.: Normal

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap	
* Bus1	11.000	100.000	0.0	275.021	147.688	75.000	22.500	Bus3	135.785	93.337	8648.2	82.4		
								Bus2	64.236	31.851	3763.2	89.6		
Bus2	11.000	99.949	0.0	0.000	0.000	0.000	0.000	Bus3	64.215	31.810	3763.2	89.6		
								Bus1	-64.215	-31.810	3763.2	89.6		
Bus3	11.000	99.917	0.0	0.000	0.000	199.934	124.958	Bus1	-135.731	-93.174	8648.2	82.4		
								Bus2	-64.203	-31.784	3763.2	89.6		

* Indicates a voltage regulated bus (voltage controlled or swing type machine connected to it)
Indicates a bus with a load mismatch of more than 0.1 MVA