National Environment Agency
Safeguard · Nurture · Cherish

40 Scotts Road #13-00
Environment Building
Singapore 228231
www.nea.gov.sg

Ref: NEA-CMD-CIRCULAR-ECA-00004-2025

Date: 10-Jun-2025

Chief Executives, Corporation Representatives and Energy Managers of Registered Corporations (RCs) under the Energy Conservation Act

Dear Sir/Mdm

Reminder on Compliance with Minimum Energy Efficiency Standards (MEES) for Water-Cooled Chilled Water Systems (WCCWS)

1 RCs of existing industry facilities are once again reminded that MEES requirements for WCCWS will come into **effect from 1 Dec 2025 onwards**.

2 Below is a summary of the regulatory requirements to be met.

Scope	Regulatory Requirements
Registration	• Industrial facilities with WCCWS installed in their facility must register in the EDMA system
Measurement and Verification (M&V)	• Install the required permanent measurement instruments to support the verification of conformance with the stipulated MEES level corresponding to the chilled water supply temperature of the WCCWS. For technical details, refer to: M&V requirement and guidelines
Reporting	• Submit MEES First Report in EDMA system by the stipulated timeline. More details on the timeline will be shared later. • The MEES First Report must be prepared and signed off by an Energy Efficiency Opportunities (EEO) Assessor with systems-specific experience in chilled water systems or a Professional Engineer in the branch of mechanical engineering, electrical engineering or chemical engineering. • Submit a MEES report annually to demonstrate continued conformance with MEES level.

3. Non-compliance by RCs will be subject to penalties as summarised below.

Non-compliance	Penalties
Registration Failure to register with NEA as a registerable person within the prescribed period	• A fine **not exceeding $5,000**
Measurement and Verification (M&V) Failure to assess and monitor the energy efficiency of the WCCWS based on the prescribed manner, measurement equipment and assessment or reporting period	• A fine not exceeding **$20,000** and, in the case of a continuing offence, to a further fine not exceeding **$500 for every day or part of a day** during which the offence continues after conviction
Reporting Failure to submit a report to NEA on the monitoring and assessment of the WCCWS system for the prescribed period.	• A fine not exceeding **$10,000** on the first conviction of that offence • A fine not exceeding **$20,000** and, in the case of a continuing offence, to a further fine **not exceeding $1,000 for every day or part of a da**y during which the offence continues after that second or subsequent conviction

4 Should you require any clarifications, please contact us at nea_eepc@nea.gov.sg or your NEA account officers without delay.

Yours faithfully
(Transmitted via email)

Suresh K.
Director
Carbon Mitigation Division
National Environment Agency

NB: This is a computer-generated letter; no signature is required.