



University of Southern California
Department of Public Safety
Daily Incident Log
From 1/4/2016 To 1/6/2016



Reported: 1/5/16 - 2:10 am	Location: UNIVERSITY RELIGIOUS CENTER	Report #: 1600015
Occurred: 1/5/16 - 2:10 am to 1/5/16 - 2:47 am	Disposition: CLOSED	
Incident: SERVICE	Illness Response	
Summary: A non-USC female suffering from diabetes related issues was transported to a local hospital for medical treatment.		
Reported: 1/5/16 - 11:30 am	Location: OUTSIDE USC AREA	Report #: 1600016
Occurred: 12/30/15 - 6:00 pm to 12/30/15 - 10:00 pm	Disposition: CLOSED	
Incident: PROPERTY	Lost/Missing Property	
Summary: A staff member reported her laptop computer missing.		
Reported: 1/5/16 - 1:00 pm	Location: 2827 MENLO AV	Report #: 1600017
Occurred: 1/5/16 - 1:00 pm to 1/5/16 - 1:37 pm	Disposition: CLOSED	
Incident: PROPERTY	Damaged Property	
Summary: A student reported that a bathroom window and drywall were damaged by unknown means.		
Reported: 1/5/16 - 12:37 pm	Location: SOCIAL SCIENCES BUILDING	Report #: 1600018
Occurred: 1/5/16 - 12:37 pm to 1/5/16 - 2:16 pm	Disposition: CLOSED	
Incident: EH&S	Water Leak	
Summary: Water from a ruptured release valve leaked into two rooms at the location. FMS personnel were requested to clean up and conduct repairs.		
cc: Safety		
Reported: 1/5/16 - 1:02 pm	Location: ANNENBERG SCHOOL FOR COMMUNICATION	Report #: 1600019
Occurred: 1/5/16 - 1:02 pm to 1/5/16 - 3:33 pm	Disposition: CLOSED	
Incident: FIRE	Alarm Accidental	
Summary: A fire alarm was activated by rain water leaking into a smoke detector.		
cc: Safety		
Reported: 1/5/16 - 3:32 pm	Location: MONTGOMERY ROSS FISHER BUILDING SCHOOL OF SOCIAL W	Report #: 1600020
Occurred: 1/5/16 - 3:32 pm to 1/5/16 - 4:24 pm	Disposition: Open	
Incident: SERVICE	Suspicious Circumstances	
Summary: A staff member reported receiving a disturbing voice mail message.		
cc: HR		
Reported: 1/5/16 - 7:32 pm	Location: H. LESLIE HOFFMAN HALL OF BUSINESS ADMINISTRATION	Report #: 1600021
Occurred: 1/5/16 - 7:32 pm to 1/5/16 - 8:11 pm	Disposition: CLOSED	
Incident: EH&S	Water Leak	
Summary: A staff member reported that an exterior classroom wall was damaged by leaking rain water.		
cc: Safety		



**University of Southern California
Department of Public Safety
Daily Incident Log
From 1/4/2016 To 1/6/2016**



Reported: 1/5/16 - 8:54 pm

Location: KAPRIELIAN HALL

Report #: 1600022

Occurred: 1/5/16 - 8:54 pm to 1/5/16 - 9:37 pm

Disposition: CLOSED

Incident: EH&S Water Leak

Summary: A staff member reported that a floor was damaged by leaking rain water.

cc: Safety
