15.7 Quality of drinking water:

Now a days most of us hesitate to use natural water directly for drinking, because biological, physical or chemical impurities from different sources mix with surface water or ground water.

Institutions like WHO (World Health Organisation) at world level and BIS (Bureau of Indian Standards) and ICMR (ICMR: Indian Council of Medical Research) at national level have prescribed standards for quality of drinking water. Standard characteristics prescribed for deciding the quality of drinking water by BIS, in 1991 are shown in Table.15.3

Table 15.3 Standard characteristics of drinking water

S.No	Characteristics	Desirable limit
I	**Physico-chemical Characteristics**	
i)	pH	6.5 to 8.5
ii)	Total Dissolved Solids (TDS)	500 ppm
iii)	Total Hardness (as $CaCO_3$)	300 ppm
iv)	Nitrate	45 ppm
v)	Chloride	250 ppm
vi)	Sulphate	200 ppm
vii)	Fluoride	1 ppm
II	**Biological Characteristics**	
i)	Escherichia Coli (E.Coli)	Not at all
ii)	Coliforms	Not to exceed 10 (In 100 ml water sample)

Fluoride:

Fluoride ion deficiency in drinking water causes tooth decay. Water soluble fluorides are added to increase the fluoride ion concentration upto 1 ppm.

The Fluoride ions make the enamel on teeth much harder by converting hydroxyapatite, $[3(Ca_3(PO_4)_2.Ca(OH)_2]$, the enamel on the surface of the teeth, into much harder fluorapatite, $[3(Ca_3(PO_4)_2.CaF_2]$.

However, Fluoride ion concentration above 2 ppm causes brown mottling of teeth. Excess fluoride causes damage to bone and teeth.

Lead :

Drinking water containing lead contamination above 50ppb can cause damage to

Unit 15.indd 272 23-12-2021 17:27:47