Baltic WWTP Glossary

Key Terms	Definitions
Aerobic	uses oxygen to break down organic contaminants and other pollutants like nitrogen (N) and phosphorous (P).
Anaerobic	breaks down organic contaminants and pollutants without oxygen.
Activated Sludge	a large group of microorganisms used to break down organic matter in an aeration basin (with oxygen).
BOD7 (Biological Oxygen Demand)	a measure of the amount of oxygen needed for microorganisms to break down the organic matter within seven days.
Flocculation	slow-mixing which allows for larger particles (floc-formation) to stick together, become heavier, and settle out by gravity.
F/M	a ratio used to show the amount of food entering the system versus the number of microorganisms in the system.
Lime $Ca(OH)_2$	Used in wastewater to raise the pH to help settle out metal salts into solids to be removed.
Metal Salts	used as a coagulant or chemical substance to help balance (neutralize) the positive and negative ions in the system.
MLSS (Mixed Liquor Suspended Solids)	the amount of active biomass available to consume the organics.
Organic Matter	matter that has come from living organisms.
Precipitants	the change from dissolved material into solid particles
SVI (Sludge Volume Index)	settleability of sludge.