



Certificate of Product Approval

Licensee:

Giza Power Industry

Abo Rawash kilo 28 -alex road 690 industrial area Al Omraneyah, Giza Governorate, Giza -Cairo, Egypt

Factory:

Abo Rawash kilo 28 -alex road 690 industrial area Al Omraneyah, Giza Governorate, Giza -Cairo, Egypt

Standard:

BS 6622:2007 Incorporating Corrigenda Nos. 1 and 2

Description:

Medium voltage power cables up to 36 kV with PVC sheathing

Details:

Circular stranded plain copper or aluminium conductors, extruded cross-linkable semi-conducting conductor screen, extruded cross-linkable polyethylene (XLPE/GP 8) insulation, extruded cross-linkable semi-conducting bonded or strippable insulation screen, copper tape and/or copper wire screened, extruded polyvinyl chloride (PVC) separation sheath, aluminium wire armour for single core cables and galvanized steel wire armour for multi-core cables, extruded polyvinyl chloride (PVC/Type 9) oversheath.

The cables' design, materials, and testing conform to BS 6622 up to 19/33 (36) kV

Materials:

Insulation XLPE/GP 8, Sheath PVC/Type 9

Brand Name

N/A

Origin Mark:

GIZA POWER INDUSTRY

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Date: 08/07/2024

Date of original issue: 08/07/2024

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK

Registered in England No. 13950143, Tel: +44 (0)1908 267300

Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
23/01/2027