

KEMA REPORT OF PERFORMANCE

1492-21

Object	Power cable with extruded insulation for fixed installations
Type	Cu/MICA/XLPE/SWA/LSHF 4 x 16 mm ² 0,6/1 (1,2) kV – Cu – XLPE
Client	Giza Power Industry (GPI), Kilo 28 Abo Rawash industrial Area, Giza, Egypt
Manufacturer	Giza Power Industry (GPI), Kilo 28 Abo Rawash industrial Area, Giza, Egypt *)
Tested by	KEMA B.V., Klingelbeekseweg 195, Arnhem, the Netherlands
Date of tests	1 September to 9 November 2021
Test specification	The tests have been carried out in accordance with BS 6387:2013 Category CWZ (modified by BS 7846:2015 Annex I for cables exceeding 20 mm diameter).
Summary and conclusion	The object has complied with the relevant requirements of the standard.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

*) as declared by the manufacturer

This report consists of 13 pages in total.

KEMA B.V.



Bas Verhoeven
Director, High-Voltage
Laboratory

Arnhem, 11 November 2021