防 爆 合 格 证

证　号：GYB23.3035X

制　造　商　上海星申仪表有限公司

（地址：上海市浦东新区宣中路 8 号）

产 品 名 称　磁性液位计（带变送器）

型 号 规 格　UHZ-517aRDb c d-e-f-g

防 爆 标 志　Ex db ⅡC T1…T6 Gb

产 品 标 准　Q31/0115000245C016-2023

图 样 编 号　B54.0、C10.0（LB）、T32.0（LB）

经图样及技术文件的审查和样品检验，确认上述产品符合下列标准：
GB/T 3836.1-2021,GB/T 3836.2-2021

特颁发此证。

本证书有效期：2023 年 11 月 14 日 至 2028 年 11 月 13 日

备注

1. 安全使用注意事项见使用说明书。
2. 证书编号后缀“X”表明产品具有安全使用特殊条件：涉及隔爆接合面的维修须联系产品制造商；使用环境温度范围为-40℃～+70℃。
3. 型号规格说明：a 表示结构形式，可为 B，C，T；b 表示面板指示器类型，可为 A，B；c 表示接液材质，可为 1~7；d 表示保温方式，可为 J1，J2，J4，J5，J6；e 表示测量范围；f 表示介质密度；g 表示公称压力（MPa）。
4. 安全电气参数：24VDC。
5. 产品外壳防护等级 IP66。

批　准

上海仪器仪表自控系统检验测试所有限公司
国家级仪器仪表防爆安全监督检验站

颁发日期 二〇二三 年 十一 月 十四 日

本证书仅对与认可文件和样品一致的产品有效。

地址：上海市漕宝路103号
邮编：200233
网址：www.nepsi.org.cn
Email:info@nepsi.org.cn
电话：+86 21 64368180
传真：+86 21 64844580

EXPLOSION PROTECTION
CERTIFICATE OF CONFORMITY

Cert No. GYB23.3035X

Manufacturer	**Shanghai Xingshen Instrument Co., Ltd** **(Address: No.8 Xuanzhong Road, PuDong District, Shanghai)**
Product	**Magnetic Liquid Level Gauge(with transmitter)**
Model	**UHZ-517aRDb c d-e-f-g**
Ex marking	**Ex db IIC T1…T6 Gb**
Product standard	**Q31/0115000245C016-2023**
Drawing number	**B54.0、C10.0（LB）、T32.0（LB）**

The product was found to comply with the following standard(s):

GB/T 3836.1-2021,GB/T 3836.2-2021

Valid until: 2028.11.13

Remarks

1.Conditions for safe use are specified in the instructions.
2.Symbol "X" placed after the certification number denotes specific conditions of use:Contact the original manufacturer when repair work relates to the flamepath;The ambient temperature range for use is -40°C to+70°C.
3.Model designation: a indicates the structural type, which can be B, C, T; b indicates the type of panel indicator, which can be A or B; c indicates the liquid receiving material, which can be 1~7; d indicates the insulation method, which can be J1, J2, J4, J5, J6; e indicates measuring range; f indicates medium density; g indicates nominal pressure (MPa).
4.Safe parameters:24VDC.
5.Degree of protection:IP66.

Approval

Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.
National Supervision and Inspection Center for Explosion Protection and Safety of Instrumentation
Date of issue 2023.11.14

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

http://www.nepsi.org.cn
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580