


Cairo University جامعة القاهرة



FIRE ALARM SYSTEM SERIES LEGEND

SYMBOL	DESCRIPTION
FIRE ALARM SYSTEM	
[FRP]	ADDRESSABLE FIRE ALARM Repeter PANEL.
[FACP]	ADDRESSABLE FIRE ALARM CONTROL PANEL.
[S]	ADDRESSABLE INTELLIGENT OPTICAL SMOKE DETECTOR.
[SA]	ADDRESSABLE INTELLIGENT OPTICAL SMOKE DETECTOR ABOVE FALSE CEILING. COMPLETE WITH LED INDICATOR.
[AM]	ADDRESSABLE INTELLIGENT CONTROL MODULE.
[AM]	ADDRESSABLE INTELLIGENT MONITOR MODULE.
[C]	ADDRESSABLE INTELLIGENT MULTI-SENSOR (SMOKE+HEAT) DETECTOR.
[H]	ADDRESSABLE INTELLIGENT HEAT DETECTOR.
[S]	ADDRESSABLE INTELLIGENT DUCT SMOKE DETECTOR.
[SL]	STROBE LIGHT WITH CANDELA RATING AS INDICATED IN DRAWING.
[SLP]	STROBE LIGHT (WEATHER PROOF TYPE)
[ST]	BEAM DETECTOR (TRANSMITTER).
[SR]	BEAM DETECTOR (RECEIVER).
[M]	ADDRESSABLE INTELLIGENT MANUAL FIRE ALARM PULL STATION, DOUBLE ACTION.
[F]	FIRE FIGHTER TELEPHONE JACK.
[S]	FIRE ALARM SIREN, dB LEVEL SHALL BE AT LEAST 15 dB ABOVE THE AMBIENT SOUND LEVEL.
[DH]	DOOR HOLDER.

MAIN CONSULT 1997



المجمع الطبي لاطفال
المطلة الشهيرة لجامعة القاهرة

DESIGNED BY	ENGINEER	PROJECT NO.	CA171200
DRAWN BY	ENGINEER	DATE	1997
CHECKED BY	ENGINEER	DATE	1997
APPROVED BY	ENGINEER	DATE	1997
REVISION	DATE	DESCRIPTION	