

OA-2026-0908 — Oil Analysis Report — U-105

Sampled 2026-09-08 | Issued 2026-09-11 | ForInformation | 50-UZ-105

Water	850 ppm (> 500 action)
ISO 4406	19/17/14 (target 17/15/12)
Verdict	Action — water ingress suspected, check cooler