

PAL-TR-CM-001 Rev 4 — Vibration Monitoring of Rotating Equipment

Company procedure | Current | 2024-09-01 | Applies to 50-PA-101A; 50-PA-101B

Alarm and trip precedence

For machines > **300 kW** on **rigid** support:

- Vibration **alarm** = min(4.0 mm/s RMS, OEM alarm)
- Vibration **trip** = per OEM manual (current revision, applicable arrangement)
- The more conservative alarm applies.

Refer lube oil condition questions to the LO unit manual (KLS-KLU60-OM), not the pump IOM.