Test Report



Novasys Greenergy Private Limited

REPORT NUMBER: 4790378634.5.1-S1

PROJECT NUMBER: 4790378634.5.1

Select the applicable test locations:

⊠LOCATION 1:

UL India Private Limited, Laboratory building, Kalyani Platina Campus, Sy.no.129/4, EPIP Zone, Phase II, Whitefield, Bangalore – 560 066 P:91-80-41384400

\square LOCATION 2:

UL India Private Limited,
Oak building, Kalyani Platina
Campus, Sy.No.129/4,
EPIP Zone, Phase II, Whitefield,
Bangalore, Karnataka – 560 066

\square LOCATION 3:

UL India Private Limited, 30/A, I Stage, Vishveshwarya Industrial Estate, Doddanekkundi Industrial Area, Bangalore - 560048

\square Other:

(#Refer Page no. for Test lab location)



TEST DISCIPLINE: ELECTRONICS PRODUCT GROUP: SOLAR PANEL

General details

Customer / Applicant	Novasys Greenergy Private Limited KHASRA NO. 185, MOUZA-MAHALGAON, TAHSIL-KAMPTEE, NAGPUR MAHARASHTRA 441202 INDIA				
Manufacturer	Novasys Greenergy Private Limite KHASRA NO. 185, MOUZA-MAHA 441202 INDIA		EE, NAGPUR MAHARASHTRA		
Program	Other				
Item Under Test	Mono crystalline PV modules (PEF	RC)			
Model	NOVA550MP144 (tested Model)				
Number of Samples	03 Nos.				
UL Sample Identification	Refer sample identification table Refer Summary of Test results for multiple samples				
Manufacturer Serial Number (if any)	NOVABTMPVD00082, NOVABTMPVD00083, NOVABTMPVD00084				
Condition of IUT on receipt	Good				
Date of Receipt	29 April 2022				
Applicable Standard	PID (Potential Induced Degradation) Testing of Solar Photovoltaic modules as per IEC TS 62804 – Test Methods for The Detection of Potential-Induced Degradation Part 1: Crystalline Silicon Photovoltaic Modules. Edition 1.0, 2015-08 [Negative Grounding] (Severity level as per MNRE requirement: 3 Cycles at 85°C ± 2°C, 85 ± 3% of RH for 96Hrs – Total 288Hrs).				
Date of Testing (Start date)	13 June 2022 End Date 5 July 2022				
UL general^ ambient	Temperature in °C 23 ±5°C				
condition	Relative humidity in % <70 %				
Date of Issue	28 July 2022				
Test In-charge	Mohan A				

[#] Fill in the rows with information or add hyphen (-)

Supratik Ghosh	Srimathy N
Engineer Project Associate	Project Engineer
Reviewed by	Authorized signatory

Disclaimer

Disclaimer

The issuance of this report in no way implies Listing, Classification or Recognition by Under the company to reproduce this Report provided it is reproduced in its entirety. UL's name or marks cannot be used in any packaging, advertising, promotion or marketing relating to the data in this Report, without UL's prior written permission. The results of testing in this report apply only to the sample product/fitem, which was tested. UL Lab has not participated in the sample selection for Electrical, Electronics, Mechanical, Radiology and Chemical disciplines, with exception to Chemical lab, Gurugram. Other similar equipment will not necessarily produce the same results due to production tolerance and measurement uncertainties. The applicable standard ambient condition supersedes the lab general ambient conditions and are recorded in datasheets available in the lab, Decision rule for statement(s) of conformity is based on IEC Guide 115 Clause 4.4.3 Procedure 2 "Accuracy Method".

UL India Private Limited Registered Office: Kalyani Platina - Block I, 3rd Floor No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com CIN: U74200KA1997PTC023189



General Remarks (If any)

- 1) The below got test results in this report will relate only to the items tested.
- 2) This report shall not be reproduced except in full, without the written approval of the testing laboratory.

Below listed models covered in this test report, on basis of having same construction, design and BOM as declared by manufacturer. No testing was considered necessary to cover below listed models. Only changes are the electrical ratings, number of cells and overall dimension from the tested model.

Models covered Models covered	ep ep ep of 5
--	------------------------

Description of Item under Test (IUT)

Mono crystalline PV modules (PERC) of 540Wp was tested for PID (Model- NOVA550MP144). Total 3 samples were tested, 1 sample was used as control sample.

Sample	Sample Identification for PID Test						
SI. No.	Sample card Number	Sample Serial Number	Test	Product Identification & Serial Number			
1	4915522 (control)	NOVABTMPVD00082		Solar PV Module 550W, Model No- NOVA550MP144, SI No NOVABTMPVD00082			
2	4915527	NOVABTMPVD00083	PID (Negative Grounding)	Solar PV Module 550W, Model No- NOVA550MP144, SI No NOVABTMPVD00083			
3	4915528	NOVABTMPVD00084		Solar PV Module 550W, Model No- NOVA550MP144, SI No NOVABTMPVD00084			

Summary of Test Results

Test No.	Test Name	Results
1	Preconditioning (Pre- PID Test)	REFER INDIVIDUAL TEST TABLE
2	Visual Inspection Test (Pre-PID Test)	REFER INDIVIDUAL TEST TABLE
3	Maximum Power Determination (Pre-PID Test)	REFER INDIVIDUAL TEST TABLE
4	Performance at low irradiance (Pre-PID Test)	REFER INDIVIDUAL TEST TABLE
5	Wet Leakage Current Test (Pre-PID Test)	REFER INDIVIDUAL TEST TABLE
6	Electroluminescence at Isc and 0.1*Isc (Pre-PID Test)	REFER INDIVIDUAL TEST TABLE

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



7	Ground continuity test (Pre-PID Test)	REFER INDIVIDUAL TEST TABLE
8	Insulation test (Pre-PID Test)	REFER INDIVIDUAL TEST TABLE
8	PID Test: 3 Cycles at 85°C ± 2°C, 85 ± 3% of RH for 96Hrs – Total 288Hrs	Test Condition: 3 Cycles at 85°C ± 2°C, 85 ± 3% of RH for 96Hrs – FIRST CYCLE
9	Maximum Power Determination (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
10	Performance at low irradiance (Post-PID Test) - Final	REFER INDIVIDUAL TEST TABLE
11	Wet Leakage Current Test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
12	Electroluminescence at Isc (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
13	Visual Inspection Test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
14	Insulation test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
15	PID Test: 3 Cycles at 85°C ± 2°C, 85 ± 3% of RH for 96Hrs – Total 288Hrs	Test Condition: 3 Cycles at 85°C ± 2°C, 85 ± 3% of RH for 96Hrs – SECOND CYCLE
16	Maximum Power Determination (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
17	Performance at low irradiance (Post-PID Test) - Final	REFER INDIVIDUAL TEST TABLE
18	Wet Leakage Current Test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
19	Electroluminescence at Isc (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
20	Visual Inspection Test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
21	Insulation test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
22	PID Test: 3 Cycles at 85°C ± 2°C, 85 ± 3% of RH for 96Hrs – Total 288Hrs	Test Condition: 3 Cycles at 85°C ± 2°C, 85 ± 3% of RH for 96Hrs – THIRD CYCLE
23	Maximum Power Determination (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
24	Performance at low irradiance (Post-PID Test) - Final	REFER INDIVIDUAL TEST TABLE
25	Wet Leakage Current Test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
26	Electroluminescence at Isc (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
27	Visual Inspection Test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE
28	Insulation test (Post-PID Test)	REFER INDIVIDUAL TEST TABLE



Master Equipment and Calibration details

SI No.	Test Name	Id Number	Description	Expiration Date
1	Preconditioning	54584	Apparatus, Pyranometer, Solar Diffuse Radiance	2025-AUG-26
2	Preconditioning	175794	Fixture, For Testing, Metal Plate	Support Equipment
3	Preconditioning	168531	Datalogger	2023-FEB-25
4	Visual inspection- Initial	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
5	Visual inspection- Initial	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
6	Visual inspection- Initial	180089	Meter and/or Sensor, Light	2022-JUL-16
7	Visual inspection- Initial	76645	Magnifying Lens, Without Ruler	Support Equipment
8	Visual inspection- Initial	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
9	Maximum power determination- Initial	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
10	Maximum power determination- Initial	199796	Apparatus, Solar Simulator	Support Equipment
11	Maximum power determination- Initial	64832	Datalogger, RH & Temperature	2022-SEP-30
12	Maximum power determination- Initial	199638	Thermometer, Infrared	2023-APR-05
13	Maximum power determination- Initial	176312	Reference Standard, Voltage or Current	2022-DEC-15
14	Maximum power determination- Initial	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
15	Electroluminescence Test- Power supply- Initial	70251	Power Supply, DC	2023-JUN-07
16	INSULATION RESISTANCE TESTER- Initial	169917	Apparatus, Dielectric Strength Test	2023-APR-13
17	INSULATION RESISTANCE TESTER- Initial	64832	Datalogger, RH & Temperature	2022-SEP-30
18	WET LEAKAGE CURRENT TEST- Initial	177914	Meter, pH, Digital or Analog	2023-JAN-24
19	WET LEAKAGE CURRENT TEST- Initial	151524	Apparatus, High Voltage Low Current Arc Tester	2022-DEC-06
20	WET LEAKAGE CURRENT TEST- Initial	167776	Fixture, For Testing, Water Tank	Support Equipment
21	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Initial	78723	Ammeter, Digital, Clamp-on	2022-AUG-06
22	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Initial	78719	Multimeter, Digital, Handheld	2021-AUG-04
23	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Initial	70580	Power Supply, DC	2022-DEC-01
24	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Initial	69871	Power Supply, DC	2023-JUN-07

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



	T			
25	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Initial	72840	Power Supply, DC	2023-JUN-07
26	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Initial	157279	Stopwatch, Digital or Analog	2022-AUG-10
27	PID (Potential Induced Degradation) Testing- 1st cycle	72835	Chamber, Climatic, Temp and RH	2023-APR-01
28	PID (Potential Induced Degradation) Testing- 1st cycle	85103	Datalogger, Temperature	2023-APR-01
29	PID (Potential Induced Degradation) Testing- 1 st cycle	216904	Power Supply, DC	2023-MAY-04
30	PID (Potential Induced Degradation) Testing- 1st cycle	202654	Load, Resistive, Variable	Support Equipment
31	PID (Potential Induced Degradation) Testing- 1st cycle	59358	Datalogger	2023-FEB-03
32	PID (Potential Induced Degradation) Testing- 1st cycle	78719	Multimeter, Digital, Handheld	2021-AUG-04
33	Visual inspection AFTER 1st cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
34	Visual inspection AFTER 1st cycle	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
35	Visual inspection AFTER 1st cycle	180089	Meter and/or Sensor, Light	2022-JUL-16
36	Visual inspection AFTER 1st cycle	76645	Magnifying Lens, Without Ruler	Support Equipment
37	Visual inspection AFTER 1st cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
38	Maximum power determination AFTER 1st cycle	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
39	Maximum power determination AFTER 1st cycle	199796	Apparatus, Solar Simulator	Support Equipment
40	Maximum power determination AFTER 1st cycle	64832	Datalogger, RH & Temperature	2022-SEP-30
41	Maximum power determination AFTER 1st cycle	199638	Thermometer, Infrared	2023-APR-05
42	Maximum power determination AFTER 1st cycle	176312	Reference Standard, Voltage or Current	2022-DEC-15

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



T. a		1	ı
determination AFTER 1st cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
Electroluminescence Test- Power supply- AFTER 1 st cycle	70251	Power Supply, DC	2023-JUN-07
INSULATION RESISTANCE TESTER AFTER 1st cycle	169917	Apparatus, Dielectric Strength Test	2023-APR-13
INSULATION RESISTANCE TESTER AFTER 1st cycle	64832	Datalogger, RH & Temperature	2022-SEP-30
WET LEAKAGE CURRENT TEST AFTER 1st cycle	177914	Meter, pH, Digital or Analog	2023-JAN-24
WET LEAKAGE CURRENT TEST AFTER 1st cycle	151524	Apparatus, High Voltage Low Current Arc Tester	2022-DEC-06
WET LEAKAGE CURRENT TEST AFTER 1st cycle	167776	Fixture, For Testing, Water Tank	Support Equipment
PID (Potential Induced Degradation) Testing- 2 nd cycle	85103	Datalogger, Temperature	2023-APR-01
PID (Potential Induced Degradation) Testing- 2 nd cycle	216904	Power Supply, DC	2023-MAY-04
PID (Potential Induced Degradation) Testing- 2 nd cycle	202654	Load, Resistive, Variable	Support Equipment
PID (Potential Induced Degradation) Testing- 2 nd	59358	Datalogger	2023-FEB-03
PID (Potential Induced Degradation) Testing- 2 nd cycle	72835	Chamber, Climatic, Temp and RH	2023-APR-01
PID (Potential Induced Degradation) Testing- 2 nd cycle	78719	Multimeter, Digital, Handheld	2021-AUG-04
Visual inspection AFTER	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
Visual inspection AFTER	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
Visual inspection AFTER	180089	Meter and/or Sensor, Light	2022-JUL-16
Visual inspection AFTER 2 nd cycle	76645	Magnifying Lens, Without Ruler	Support Equipment
Visual inspection AFTER 2 nd cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
	Electroluminescence Test- Power supply- AFTER 1st cycle INSULATION RESISTANCE TESTER AFTER 1st cycle INSULATION RESISTANCE TESTER AFTER 1st cycle WET LEAKAGE CURRENT TEST AFTER 1st cycle PID (Potential Induced Degradation) Testing- 2nd cycle Visual inspection AFTER	determination AFTER 1st cycle Electroluminescence Test-Power supply- AFTER 1st cycle INSULATION RESISTANCE TESTER AFTER 169917 AFTER 1st cycle INSULATION RESISTANCE TESTER 64832 AFTER 1st cycle WET LEAKAGE CURRENT TEST AFTER 177914 1st cycle WET LEAKAGE CURRENT TEST AFTER 151524 Ist cycle WET LEAKAGE CURRENT TEST AFTER 167776 1st cycle WET LEAKAGE CURRENT TEST AFTER 167776 1st cycle PID (Potential Induced Degradation) Testing- 2nd cycle Visual inspection AFTER 2nd cycle	determination AFTER 1st cycle Electroluminescence Test-Power supply- AFTER 1st cycle INSULATION RESISTANCE TESTER AFTER 1st cycle INSULATION RESISTANCE TESTER AFTER 1st cycle INSULATION RESISTANCE TESTER AFTER 1st cycle WET LEAKAGE CURRENT TEST AFTER 1st cycle PID (Potential Induced Degradation) Testing- 2nd cycle Visual inspection AFTER 2n

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



61	Maximum power determination AFTER 2 nd cycle	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
62	Maximum power determination AFTER 2 nd cycle	199796	Apparatus, Solar Simulator	Support Equipment
63	Maximum power determination AFTER 2 nd cycle	64832	Datalogger, RH & Temperature	2022-SEP-30
64	Maximum power determination AFTER 2 nd cycle	199638	Thermometer, Infrared	2023-APR-05
65	Maximum power determination AFTER 2 nd cycle	176312	Reference Standard, Voltage or Current	2022-DEC-15
66	Maximum power determination AFTER 2 nd cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
67	Electroluminescence Test- Power supply AFTER 2 nd cycle	70251	Power Supply, DC	2023-JUN-07
68	INSULATION RESISTANCE TESTER AFTER 2 nd cycle	169917	Apparatus, Dielectric Strength Test	2023-APR-13
69	INSULATION RESISTANCE TESTER AFTER 2 nd cycle	64832	Datalogger, RH & Temperature	2022-SEP-30
70	WET LEAKAGE CURRENT TEST AFTER 2 nd cycle	177914	Meter, pH, Digital or Analog	2023-JAN-24
71	WET LEAKAGE CURRENT TEST AFTER 2 nd cycle	151524	Apparatus, High Voltage Low Current Arc Tester	2022-DEC-06
72	WET LEAKAGE CURRENT TEST AFTER 2 nd cycle	167776	Fixture, For Testing, Water Tank	Support Equipment
73	PID (Potential Induced Degradation) Testing- 2 nd cycle	85103	Datalogger, Temperature	2023-APR-01
74	PID (Potential Induced Degradation) Testing- 2 nd cycle	216904	Power Supply, DC	2023-MAY-04
75	PID (Potential Induced Degradation) Testing- 2 nd cycle	202654	Load, Resistive, Variable	Support Equipment
76	PID (Potential Induced Degradation) Testing- 2 nd cycle	59358	Datalogger	2023-FEB-03
77	PID (Potential Induced Degradation) Testing- 2 nd cycle	72835	Chamber, Climatic, Temp and RH	2023-APR-01

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



	1 = 1 = 1 = 1 = 1			T .
78	PID (Potential Induced Degradation) Testing- 2 nd cycle	78719	Multimeter, Digital, Handheld	2022-AUG-06
79	Visual inspection AFTER 3 rd cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
80	Visual inspection AFTER 3 rd cycle	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
81	Visual inspection AFTER 3 rd cycle	180089	Meter and/or Sensor, Light	2022-JUL-16
82	Visual inspection AFTER 3 rd cycle	76645	Magnifying Lens, Without Ruler	Support Equipment
83	Visual inspection AFTER 3 rd cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
84	Maximum power determination AFTER 3 rd cycle	69881	Measuring Tool, Caliper, Digital or Analog	2022-DEC-07
85	Maximum power determination AFTER 3 rd cycle	199796	Apparatus, Solar Simulator	Support Equipment
86	Maximum power determination AFTER 3 rd cycle	64832	Datalogger, RH & Temperature	2022-SEP-30
87	Maximum power determination AFTER 3 rd cycle	199638	Thermometer, Infrared	2023-APR-05
88	Maximum power determination AFTER 3 rd cycle	176312	Reference Standard, Voltage or Current	2022-DEC-15
89	Maximum power determination AFTER 3 rd cycle	176846	Measuring Tool, Rigid Ruler	2022-DEC-06
90	Electroluminescence Test- Power supply- AFTER 3 rd cycle	70251	Power Supply, DC	2023-JUN-07
91	INSULATION RESISTANCE TESTER AFTER 3 rd cycle	169917	Apparatus, Dielectric Strength Test	2023-APR-13
92	INSULATION RESISTANCE TESTER AFTER 3 rd cycle	64832	Datalogger, RH & Temperature	2022-SEP-30
93	WET LEAKAGE CURRENT TEST AFTER 3 rd cycle	177914	Meter, pH, Digital or Analog	2023-JAN-24
94	WET LEAKAGE CURRENT TEST AFTER 3 rd cycle	151524	Apparatus, High Voltage Low Current Arc Tester	2022-DEC-06
95	WET LEAKAGE CURRENT TEST AFTER 3 rd cycle	167776	Fixture, For Testing, Water Tank	Support Equipment

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



96	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Final	78723	Ammeter, Digital, Clamp-on	2022-AUG-06
97	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Final	78719	Multimeter, Digital, Handheld	2022-AUG-06
98	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Final	70580	Power Supply, DC	2022-DEC-01
99	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Final	69871	Power Supply, DC	2023-JUN-07
100	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Final	72840	Power Supply, DC	2023-JUN-07
101	CONTINUITY TEST OF EQUIPOTENTIAL BONDING- Final	157279	Stopwatch, Digital or Analog	2022-AUG-10



Test methodology adopted:- As per IEC TS 62804-1: 2015 and MNRE requirement.

Test Observation and Results:

Table 10.1		VISUAL INSPECTION- INITIAL (Pre PID Test after Preconditioning) [MM/DD/YYYY]: 06/13/2022		
Sam	Sample No. Position in test sequence:			
		Initial examination	No major finding	_
	15522 ontrol)	Preconditioning: (mm/dd/yyyy)	Exposed for 5 kwh/m2 (06/11/2022 to 06/12/2022)	5.50 kwh/m2
		Final examination	No major finding	_
		Initial examination	No major finding	_
49	15527	Preconditioning: (mm/dd/yyyy)	Exposed for 5 kwh/m2 (06/11/2022 to 06/12/2022)	5.50 kwh/m2
		Final examination	No major finding	_
		Initial examination	No major finding	
4915528		Preconditioning: (mm/dd/yyyy)	Exposed for 5 kwh/m2 (06/11/2022 to 06/12/2022)	5.50 kwh/m2
		Final examination	No major finding	_

10.2	TABLE: MAXIMUI PRECONDITIONII	AXIMUM POWER DETERMINATION – INITIAL (PRE PID TEST AFTER ITIONING)						
Test Date [M	M/DD/YYYY]	:	06/1	3/2022				_
Module temp	erature [°C]	:	25					_
Irradiance [W/m²):			1000)				_
Sample #	Voc [V]	Vmp [V]		Isc [A]	Imp [A]	Pmp [W]	F	FF [%]
4915522 (control)	49.84	41.46		13.77	13.20	547.29		80.0
4915527	49.66	41.52		13.85	13.24	549.60		80.0
4915528	49.77	41.87		13.84	13.25	554.60		81.0
Supplementa	Supplementary information: N/A							



10.7 B	.7 B TABLE: PERFORMANCE AT LOW IRRADIANCE- INITIAL (PRE PID TEST)							Р
Test Date [M	M/DD/YYYY]	:		06/13/20	022			_
Ambient air to	emperature [°C]	:		25.1				_
Irradiance [W	//m2](200 W/m2)	:		200				_
Module temperature [°C]:				25.0				_
Test method:				tempera	corrected to a 2 sture and 200 W/ ctly measured			_
Sample #	Voc [V]	Vmp [V]	Iso	c [A]	Imp [A]	Pmp [W]		FF [%]
4915522 (control)	46.76	40.26	2.76		2.63	105.88		82.0
4915527	46.61	1 40.48 2			2.63	106.53		82.0
4915528 46.74 40.45 2.			.77	2.64	106.93		83.0	
Supplementa	Supplementary information: N/A							

10.15	TABLE: Wet leakage current test- (Pre PID Test)				
Test Date [MI	M/DD/YYYY]:	06/16/2022		_	
Test Voltage	applied [V]:	1500		_	
Solution resis	stivity [Ω cm):	2 cm) Required Measured			
		< 3,500 Ω-cm at 22 ± 3°C	2100		
Solution temp	perature [°C]:	23.1			
Sample #	Measured [MΩ]	Limit [MΩ]		Result	
4915522 (control)	3900	15.50		Р	
4915527	3000	15.50		Р	
4915528	4100	15.50		Р	
Supplementa	ry information: Size of module [m²]: 2.5	8			

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



Table	ELECTROLUMINESCENCE IMAGES – INITIAL (PRE PID TEST) Test Date [MM/DD/YYYY] : 06/13/2022
Sample No.	Image At Isc
4915522 (control)	
4915527	






Table 10.4	MST 13 - 0	GROUND CONTINUITY TEST (Pre PID Test)				
	Maximum over-current protection rating (A):					
	Current ap	plied (A):	62.5		_	
	Location of	designated grounding point::	Grounding hole side (long side)	on frame left	_	
	Location of	second contacting point:	Grounding hole side (long side)	on frame right	_	
Sample	No.	Position in test sequence:	Voltage (V)	Resistance (Ω)	P/F	
491552	22	Initial examination Test Date [MM/DD/YYYY]: 06/16/2022	0.678	0.0108	Р	
(control)		Final examination Test Date [MM/DD/YYYY]: 07/05/2022	0.789	0.0126	Э	
40455	0.7	Initial examination Test Date [MM/DD/YYYY]: 06/16/2022	0.650	0.0104	Р	
491552	21	Final examination Test Date [MM/DD/YYYY]: 07/05/2022	0.854	0.0136	Р	
1015700		Initial examination Test Date [MM/DD/YYYY]: 06/16/2022	0.720	0.0115	Р	
491552	2 ŏ	Final examination Test Date [MM/DD/YYYY]: 07/05/2022	0.567	0.0090	Р	
Supplementary i	nformation:	N/A				

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



10.3 Insulation test (Pre PID Test)							
Test Date [MM/	DD/YYYY]	:	06/16/2022	_			
Test Voltage ap	plied [V]	:	IR=1500, Dielectric=8000	_			
Sample #	Measured, $M\Omega$	Required, $M\Omega$	Dielectric breakdown; Yes (description)/ No	Result			
4915522 (control)	6700	15.50	No	Р			
4915527	9800	15.50	No	Р			
4915528 8400 15.50 No		No	Р				
Supplementary	Supplementary information: Size of module [m²]: 2.58						

Procedure for PID Test:

a) The module shall be placed into an environmental chamber supported by a non-porous electrically insulating mounting material. Modules shall be placed by default in any upright position; however, this placement may be changed if it is helpful to better achieve the intended goals of this test method, including improved air circulation, temperature and relative humidity uniformity, tolerances, and set points, or implementation of the module's specifically documented mounting or grounding instructions.

NOTE Insulator mounts are used to prevent alternative paths for leakage current between the biased active cell circuit and the manufacturers intended ground points, if any are provided, and for the safety of personnel and equipment. The insulation of the individual modules from each other may also be required to control the path to ground.

b) The method of the connection at the grounding point shall be based on the installation manual. For continuous metallic frames encasing the perimeter of the module that have grounding points or that have points for mounting the module that are not specified to be used on insulating mounting structures, the ground terminal of the voltage power supply shall be connected to a grounding point of the module with the manufacturer-specified

grounding hardware, or if not specified, an insulated wire terminated with a crimped-on ring terminal attached with a stainless steel nut, bolt, and star washer. Thin layer coatings on the metallic frame shall be removed by abrasion to achieve metal-to-metal contact between the connector and the module frame.

In the case of modules with frames that are not continuous or compliant with IEC 61730-2 MST 13, non-metallic frames, and metallic frames with insulating surfaces that cannot be reasonably penetrated anywhere by abrasion, all module mounting points and grounding points available on the module shall be connected at those points of attachment to one another and to the ground terminal of the DC voltage supply with insulated wire terminated with a crimped-on screw connector and stainless steel annulus washers in contact with the module.

Modules without frames (frameless modules) should be tested with the supplied mounting brackets that are consistent in every way with that specified in the module installation manual. If none are specified in the installation manual or if the specifications do not indicate a specific bracket model or materials and dimensions of mounting brackets, then the stress test shall include a conductively adhered conductive foil on the perimeter of the module that spans from the module edges to the active cell circuit. The foil, which simulates a grounded module frame, is connected to the ground terminal of the DC voltage supply.

The testing shall reasonably accommodate requests by the module manufacturer to reproduce manufacturer-specified mounting configurations that could influence the electrical resistance between the module surfaces and ground. Specifically, if

- the PV module is provided or is specified for use with an insulating structure for mounting, and
- 2) the module is designed and specified not to be connected to ground,

then such method of mounting the module shall be implemented to the extent possible. The base of that structure or portion designed to be mounted to a building structure or on the ground shall be thoroughly grounded and connected to the ground terminal of the DC voltage power supply during the course of the test.

c) Positive and negative electrical terminal wires (leads, tags, studs, screws, connectors) of the module shall be connected to one another and to the appropriate energized DC voltage terminal of the power supply with insulated wire rated for the intended test voltage.

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



- d) Stresses are applied to the module in chamber according to the severities listed in 4.3.2.2 referencing the example profile in Figure 2. Recording of sensor data shall be commenced. The chamber temperature shall be ramped from ambient to the specified stress temperature. When the chamber air temperature and the module temperature reach the set point within tolerance, increase the relative humidity to arrive at the prescribed severity. When the temperature and relative humidity set points are reached within the prescribed tolerances, start the 12 h to 24 h stabilization period for the environmental conditions. At the end of this period, switch on the voltage to the prescribed stress level (rated maximum system voltage and polarity). The prescribed dwell period begins when the voltage has arrived at the prescribed severity.
- e) For the cooling phase to ambient temperature (25 °C or less) at the end of the damp heat dwell, turn off the humidity generation and simultaneously begin to cool the chamber so that the modules reach the ambient temperature in a maximum of 1 h. The specified applied voltage shall be switched off when the module temperature reaches 25 °C \pm 5 °C.




Figure 2 – Example test time-temperature-humidity-voltage profile for application of stress in an environmental chamber

POTENTIAL INDUCED DEGRADATION TEST					
Voltage across the terminal	& frame	1500		_	
Chamber Temperature		85 ± 2 °C		_	
Chamber RH (%)		85 ± 3 %		_	
Hours of exposure		1st Cycle at 85°C ± 2°C, RH for 96Hrs	85 ± 3% of		
Sample No.	Position in test sequence:	Voltage (V)	Resistance (Ω)		
	Negative connected to frame	_	_	_	
4915527	Positive connected to shorted terminals	1500	500	_	
	Negative connected to frame	_	_	_	
4915528	Positive connected to shorted terminals	1500	500	_	
Supplementary information:	Test Date [MM/DD/YYYY]	: 06/16/2022 to	06/20/2022.		

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



10.2	TABLE: MAXIMUM POWER DETERMINATION (POST PID TEST) – AFTER 1ST CYCLE							
Test Date [MM/DD/YYYY]			06/21/2022			_		
Module temperature [°C]		25	25					
Irradiance [W/m²):		1000			_			
Sample	¥ Voc [V]	Vmp [V]	Isc [A]	Imp [A]	Pmp [W]	FF [%]		
4915522 (control)	49 / 9	41.61	13.76	13.15	547.05	80.0		
4915527	49.57	41.54	13.82	13.19	548.12	80.0		
4915528	49.65	41.51	13.81	13.30	551.89	80.0		
Supplementary information: Degradation Observed: 4915527: (-0.26), 4915528: (-0.48)								

	TABLE: PERFORMANCE AT LOW IRRADIANCE- (POST PID TEST) – AFTER 1 ST CYCLE					Т	Р	
Test Date [MI	M/DD/YYYY]	:		06/21/2	022			_
Ambient air te	emperature [°C]	:		25.0				_
Irradiance [W	/m2](200 W/m2)	:		200				_
Module temperature [°C] 24.6						_		
Test method:				tempera	a corrected to a 2 ature and 200 W/ ctly measured			_
Sample #	Voc [V]	Vmp [V]	Iso	[A]	Imp [A]	Pmp [W]	F	F [%]
4915527	46.51	40.25	2.77		2.61	105.20	8	32.0
4915528	46.59	40.16	2	.77	2.64	106.20	8	32.0
Supplementa	ry information: N/A	1			1	<u> </u>		



10.15	TABLE: Wet leakage current test- (Post PID Test) – After 1st Cycle				
Test Date [MM/DD/YYYY]:		06/21/2022		_	
Test Voltage applied [V]:		1500		_	
		Required	Measured		
Solution resistivity [Ω cm):		< 3,500 Ω-cm at 22 ± 3°C	1910		
Solution temp	perature [°C]:	23.5			
Sample #	Measured [MΩ]	Limit [MΩ]		Result	
4915527	3240	15.50		Р	
4915528 2700		15.50		Р	

ELECTROLUMINESCENCE IMAGES - (POST PID TEST) - AFTER 1ST CYCLE
Test Date [MM/DD/YYYY]: 06/21/2022

Sample No. Image At Isc

4915527






Table 10.1	MST 01 – VIS	UAL INSPECTION - (Post PID Test	Р	
Sam	ple No.	•	Test date: 06/21/2022(MM/DD/YYYY)	
4915527		Horizontal	No visual defects were found	Р
491	5528	Horizontal	No visual defects were found	Р

10.3 Insulation test (Post PID Test) – AFTER 1ST CYCLE				
Test Date [MM/	DD/YYYY]	:	06/21/2022	
Test Voltage ap	plied [V]	:	IR=1500, Dielectric=8000	
Sample #			Dielectric breakdown; Yes (description)/ No	Result
4915527	7150	15.50	No	Р
4915528 5300 15.50		15.50	No	Р
Supplementary	information: Si	ze of module [m²]: 2	.58	

Note and other observations from Lab: N/A



POTENTIAL INI	DUCED DEG	GRADATION TEST			P
	Voltage ac	ross the terminal & frame	1500	_	
	Chamber Temperature 8				_
	Chamber F	RH (%)	85 ± 3 %		_
·			2nd Cycle at 85 3% of RH for 96	•	_
Sample	No.	Position in test sequence:	Voltage (V)	Resistance (Ω)	
		Negative connected to frame	_	_	_
49155	27	Positive connected to shorted terminals	1500	500	_
		Negative connected to frame	_	_	-
4915528		Positive connected to shorted terminals	1500	500	_
Supplementary i	information:	Test Date [MM/DD/YYYY]	: 06/23/2022 to	06/27/2022.	

10.2	TABLE: MAXIMUM POWER DETERMINATION (POST PID TEST) – AFTER 2 ND CYCLE							
Test Date [MM/DD/YYYY]		06/2	27/2022					
Module temperature [°C]		25						
Irradiance [W/m²):		:	100	00				
Sample	# Voc [V]	Vmp [V]		Isc [A]	Imp [A]	Pmp [W]		FF [%]
4915522 (control)	49.70	41.39		13.76	13.22	547.26		80.0
491552	49.70	41.50		13.83	13.17	546.74		80.0
4915528	3 49.73	41.40		13.82	13.26	548.94		80.0

Supplementary information:

Total Degradation Observed: initial to 2nd cycle: 4915527: (-0.52) 4915528: (-1.02)

1st cycle to 2nd cycle: 4915527: (-0.25) 4915528: (-0.53)



	TABLE: PERFORMANCE AT LOW IRRADIANCE- (POST PID TEST) – AFTER 2 ND CYCLE							
Test Date [MN	Test Date [MM/DD/YYYY]: 06/27/2022							
Ambient air te	mperature [°C]	:		25			_	
Irradiance [W/	m2](200 W/m2)	:		200			_	
Module tempe	erature [°C]	:		25			_	
Test method		:		 ☑ Data corrected to a 25°C cell temperature and 200 W/m² irradiance ☑ Directly measured 			_	
Sample #	Voc [V]	Vmp [V]	Iso	[A]	Imp [A]	Pmp [W]	FF [%]	
4915527 46.60 40.28 2				.77	2.60	104.75	81.0	
4915528 46.64 40.46 2.77 2.62 106.11							82.0	
Supplementar	Supplementary information: N/A							

10.15	TABLE: Wet leakage current test- (Post PID Test) – After 2nd Cycle				
Test Date [MI	M/DD/YYYY]:	06/27/2022		_	
Test Voltage	applied [V]:	1500			
		Required	Measured		
Solution resistivity [Ω cm)		< 3,500 Ω-cm at 22 ± 3°C	2130		
Solution temp	perature [°C]:	22.8			
Sample #	Measured [MΩ]	Limit [MΩ]		Result	
4915527	3420	15.50		Р	
4915528	3230	15.50		Р	
Supplementa	ry information: Size of module [m²]: 2.56	3			



Table	ELECTROLUMINESCENCE IMAGES – (POST PID TEST) – AFTER 2ND CYCLE Test Date [MM/DD/YYYY]: 06/27/2022							
Sample No.	Image At Isc							
4915527								
4915528								

Table 10.1	MST 01 – VIS	MST 01 – VISUAL INSPECTION – (Post PID Test) – AFTER 2ND CYCLE						
Sample No. Position in test sequence:		•	Test date: 06/27/2022 (MM/DD/YYYY)					
491	5527	Horizontal	No visual defects were found	Р				
491	5528	Horizontal	No visual defects were found	Р				

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



10.3 Insulation test (Post PID Test) – AFTER 2ND CYCLE					
Test Date [MM/DD)/YYYY]	:	06/27/2022	_	
Test Voltage applie	ed [V]	:	IR=1500, Dielectric=8000	_	
Sample #			Dielectric breakdown; Yes (description)/ No	Result	
4915527	9900	15.50	No	Р	
4915528 12100 15.50			No	Р	
Supplementary info	ormation: Size	of module [m²]: 2.58	3		

Note and other observations from Lab: N/A

POTENTIAL INDUCED D	POTENTIAL INDUCED DEGRADATION TEST					
Voltage a	across the terminal & frame	1500	1500			
Chambe	Temperature	85 ± 2 ℃		_		
Chambe	· RH (%)	85 ± 3 %		_		
Hours of	exposure	3rd Cycle at 85° 3% of RH for 96	•	_		
Sample No.	Position in test sequence:	Voltage (V)	Resistance (Ω)			
	Negative connected to frame	_	1	_		
4915527	Positive connected to shorted terminals	1500	500	1		
	Negative connected to frame	_	_	_		
Positive connected to shorted terminals		1500	500	_		
Supplementary information	n: Test Date [MM/DD/YYYY]	: 06/30/2022 to	07/04/2022.			

	TABLE: MAXIMUM POWER DETERMINATION (POST PID TEST) – AFTER 3RD CYCLE							Р
Test Date [MM/DD/YYYY]			07/0	04/2022				_
Module te	mperature [°C]	:	25					_
Irradiance [W/m²):			100	00				_
Sample	Voc [V]	Vmp [V]		Isc [A]	Imp [A]	Pmp [W]		FF [%]

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



4915522 (control)	49.79	41.48	13.76	13.20	547.38	80.0
4915527	49.59	41.28	13.77	13.16	543.43	80.0
4915528	49.63	41.24	13.75	13.23	545.59	80.0

Supplementary information: Total Degradation Observed: Final Degradation:

Initial to 3rd cycle: 4915527: (-1.12) 4915528: (-1.62)

2nd cycle to 3rd cycle: 4915527: (-0.60) 4915528: (-0.61)

	TABLE: PERFORMANCE AT LOW IRRADIANCE- (POST PID TEST) – AFTER 3RD CYCLE											
Test Date [MI	M/DD/YYYY]	:		07/04/2	022			_				
Ambient air te	mperature [°C]	:		25				_				
Irradiance [W/	/m2](200 W/m2)	:		200				_				
Module tempe	erature [°C]	:		25				_				
Test method.		·····::		tempera	corrected to a 2 ature and 200 W/ ctly measured			_				
Sample #	Voc [V]	Vmp [V]	Iso	c [A]	Imp [A]	Pmp [W]	Ī	FF [%]				
4915527 46.44 39.63 2			.76	2.63	104.11		81.0					
4915528 46.51 40.36 2.75 2.61 105.34								82.0				
Supplemental	ry information: N/A		Supplementary information: N/A									

TABLE: Wet leakage current test- (Post PID Test) – After 3rd Cycle			
//DD/YYYY]:	07/05/2022	07/05/2022	
applied [V]:	1500	1500	
	Required	Measured	
tivity [Ω cm)	: < 3,500 Ω-cm at 22 ± 3°C	1860	
erature [°C]	23.4		
Measured [MΩ]	Limit [MΩ]	Limit [MΩ]	
3400	15.50		Р
2700	15.50	Р	
	M/DD/YYYY]: applied [V]	M/DD/YYYY]	M/DD/YYYY] : 07/05/2022 applied [V] : 1500 Required Measured tivity [Ω cm) : < 3,500 Ω-cm at 22 ± 3°C

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



Table	ELECTROLUMINESCENCE IMAGES – (POST PID TEST) – AFTER 3RD CYCLE Test Date [MM/DD/YYYY]: 07/04/2022			
Sample No.	Image At Isc			
4915527				
4915528				

Table 10.1	MST 01 – VISUAL INSPECTION – FINAL (Post PID Test) – AFTER 3RD CYCLE – FINAL CYCLE			Р
Sample No.		Position in test sequence:	Test date: : 07/04/2022(mm/dd/yyyy)	
4915527		Horizontal	No visual defects were found	Р
4915528		Horizontal	No visual defects were found	Р

UL India Private Limited

Registered Office: Kalyani Platina - Block I, 3rd Floor

No. 24, EPIP Zone, Phase II, Whitefield, Bangalore - 560066, India
T: 91.80.4138.4400 / F: 91.80.2841.3759 / W: ul.com

CIN: U74200KA1997PTC023189



10.3 Insulation test (Post PID Test)				Р	
Test Date [MM/DD/YYYY]:			07/05/2022	_	
Test Voltage applied [V]::		:	IR=1500, Dielectric=8000		
Sample #	Measured,	Required, MΩ	Dielectric breakdown; Yes (description)/ No	Result	
	MΩ				
4915527	10100	15.50	No	Р	
4915528	13200	15.50	No	Р	
Supplementary information: Size of module [m²]: 2.58					

Note and other observations from Lab: N/A

Test Observation (If any):- N/A


Appendix

Schematic Diagrams (If any):- N/A



Annexure-1:

PIV graphs (Initial):-






5600

Title: NOVASYS 4790378634
Comment: INITIAL PIV
Operator: Admin
ID: 4915522 (NOVABTMPVD00082)
Module Type: ModuleType1
11:25:16 13-06-2022
Measured Temperature = 25.0°C
Irr Meas = 99.9 mW/cm²
Irr Corr = 100.0mW/cm²
Irr Corr = 100.0mW/cm²
Voc = 49.84V
Isc = 13.77A
Pmax = 547.29W
Vpm = 41.46V
Ipm = 13.20A
FF = 0.80
Eff.m = 21.17%
Eff.c = 23.23%
Rs = 0.35 Ohm
Rsh = 278.05 Ohm

Load Voltage: 5.400 V IV Points: 3721








5600

Title: NOVASYS_4790378634
Comment: INITITÂL PIV
Operator: Admin
ID: 4915527 (NOVABTMPVD00083)
Module Type: ModuleType1
11:28:20 13-06-2022
Measured Temperature = 24.7°C
Corrected Temperature = 24.7°C
Corrected Temperature = 25.0°C
Irr Meas = 99.9mW/cm²
Irr Corr = 100.0mW/cm²
Voc = 49.66V
Isc = 13.85A
Pmax = 549.60W
Vpm = 41.52V
Ipm = 13.24A
FF = 0.80
Eff.m = 21.26%
Eff.c = 23.33%
Rs = 0.28 Ohm
Rsh = 315.34 Ohm

Load Voltage: 5.400 V IV Points: 3792







5600


Title: NOVASYS_4790378634
Comment: INITIAL PIV
Operator: Admin
ID: 4915528 (NOVABTMPVD00084)
Module Type: ModuleType1
11:20:43 13-06-2022
Measured Temperature = 25.0°C
Corrected Temperature = 25.0°C
Irr Meas = 99.9mW/m²
Irr Corr = 100.0mW/m²
Voc = 49.77V
Isc = 13.84A
Pmax = 554.60W
Vpm = 41.87V
Ipm = 13.25A
FF = 0.81
Eff,m = 21.45%
Eff,c = 23.54%
Rs = 0.27 Ohm

191.50 Ohm

Load Voltage: 5.400 V IV Points: 3793

Rsh =








5600

Title: NOVASYS_4790378634
Comment: INITIAL PIV LOW IRR
Operator: Admin
ID: 4915522 (NOVABTMPVD00082)
Module Type: ModuleType1
11:25:56 13-06-2022
Measured Temperature = 25.0°C
Corrected Temperature = 25.0°C
Irr Meas = 20.0mW/cm²
Irr Corr = 20.0mW/cm²
Voc = 46.76V
Isc = 2.76A
Pmax = 105.88W
Vpm = 40.26V
Ipm = 2.63A
FF = 0.82
Eff.m = 20.48%
Eff.c = 22.47%
Rs = 0.90 Ohm
Rsh = 2115.85 Ohm

Load Voltage: 2.000 V IV Points: 3787








5600

Title: NOVASYS_4790378634 Comment: INITIAL PIV LOW IRR Operator: Admin ID: 4915527 (NOVABTMPVD00083) Module Type: ModuleType1 11:29:58 13-06-2022 Measured Temperature = 24.6°C Corrected Temperature = 25.0°C Irr Meas = 20.0mW/cm² Irr Corr = 20.0mW/cm² Voc = 46.61V 2.77A 106.53W Isc = Pmax = Vpm= 40.48V 2.63A 0.82 20.60% 22.61% Eff,c =0.81 Ohm 307.38 Ohm Rs =

Load Voltage: 2.100 V IV Points: 3719

Rsh =







5600

Title: NOVASYS_4790378634 Comment: INITIAL PIV LOW IRR Operator: Admin ID: 4915528 (NOVABTMPVD00084) Module Type: ModuleType1 11:21:58 13-06-2022 Measured Temperature = 25.0°C Corrected Temperature = 25.0°C Corrected Temperature =

Irr Meas = 20.0mW/cm²

Irr Corr = 20.0mW/cm²


Voc = 46.74V

Isc = 2.77A Voc = Isc = 106.93W 40.45V Pmax = Vpm= Ipm = FF = 2.64A 0.83 Eff,m= 20.68% Eff,c = 22.69% 0.77 Ohm 1123.70 Ohm Rsh =

Load Voltage: 2.000 V IV Points: 3769



PIV graphs Post PID - 1st Cycle:






5600

Title: NOVASYS_4790378634 Comment: POST PID-1 Operator: Admin ID: 4915522 Module Type: ModuleType1 12:42:30 21-06-2022 Measured Temperature = 24.8°C Corrected Temperature = 25.0°C Irr Meas = 100.0mW/cm² Irr Corr = 100.0mW/cm² Voc = Isc = 49.79V 13.76A 547.05W 41.61V Pmax = Vpm = 13.15A 0.80 Eff,m= 21.16% Eff,c = 23.22% 0.32 Ohm 191.32 Ohm Rs= Rsh = Load Voltage: 5.400 V IV Points: 3712








560

Title: NOVASYS 4790378634
Comment: POST PID-1
Operator: Admin
ID: 4915527
Module Type: ModuleType1
12:37:09 21-06-2022
Measured Temperature = 24.6°C
Corrected Temperature = 25.0°C
Irr Meas = 99.9mW/cm²
Irr Corr = 100.0mW/cm²
Voc = 49.57V
Isc = 13.82A
Pmax = 548.12W
Vpm = 41.54V
Ipm = 13.19A
FF = 0.80
Eff.m = 21.20%
Eff.c = 23.26%
Rs = 0.30 Ohm
Rsh = 278.20 Ohm

Load Voltage: 5.400 V IV Points: 3780








5600

Title: NOVASYS 4790378634 Comment: POST PID-1 Operator: Admin ID: 4915528 Module Type: ModuleType1 12:31:26 21-06-2022 Measured Temperature = 24.7°C Corrected Temperature = 25.0°C Irr Meas = 99.9mW/cm² Irr Corr = 100.0mW/cm² 49.65V Voc = 13.81A Pmax = 551.89W 41.51V Vpm =Ipm = FF = 13.30A 0.80 21.35% Eff,m= Eff,c = 23.42% 0.28 Ohm 132.05 Ohm Rs =

Load Voltage: 5.400 V IV Points: 3773








5600

Title: NOVASYS_4790378634 Comment: POST PID-1 LOW IRR Operator: Admin ID: 4915522 Module Type: ModuleType1 12:43:57 21-06-2022 Measured Temperature = 24.8°C Corrected Temperature = 25.0°C Irr Meas = 20.0mW/cm² Irr Corr = 20.0mW/cm² Voc = Isc = 46.75V 2.76A Pmax = 105.61W Vpm= 40.11V 2.63A 0.82 Ipm = FF = 20.42% 22.41% Eff,m = Eff,c = Rs = 0.93 Ohm Rsh = 140.36 Ohm

Load Voltage: 2.100 V IV Points: 3755







5600

Title: NOVASYS 4790378634
Comment: POST PID-1 LOW IRR
Operator: Admin
D: 4915527
Module Type: ModuleType1
12:38:23 21-06-2022
Measured Temperature = 24.6°C
Corrected Temperature = 25.0°C
Irr Meas = 20.0mW/cm²
Irr Corr = 20.0mW/cm²
Voc = 46.51V
Isc = 2.77A
Pmax = 105.20W
Vym = 40.25V
Ipm = 2.61A
FF = 0.82
Eff,m = 20.34%
Eff,c = 22.32%


0.84 Ohm

127.83 Ohm

Load Voltage: 2.100 V IV Points: 3774

Eff,c = Rs = Rsh =








5600

Title: NOVASYS_4790378634 Comment: POST PID-1 LOW IRR Operator: Admin ID: 4915528 Module Type: ModuleType1 12:33:13 21-06-2022 Measured Temperature = 24.7°C Corrected Temperature = 25.0°C Irr Meas = 20.0mW/cm² Irr Corr = 20.0mW/cm² Voc = 2.77A 106.20W Isc = Pmax = Vpm= 40.16V Ipm = FF = 2.64A 0.82 0.82 20.54% 22.54% 0.91 Ohm 213.79 Ohm Eff,m= Eff,c = Rs =Rsh =



PIV graphs Post PID - 2nd Cycle:






5600

Title: NOVASYS_4790378634 Comment: POST PID-2 Operator: Admin ID: 4915522 Module Type: ModuleType1 18:22:04 27-06-2022 Measured Temperature = 24.8°C Corrected Temperature = 25.0°C Irr Meas = 100.0mW/cm² Irr Corr = 100.0mW/cm² 49.76V 13.76A 547.26W 41.39V Voc = Isc = Pmax = Vpm= Ipm = FF = 13.22A 0.80 21.17% 23.23% Eff.m= Eff,c = 0.31 Ohm Rsh = 132.96 Ohm








5600

Title: NOVASYS_4790378634 Comment: POST PID-2 Operator: Admin ID: 4915527 Module Type: ModuleType1 18:12:03 27-06-2022 Measured Temperature = 24.7°C Corrected Temperature = 25.0°C
Irr Meas = 100.0mW/cm²
Irr Corr = 100.0mW/cm² 13.83A 546.74W Isc = Pmax = Vpm= Ipm = FF = 13.17A 0.80 Eff,m= 21.15% Eff,c =23.20% 0.29 Ohm 152.33 Ohm Rs =Rsh =








5600

Title: NOVASYS_4790378634 Comment: POST PID-2 Operator: Admin ID: 4915528 Module Type: ModuleType1 18:16:46 27-06-2022 Measured Temperature = 24.9°C
Corrected Temperature = 25.0°C
Irr Meas = 100.0mW/cm²
Irr Corr = 100.0mW/cm²
Voc = 49.73V Voc = Isc = 13.82A 548.94W 41.40V 13.26A Pmax = Vpm= Ipm = FF = 0.80 21.23% 23.30% Eff,m = Eff,c = Rs= 0.29 Ohm Rsh = 200.19 Ohm








5600

Title: NOVASYS 4790378634
Comment: POST PID-2 LOW IRR
Operator: Admin
ID: 4915522
Module Type: Module Type1
18:22:50 27-06-2022
Measured Temperature = 24.8°C
Corrected Temperature = 25.0°C
Irr Meas = 20.1mW/cm²
Irr Corr = 20.0mW/cm²
Irr Corr = 20.0mW/cm²
Voc = 46.73V
Isc = 2.75A
Pmax = 105.72W
Vpm = 40.48V
Ipm = 2.61A
FF = 0.82
Eff.m = 20.45%
Eff.c = 22.44%
Eff.c = 22.4446
Rs = 0.87 Ohm
Rsh = 2271.78 Ohm








5600

Title: NOVASYS_4790378634 Comment: POST PID-2 LOW IRR Operator: Admin ID: 4915527 Module Type: ModuleType1 18:13:26 27-06-2022 Neasured Temperature = 24.7°C Corrected Temperature = 25.0°C Irr Meas = 20.0mW/cm² Irr Corr = 20.0mW/cm² Voc = 46.60V 2.77A Pmax = 104.75W 40.28V Vpm= Ipm = FF = 2.60A 0.81 Eff,m= 20.26% Eff,c = 22.23% Rs =0.95 Ohm 112.83 Ohm Rsh =







5600

Title: NOVASYS 4790378634 Comment: POST PID-2 LOW IRR Operator: Admin ID: 4915528 Module Type: ModuleType1 18:18:15 27-06-2022 18:18:10 2/-00-2022

Measured Temperature = 24.7°C

Corrected Temperature = 25.0°C

Irr Meas = 20.0mW/cm²

Irr Corr = 20.0mW/cm²

Voc = 46.64V

Isc = 2.77A

Dray = 106.11W 2.77A 106.11W 40.46V Pmax = Vpm= Ipm = FF = 2.62A 0.82 20.52% 22.52% 0.77 Ohm Eff,m=


Load Voltage: 2.100 V IV Points: 3627

270.27 Ohm

Eff,c = Rs =



PIV graphs Post PID - 3rd Cycle:






5600

Title: NOVASYS_4790378634
Comment: POST PID-3
Operator: Admin
ID: 4915522
Module Type: ModuleType1
18:02:03 04-07-2022
Measured Temperature = 25.1°C
Corrected Temperature = 25.0°C
Irr Meas = 100.0mW/cm²
Irr Corr = 100.0mW/cm²
Voc = 49.79V
Isc = 13.76A
Pmax = 547.38W
Vpm = 41.48V
Ipm = 13.20A
FF = 0.80
Eff.m = 21.17%
Eff.c = 23.23%
Rs = 0.33 Ohm
Rsh = 164.58 Ohm








5600

Title: NOVASYS_4790378634 Comment: POST PID-3 Operator: Admin ID: 4915527 Module Type: ModuleType1 18:06:58 04-07-2022 Measured Temperature = 24.3°C Corrected Temperature = 25.0°C Irr Meas = 100.0mW/cm² $Irr Corr = 100.0 mW/cm^2$ 49.59V 13.77A Voc = Isc = 543.43W 41.28V Pmax = Vpm =Ipm = FF = 13.16A 0.80 21.02% Eff,m= 23.06% 0.34 Ohm 116.62 Ohm Eff,c =Rs =Rsh =








5600

Title: NOVASYS_4790378634 Comment: POST PID-3 Operator: Admin ID: 4915528 Module Type: ModuleType1 18:11:14 04-07-2022 Measured Temperature = 24.9°C Corrected Temperature = 25.0°C Irr Meas = 100.0mW/cm² Irr Corr = 100.0mW/cm² Voc = Isc = 49.63V 13.75A Pmax = 545.59W 41.24V 13.23A Vpm= Ipm = FF = 0.80 21.10% 23.16% 0.29 Ohm Eff,m =Eff,c = Rs =Rsh = 211.06 Ohm








5600

Title: NOVASYS_4790378634 Comment: POST PID-3 LOW IRR Operator: Admin ID: 4915522 Module Type: ModuleType1 18:02:53 04-07-2022 Measured Temperature = 25.1°C Corrected Temperature = 25.0°C Irr Meas = 20.1mW/cm² Irr Corr = 20.0mW/cm² Voc = 46.77V Isc = 2.75A Pmax =105.64W 40.26V 2.62A Vpm =Ipm = FF = 0.82 Eff,m= 20.43% Eff,c = 22.42% 0.95 Ohm 1516.22 Ohm Rs =Rsh =








5600

Title: NOVASYS_4790378634
Comment: POST PID-3 LOW IRR
Operator: Admin
ID: 4915527
Module Type: ModuleType1
18:07:58 04-07-2022
Measured Temperature = 24.2°C
Corrected Temperature = 25.0°C
Irr Meas = 20.0mW/cm²
Irr Corr = 20.0mW/cm²
Voc = 46.44V
Isc = 2.76A

Voc = 46.44V Isc = 2.76A Pmax = 104.11W Vpm = 39.63V Ipm = 2.63A FF = 0.81 Eff.m = 20.13% Eff.c = 22.09% Rs = 0.93 Ohm Rsh = 201.34 Ohm







5600

Title: NOVASYS 4790378634
Comment: POST PID-3 LOW IRR
Operator: Admin
ID: 4915528
Module Type: ModuleType1
18:12:53 04-07-2022
Measured Temperature = 24.9°C
Corrected Temperature = 25.0°C
Irr Meas = 20.0mW/cm²
Irr Corr = 20.0mW/cm²
Irr Corr = 20.0mW/cm²
Voc = 46.51V
Isc = 2.75A
Pmax = 105.34W
Vpm = 40.36V
Ipm = 0.82
Eff,m = 0.82
Eff,m = 20.37%
Eff,c = 22.35%
Rs = 0.75 Ohm

286.21 Ohm

Load Voltage: 2.100 V IV Points: 3656

Rsh =