



1 TEST CERTIFICATION

Product: HMI (Human Machine Interface)

Model: MT8104iH

Brand: EasyView; WeinView; Weintek

Applicant: Weintek Labs., Inc.

3F., No.910, Zhongzheng Rd., Zhonghe Dist.,
New Taipei City, Taiwan

Manufacturer: Weintek Labs., Inc.

3F., No.910, Zhongzheng Rd., Zhonghe Dist.,
New Taipei City, Taiwan

Tested: December 24, 2009 ~ August 20, 2012

Applicable Standards: EN 55022: 2006 + A1: 2007 + A2: 2010, Class A
EN 61000-3-2: 2006 + A1: 2009 + A2: 2009

EN 61000-3-3: 2008

EN 55024: 2010

IEC 61000-4-2: 2008

IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010

IEC 61000-4-4: 2004 + A1: 2010

IEC 61000-4-5: 2005

IEC 61000-4-6: 2008

IEC 61000-4-8: 2009

IEC 61000-4-11: 2004

Deviation from Applicable Standard

None

The above equipment has been tested by Compliance Certification Services Inc., and found compliance with the requirements set forth in the technical standards mentioned above. The results of testing in this report apply only to the product/system, which was tested. Other similar equipment will not necessarily produce the same results due to production tolerance and measurement uncertainties.

Approved by:

Sam Hu
Section Manager

Reviewed by:

Vesta Hsu
Supervisor of report document dept.