



## 1 TEST CERTIFICATION

**Product:** HMI (Human Machine Interface)

**Model:** MT8050i; MT605i

**Brand:** EasyView; WeinView; Weintek

**Applicant:** **Weintek Labs., Inc.**  
3F., No.910, Zhongzheng Rd., Zhonghe Dist.,  
New Taipei City, Taiwan

**Manufacturer:** **Weintek Labs., Inc.**  
3F., No.910, Zhongzheng Rd., Zhonghe Dist.,  
New Taipei City, Taiwan

**Tested:** August 17, 2010 ~ August 20, 2012

<b>Applicable Standards:</b>	<b>EN 55022: 2006 + A1: 2007 + A2: 2010, Class A</b>	<b>EN 55024: 2010</b>
	<b>EN 61000-3-2: 2006 + A1: 2009 + A2: 2009</b>	IEC 61000-4-2: 2008
	<b>EN 61000-3-3: 2008</b>	IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010
		IEC 61000-4-4: 2004 + A1: 2010
		IEC 61000-4-5: 2005
		IEC 61000-4-6: 2008
		IEC 61000-4-8: 2009
		IEC 61000-4-11: 2004

Deviation from Applicable Standard
None

The above equipment has been tested by Compliance Certification Services Inc., and found compliance with the requirements set forth in the technical standards mentioned above. The results of testing in this report apply only to the product/system, which was tested. Other similar equipment will not necessarily produce the same results due to production tolerance and measurement uncertainties.

**Approved by:**

**Reviewed by:**

  
\_\_\_\_\_  
Sam Hu  
Section Manager

  
\_\_\_\_\_  
Vesta Hsu  
Supervisor of report document dept.