Insulated Gloves

Category: **Safety & PPE** Type: **Short SOP** Priority: **High** 3 labs

Covers these lab items: Dielectric safety gloves; Electrical Hand Gloves

What it is used for

Insulated gloves protect workers from electrical hazards when the gloves are correctly rated and used within their approved limits. Select the correct voltage class and follow the required inspection and testing procedures.

How to use

1. Check the glove class, voltage rating, certification, and test validity before use.
2. Inspect both gloves for cuts, punctures, cracks, moisture, and deterioration.
3. Perform the prescribed air-leak or inspection test according to the manufacturer's instructions.
4. Wear compatible leather protectors when required by the glove system.
5. Use gloves only for tasks covered by your electrical safety training and procedure.
6. Remove gloves carefully after work and inspect them again for damage.
7. Report defects and send gloves for required testing or replacement.

⚠ Safety

- Only qualified and authorised personnel should perform electrical work requiring insulating gloves.
- Never use wet, damaged, expired, or untested gloves.
- Do not exceed the gloves' rated voltage or use them outside their intended application.
- Follow isolation, lockout, and other electrical safety procedures; gloves alone do not make a circuit safe.

Care & storage

- Keep gloves clean and dry and store them away from sunlight, heat, oils, and sharp objects.
- Arrange electrical retesting and replacement according to applicable standards and manufacturer instructions.

Disclaimer: This SOP is prepared from general information available on the internet. For detailed instructions, refer to the manufacturer's original manual / file.