



SCHEDSVC Saver Centre 402181 - Tandex Service Report - 9388900

Customer Name and number	Saver Centre 402181
Site Address	33 Albert Street Footscray
Site Contact	Robert Knight
Telephone (Landline / Mobile)	(03) 9689 6811 0410 627 812
Site Contact Email	ecobusters@outlook.com
Report Number	208114
Report Copy To	admin@tomas.com.au; Rebeccaf@dixonkestles.com.au; ecobusters@outlook.com; management@portfolioms.com.au
Report Date	01 Jun 2022
Start Time	07:00 am
Service Type	Service

Cooling Tower Systems

Cooling Tower System	Cooling Tower
Cooling Tower Operational?	Yes

Parameter	Target	Result
Sample Appearance		Clear
pH	7.5 - 8.5	7.0
M.Alkalinity	< 300	30
Dissolved Solids (TDS)	<1300	208
Polytan	50 - 100	32
Water Temp		8


ALL VALUES IN PPM UNLESS OTHERWISE STATED

Equipment Type	Controller
Equipment Checked?	Yes
Biocide Slug Dose (Specify product and Lt)	RnO 50ml
Biodispersant Slug Dose (ml)	Cw10 50ml
Other Chemical dosed (specify)	Cw33c
Tests Taken	HCC LEG
Drains Flushed ?	Yes

Comments

All results are low due to water lost.
I have adjusted the ball float as much as possible, basin water level is just below overflow.
Tower is overflowing on shutdown i suspect.
This needs to be rectified to maintain protection of cooling tower from bacteria and corrosion.
Please speak with the cooling tower mechanics to solve issue.

Additional Details

Were any parts used for this service call ?	No
Chemical order	No
Invoice Method (internal use only)	Contract pending
Finish Time	07:37 am
Service Person Signature	
Service Person (Print Name)	Con Gouros
Customer Print Name	Robert Knight