
Compressed air —

Part 1:

Contaminants and purity classes

Air comprimé —

Partie 1: Polluants et classes de pureté



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

© ISO 2001

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.ch
Web www.iso.ch

Printed in Switzerland

Licensed to /MANOJ PATEL
ISO Store order #:831032/Downloaded:2007-06-20
Single user licence only, copying and networking prohibited

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 3.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this part of ISO 8573 may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

International Standard ISO 8573-1 was prepared by Technical Committee ISO/TC 118, *Compressors, pneumatic tools and pneumatic machines*, Subcommittee SC 4, *Quality of compressed air*.

This second edition cancels and replaces the first edition (ISO 8573-1:1991), which has been technically revised.

ISO 8573 consists of the following parts, under the general title *Compressed air*:

- *Part 1: Contaminants and purity classes*
- *Part 2: Test methods for aerosol oil content*
- *Part 3: Test methods for measurement of humidity*
- *Part 4: Test methods for solid particle content*
- *Part 5: Determination of oil vapour and organic solvent content*
- *Part 6: Determination of content of gaseous contaminants*

The following parts are in preparation:

- *Part 7: Test methods for viable microbiological contaminant content*
- *Part 8: Contaminants and purity classes (by mass concentration of solid particles)*
- *Part 9: Test methods for liquid water content*

Introduction

This part of ISO 8573 is one in a series of standards (planned or published), with the ambition of harmonizing air contamination measurements.

The source of odours from a compressed air supply may be present due to a number of factors. The presence of an odour results in discomfort to personnel using breathing equipment. The means of detection is the human olfactory system and the person involved bases the quantification on a subjective analysis. No reliable measurement methods are available therefore each situation must be treated as an individual case and appropriate action taken to minimise the discomfort. For the time being there will be no separate part of ISO 8573 dealing with odours.

Compressed air —

Part 1: Contaminants and purity classes

1 Scope

This part of ISO 8573 specifies purity classes of compressed air in respect of particles, water and oil regardless of the source of the compressed air.

This part of ISO 8573 identifies microbiological and gaseous contaminants.

The gaseous contaminants included in this part of ISO 8573 are carbon monoxide, carbon dioxide, sulfur dioxide, nitrogen dioxide, nitric oxide and hydrocarbons with carbon atoms in the range C₁ to C₅.

NOTE Other contaminants are taken into consideration for specific applications, e.g. air used for breathing, medical, food and beverage purposes.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of ISO 8573. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of ISO 8573 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

ISO 7183, *Compressed air dryers — Specifications and testing*.

ISO 8573-2, *Compressed air for general use — Part 2: Test methods for aerosol oil content*.

ISO 8573-3, *Compressed air — Part 3: Test methods for measurement of humidity*.

ISO 8573-4, *Compressed air — Part 4: Test methods for solid particle content*.

ISO 8573-5, *Compressed air — Part 5: Determination of oil vapour and organic solvent content*.

3 Terms and definitions

For the purposes of this part of ISO 8573, the terms and definitions given in ISO 7183 and the following apply.

3.1

aerosol

suspension in a gaseous medium of solid particles, liquid particles or solid and liquid particles having negligible fall-velocity/settling-velocity

3.2

agglomerate

group of two or more particles combined, joined or formed into a cluster by any means

3.3

dewpoint

temperature at which water vapour begins to condense

3.4

microbiological organisms

viable colony forming units which may be a bacteria, fungi or yeasts

3.5

oil

mixture of hydrocarbons composed of 6 or more carbon atoms (C_6)

3.6

particle

a small discrete mass of solid or liquid matter

3.7

particle size

d

length of the greatest distance between two external boundaries.

3.8

relative water vapour pressure

relative humidity

ratio of the partial pressure of water vapour to its saturation pressure at the same temperature

3.9

vapour

gas which is at a temperature below its critical temperature and which therefore can be liquefied by isothermal compression

4 Measurement of contaminants

For the purpose of assessing the purity class of a compressed air sample, measurements shall be made in accordance with the appropriate part of ISO 8573:

- Part 2 for measuring oil aerosols and oil liquid content of compressed air;
- Part 3 for measuring humidity;
- Part 4 for measuring solid particles;
- Part 5 for measuring oil vapour and organic solvent content;

Further parts of ISO 8573 are under preparation for measuring gaseous contaminant content (Part 6), for determining viable microbiological contaminant content (Part 7) and for measuring solid particles (Part 8) and liquid water content (Part 9). In their absence, other recognized standards shall be used for the measurement of the various contaminants, if possible, and the following rules apply:

- measurements shall be based on a number of samples taken during a suitable length of time;
- measurements should be carried out at the actual operating pressure and temperature;
- the purity classes of a compressed air system should be based on the mean value of an agreed number of measurements (see note);
- the purity classes are relevant only at the point of measurement (see note).

The content of particles, water and oil in compressed air varies due to sudden changes in the intake air, to the wear of components as well as to changes in flow, pressure, temperature and ambient conditions.

It is not possible to measure the full flow area of a compressed air stream using most test methods and therefore it is necessary to take samples of the air. Care should be exercised to ensure that the sample taken is representative of the compressed air purity.

NOTE Measurements should be carried out at the actual operating conditions as otherwise the balance between impurities in liquid, aerosol or gaseous form will be altered. Liquid oil and free water in particular tend to cling to pipe and tube walls where they form a film or thin rivulets.

5 Standard atmosphere

Reference conditions for volume statements shall be as specified in Table 1.

Table 1 — Reference conditions

Air temperature	20 °C
Air pressure	1 bar ^a absolute
Relative water vapour pressure	0
^a 1 bar = 0,1 MPa	

6 Contaminants

6.1 General

The three major impurities in compressed air are solid particles, water and oil. They influence each other (e.g. solid particulate agglomerates in the presence of oil or water to form larger particles, oil and water form an emulsion) and are sometimes deposited or condensed (e.g. oil vapour or water vapour) inside the pipework of a compressed air system. Other contaminants are also considered, including microbiological organisms and gaseous contaminants.

6.2 Solid particles

6.2.1 General

Solid particle properties are important and are characterized by density, shape, size and by hardness.

It is essential to eliminate the influence of water on particle size and number in order to obtain a correct reading.

6.2.2 Measuring parameters

6.2.2.1 Particle size

Particle size shall be measured in accordance with recognized methods.

6.2.2.2 Particle concentration

Concentration of particles shall be measured in accordance with ISO 8573-4. Mass concentration of particles shall be measured in accordance with a recognized standard (see clause 4).

6.2.2.3 Humidity

The actual humidity level shall be measured in accordance with ISO 8573-3.

6.3 Water

6.3.1 General

Atmospheric air always contains water vapour. When atmospheric air is compressed the partial pressure of the water vapour increases but, owing to the increase in temperature caused by the compression, no water precipitates. When the air is subsequently cooled (e.g. in an intercooler or aftercooler, in the distribution pipework or during the expansion process in a pneumatic tool) water will condense to liquid, but the air will be fully saturated with water vapour.

6.3.2 Measuring parameters

Humidity measurement shall be in accordance with ISO 8573-3 and for liquid water in accordance with a recognized standard (see clause 4).

6.4 Oil

6.4.1 General

For the purposes of this part of ISO 8573, oil in compressed air can belong to one or more of three categories: liquid, aerosol or vapour.

When considering oil vapour content of compressed air it is important to reference the temperature as this affects the ratio of vapour to total oil content.

Testing for vapour should be carried out in conjunction with the test for aerosols and bulk liquid so the various phase concentrations may be discerned. Due to the complex organic molecules, which may be involved, the calibration procedure of the measurement equipment shall be clearly stated.

6.4.2 Measuring parameters

6.4.2.1 Oil liquid, aerosol or vapour

The measurement of oil aerosol and liquid shall be in accordance with ISO 8573-2. The measurement of oil vapour shall be in accordance with ISO 8573-5.

6.4.2.2 Humidity

The actual humidity level shall be measured in accordance with ISO 8573-3.

6.5 Gaseous contaminants

Atmospheric air contains not only those common contaminants generally identified for treatment but also gaseous contaminants which may be present in varying amounts depending on location. Concentration of gaseous contaminants shall be measured in accordance with a recognized standard (see clause 4).

6.6 Microbiological organisms

Microbiological organisms are generally considered to be solid contaminants, which can be present in the atmospheric air. These organisms may be introduced into the compressed air by a number of means. If the microbiological organism is to be identified as a solid particle then the measurement method identified in ISO 8573-4 is used. If the colony forming activity of bacteria, fungi or yeasts is important then this can be identified using a recognized standard (see clause 4).

7 Compressed air purity classes

7.1 Solid particle classes

The solid particle classes are defined in Table 2. Values for classes 0 to 5 shall be measured in accordance with ISO 8573-4 and for classes 6 and 7 in accordance with a recognized standard (see clause 4).

Table 2 — Solid particle classes

Class	Maximum number of particles per m ³ (see clause 5)				Particle size µm	Concentration mg/m ³
	Particle size, <i>d</i> µm					
	≤ 0,10	0,10 < <i>d</i> ≤ 0,5	0,5 < <i>d</i> ≤ 1,0	1,0 < <i>d</i> ≤ 5,0		
0	As specified by the equipment user or supplier and more stringent than class 1				Not applicable	Not applicable
1	Not specified	100	1	0		
2	Not specified	100 000	1 000	10		
3	Not specified	Not specified	10 000	500		
4	Not specified	Not specified	Not specified	1 000		
5	Not specified	Not specified	Not specified	20 000		
6	Not applicable				≤ 5	≤ 5
7	Not applicable				≤ 40	≤ 10

NOTE A filtration ratio (β) related to a particle size class is the ratio between the number of particles upstream of the filter and the number of particles downstream. This can be expressed as ($\beta = 1/P$), where P is the penetration of the particles expressed as the ratio of down stream particle concentration to upstream particle concentration. The particle size class is used as an index, e.g. $\beta_{10} = 75$ means that the number of particles of size 10 µm (β m) and larger is 75 times higher upstream of the filter than downstream.

7.2 Humidity and liquid water classes

The humidity classes are defined in Table 3 and liquid water classes in Table 4. Values for pressure dewpoints shall be determined according to ISO 8573-3 and liquid water content according to a recognized standard (see clause 4). When lower dewpoints are required they shall be clearly specified.

Table 3 — Humidity classes

Class	Pressure dewpoint °C
0	As specified by the equipment user or supplier and more stringent than class 1
1	≤ −70
2	≤ −40
3	≤ −20
4	≤ +3
5	≤ +7
6	≤ +10

Table 4 — Liquid water classes

Class	Concentration of liquid water, C_w g/m ³
7	$C_w \leq 0,5$
8	$0,5 < C_w \leq 5$
9	$5 < C_w \leq 10$

7.3 Oil classes

The oil classes are defined in Table 5. Values for oil aerosol and oil liquid shall be determined according to ISO 8573-2 and oil vapour according to ISO 8573-5. The concentration of total oil is the sum of these values.

Table 5 — Oil classes

Class	Concentration total oil (aerosol, liquid, and vapour) mg/m ³
0	As specified by the equipment user or supplier and more stringent than class 1
1	$\leq 0,01$
2	$\leq 0,1$
3	≤ 1
4	≤ 5

7.4 Gases

The reporting of the levels of gaseous contaminant content included within the scope of this part of ISO 8573 shall be determined as the actual determined values in accordance with a recognized standard (see clause 4).

7.5 Microbiological organisms

Due to the complex nature of the involvement of microbiological organisms in many types of application the classification in this part of ISO 8573 is limited to a simple identity based on sterile or non-sterile applications. Reporting of the levels of contaminant content included within the scope of this part of ISO 8573 shall be determined as the actual determined values in accordance with a recognized standard (see clause 4).

7.6 Designation

The designation of the purity class of compressed air at the specified measuring point shall include the following information in the order given:

Compressed air purity classes ISO 8573-1 A B C

where

- A is the figure for solid particle classes as measured in accordance with ISO 8573-4 (see 7.1);
- B is the figure for humidity or liquid water classes as measured in accordance with ISO 8573-3 (see 7.2);
- C is the figure for total oil classes as measured in accordance with ISO 8573-2 and ISO 8573-5 (see 7.3).

When a class for any particular contaminant A, B or C is not specified, the designation shall be replaced by a hyphen.

Additional qualification may be given on:

- gaseous contaminant content (see 7.4);
- microbiological contaminant content (see 7.5).

Bibliography

- [1] ISO 3649, *Cleaning equipment for air or other gases — Vocabulary*.
- [2] ISO 8573-6, *Compressed air — Part 6: Determination of content of gaseous contaminants*.
- [3] ISO 8573-7, *Compressed air — Part 7: Test methods for viable microbiological contaminant content*.
- [4] ISO 8573-8, *Compressed air — Part 8: Contaminants and purity classes (by mass concentration of solid particles)*.
- [5] ISO 8573-9, *Compressed air — Part 9: Test methods for liquid water content*.
- [6] PN 14M3, *Contaminants, purity classes and measurement methods*¹⁾.

1) PNEUROP Publications available from: PNEUROP General Secretariat, 33/34 Devonshire Street, London W1N 1RF.

ICS 71.100.20

Price based on 8 pages