



Invoice # 570004A

Remit To:
FGL Environmental
853 Corporation St
Santa Paula, CA 93060

INVOICE



Silq Technologies
Attn: Chris Turner
311 Otterson Drive Suite 60
Chico, CA 95928

Account # 7013516

Date Billed 02/03/2025	Amount Due \$319.00
Date Due 03/05/2025	Amount Paid

To ensure that your account is properly credited, please return top portion with payment

Keep bottom portion for your records.

INVOICE



Customer Silq Technologies	Account # 7013516	Date Sampled 01/10/2025	Lab Number CH 2570004
Project Water Analysis	Invoice # 570004A	Date Billed 02/03/2025	Amount Due \$319.00
PO# / Check Number Purchase Order 158	Date Paid	Date Due 03/05/2025	Amount Paid

Description of Work	Quantity	Rate	Extended
Bacti Analysis			
Coliform-Quanti Tray 100 L	1	40.00	40.00
Inorganic Analysis			
General Mineral	1	200.00	200.00
Misc. Analysis			
Materials/Disposal For More Information http://fglinc.com/md.php	1	5.00	5.00
Organic Analysis			
TOC	1	74.00	74.00
Total			\$319.00

(SMH-L4) **For Questions about this Invoice - contact Stephanie Herron at 805-392-2021**

January 21, 2025

Silq Technologies

Attn: Chris Turner
311 Otterson Drive Suite 60
Chico, CA 95928

Coliform Bacteria Analysis

Lab No. : CH 2570004 1

Customer No. : 7013516

System Number : N/A

Project Name : Water Analysis

Analytical Results

ID	Sample Description	Total	Fecal	E. Coli	Units	Method	Prep	Footnote
1	CGMP-003A	<1.0 Absent	---	<1.0 Absent	MPN/100ml	SM 9223B	Quanti Tray 18	

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

Result Interpretation

The samples listed above were Acceptable for both Total and Fecal Coliform

Sample Handling Information

ID	Sample Number	System Number	Sample Type/Reason	Sampler	Employed By	Sampled
1	CH 2570004-001	N/A	System-Other	Chris Turner	Silq Technologies	2025-01-10 15:15

Field Analysis/QA Information

ID	Sample Description	CI Total/Free	Temp	Analysis Started	Analysis Completed	Contact	Contacted
		mg/l					
1	CGMP-003A	---/---	---	2025-01-10 16:34 zmp	2025-01-11 11:27 kx1	N/R	

Analyses were performed at the FGL Chico Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call.

Prepared By: RRH

Reviewed and
Approved By

Raquel R. Harvey



Digitally signed by Raquel R. Harvey
Title: Tech Director Microbiology
Date: 2025-01-21

January 31, 2025

Lab No. : CH 2570004

Customer No. : 7013516

Silq Technologies

Attn: Chris Turner
 311 Otterson Drive Suite 60
 Chico, CA 95928

Laboratory Report

Introduction: This report package contains a total of 9 pages divided into 4 sections:

Case Narrative	(2 pages)	: An overview of the work performed at FGL.
Sample Results	(2 pages)	: Results for each sample submitted.
Interpretation	(1 page)	: Drinking water Interpretation for each sample submitted.
Quality Control	(4 pages)	: Supporting Quality Control (QC) results.

Case Narrative

This Case Narrative pertains to the following samples:

Sample Description	Date Sampled	Date Received	FGL Lab No.	Matrix
CGMP-003A	01/10/2025	01/10/2025	CH 2570004-001	DW

Sampling and Receipt Information:

The Sample was received in acceptable condition and within temperature requirements, unless noted on the Condition Upon Receipt (CUR) form. The Sample was received, prepared and analyzed within the method specified holding times except those as listed in the table below. All samples arrived on ice. All samples were checked for pH if acid or base preservation is required (except for VOAs). For details of sample receipt information, please see the associated Chain of Custody and Condition Upon Receipt Form.

Samples Over Hold Time

Lab No	Analyte Method	Maximum Hold Time	Actual Hold Time
CH 2570004-001	pH	15 minutes	4,420.0 minutes

Quality Control: All samples were prepared and analyzed according to established quality control criteria. Any exceptions are noted in the Quality Control Section of this report.

Test Summary

EPA 200.7	Preparation and analysis performed by FGL-Santa Paula (FGL-SP ELAP# 1573)
EPA 300.0	Preparation and analysis performed by FGL-Santa Paula (FGL-SP ELAP# 1573)
SM 2540 C	Preparation and analysis performed by FGL-Santa Paula (FGL-SP ELAP# 1573)
SM 4500-H+B	Preparation and analysis performed by FGL-Santa Paula (FGL-SP ELAP# 1573)
SM 4500-NO3 F	Preparation and analysis performed by FGL-Santa Paula (FGL-SP ELAP# 1573)
SM 5310 C	Preparation and analysis performed by FGL-Santa Paula (FGL-SP ELAP# 1573)
SM 5540 C	Preparation and analysis performed by FGL-Santa Paula (FGL-SP ELAP# 1573)

Certification: I certify that this data package is in compliance with ELAP standards, both technically and for completeness, except for any conditions listed above and in the QC Section. Release of the data contained in this data package is authorized by the Laboratory Director or his designee, as verified by the following electronic signature. This report shall not be reproduced except in full, without the written approval of the laboratory.

KD: SMH

Approved By **Kelly A. Dunnahoo, B.S.**  Digitally signed by Kelly A. Dunnahoo, B.S.
Title: Laboratory Director
Date: 2025-01-31

January 31, 2025

Silq Technologies

Attn: Chris Turner
 311 Otterson Drive Suite 60
 Chico, CA 95928

Description : CGMP-003A
 Project : Water Analysis

Lab No. : CH 2570004-001

Customer No. : 7013516

Sampled On : January 10, 2025 at 15:15

Sampled By : Chris Turner

Received On : January 10, 2025 at 15:50

Matrix : Drinking Water

Sample Results - Inorganic

Constituent	Result	RL	Units	MCL/AL	Dil.	DQF	Sample Preparation			Sample Analysis			
General Mineral							Date	Time	Who	Method	Date	Time	Who
Total Hardness as CaCO3	ND	2.5	mg/L		1	U	01/16/2025	08:00	ac	2340B	01/16/2025	11:37	ac
Calcium	ND	1	mg/L		1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Magnesium	ND	1	mg/L		1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Potassium	ND	1	mg/L		1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Sodium	ND	1	mg/L		1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Total Cations	ND	---	meq/L			U	01/16/2025	08:00	ac	Calc.	01/16/2025	11:37	ac
Boron	ND	0.1	mg/L		1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Copper	ND	10	ug/L	1000 ²	1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Iron	ND	30	ug/L	300 ²	1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Manganese	ND	10	ug/L	50 ²	1	U	01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Zinc	40	20	ug/L	5000	1		01/16/2025	08:00	ac	EPA 200.7	01/16/2025	11:37	ac
Total Alkalinity (as CaCO3)	ND	10	mg/L		1	U	01/13/2025	16:55	amm	SM 4500-H+B	01/14/2025	02:28	amm
Hydroxide as OH	ND	10	mg/L		1	U	01/13/2025	16:55	amm	SM 4500-H+B	01/14/2025	02:28	amm
Carbonate as CO3	ND	10	mg/L		1	U	01/13/2025	16:55	amm	SM 4500-H+B	01/14/2025	02:28	amm
Bicarbonate as HCO3	ND	10	mg/L		1	U	01/13/2025	16:55	amm	SM 4500-H+B	01/14/2025	02:28	amm
Sulfate	ND	0.5	mg/L	500 ²	1	U	01/29/2025	16:04	ldm	EPA 300.0	01/30/2025	00:57	ldm
Chloride	ND	1	mg/L	500 ²	1	U	01/29/2025	16:04	ldm	EPA 300.0	01/30/2025	00:57	ldm
Nitrate as NO3	0.4	0.4	mg/L	45	1	J	01/11/2025	14:00	akb	SM 4500-NO3 F	01/11/2025	14:41	akb
Nitrite as N	ND	0.2	mg/L	1	1	U	01/11/2025	14:00	akb	SM 4500-NO3 F	01/11/2025	14:38	akb
Fluoride	ND	0.1	mg/L	2	1	U	01/29/2025	16:04	ldm	EPA 300.0	01/30/2025	00:57	ldm
Total Anions	ND	---	meq/L		1	UJ	01/13/2025	16:55	amm	Calc.	01/14/2025	02:28	amm
pH	7.6	---	units		1	T	01/13/2025	16:55	amm	SM 4500-H+B	01/14/2025	02:28	amm
Specific Conductance	18.0	1	umhos/cm	1600 ²	1		01/13/2025	16:55	amm	SM 4500-H+B	01/14/2025	02:28	amm
Total Dissolved Solids	ND	20	mg/L	1000 ²	1	U	01/14/2025	14:00	ctl	SM 2540 C	01/15/2025	11:45	ctl
MBAS (Screen)	Negative	0.1	mg/L		1	U	01/11/2025	18:51	akb	SM 5540 C	01/11/2025	19:11	akb
Aggressiveness Index	9.0	1	--		1		01/13/2025	16:55	amm	Calc.	01/14/2025	02:28	amm
Langelier Index (20°C)	7.0	1	--		1		01/13/2025	16:55	amm	Calc.	01/14/2025	02:28	amm
Nitrate Nitrogen	ND	0.4	mg/L	10	1	U	01/11/2025	14:00	akb	SM 4500-NO3 F	01/11/2025	14:41	akb

ND=Non-Detected, RL=Reporting Level.

MCL = Maximum Contamination Level. 2 - Secondary Standard. 3 - CDPH Notification Level. AL = Regulatory Action Level.

January 31, 2025

Silq Technologies

Attn: Chris Turner
 311 Otterson Drive Suite 60
 Chico, CA 95928

Description : CGMP-003A
 Project : Water Analysis

Lab No. : CH 2570004-001
 Customer No. : 7013516

Sampled On : January 10, 2025 at 15:15
 Sampled By : Chris Turner
 Received On : January 10, 2025 at 15:50
 Matrix : Drinking Water

Sample Results - Organic

Constituent	Result	RL	Units	MCL/AL	Dil.	DQF	Sample Preparation			Sample Analysis		
TOC												
TOC	2.6	0.3	mg/L	---	1		01/15/2025	15:46	amm	SM 5310 C	01/16/2025	01:57 amm

DQF Flags Definition:

- U Constituent results were non-detect.
- J Reported value is estimated; detected at a concentration below the RL and above the laboratory MDL.
- T Exceeded method/regulatory-specific holding time.

ND=Non-Detected, RL=Reporting Level , Dil.=Dilution

MCL = Maximum Contamination Level. 2 - Secondary Standard. 3 - CDPH Notification Level. AL = Regulatory Action Level.

January 31, 2025

Silq Technologies

Description : CGMP-003A
 Project : Water Analysis

Lab No. : CH 2570004-001
 Customer No. : 7013516
 Matrix : Drinking Water
 Sampled On : January 10, 2025 at 15:15

Drinking Water Interpretations

Summary: Your water was acceptable for all items tested on this sample report. Details are presented below:

Constituent	Result	Units	MCL	Result Compared to MCL	
Inorganic - Primary				Less Than or Equal	Exceeded
Fluoride	ND	mg/L	2	PASS	
Nitrate as NO3	0.4	mg/L	45	PASS	
Nitrate Nitrogen	ND	mg/L	10	PASS	
Nitrite as N	ND	mg/L	1	PASS	
Zinc	40	ug/L	5000	PASS	
Inorganic - Secondary				Less Than or Equal	Exceeded
Chloride	ND	mg/L	500	PASS	
Copper	ND	ug/L	1000	PASS	
Iron	ND	ug/L	300	PASS	
Manganese	ND	ug/L	50	PASS	
Specific Conductance	18.0	umhos/cm	1600	PASS	
Sulfate	ND	mg/L	500	PASS	
Total Dissolved Solids	ND	mg/L	1000	PASS	
Other				Less Than or Equal	Exceeded
Copper	ND	ug/L	1300**	PASS	

ND=Non-Detect; ** Action Levels per California Title 22, Section 64678

Definitions

MCL	The maximum level at which a constituent may be present and be considered acceptable for potability or aesthetics.
Primary	Items listed as primary are regulated because of health concerns. If there is a failure for a primary constituent treatment is normally required.
Secondary	Items listed as secondary are regulated because they may adversely affect the taste, odor or appearance of drinking water. They are not directly health related. If there is a failure for a secondary constituent on a small public water system it is best to consult your regulator to determine if treatment is required. A secondary constituent failure for a private water system does not require treatment. However, the owner may wish to treat the water in order to improve the quality.
Treatment	If your water requires treatment we suggest that you contact a qualified water treatment company. They are normally listed under the following searches: Water Purification & Filtration Equipment Water Softening & Conditioning Equipment Water Treatment Equipment

January 31, 2025
Silq Technologies

Lab No. : CH 2570004
 Customer No. : 7013516

Quality Control - Metals

Constituent	Method	Date/ID	Type	Units	Conc.	QC Data	DQO	Note
Metals								
Boron	200.7	01/16/2025:200530AC (STK2530563-001)	MS	mg/L	4.000	93.7%	75-125	
			MSD	mg/L	4.000	104%	75-125	
			MSRPD	mg/L		10.7%	≤20.0	
Calcium	200.7	01/16/2025:200530AC (STK2530563-001)	MS	mg/L	12.00	88.9%	75-125	
			MSD	mg/L	12.00	101%	75-125	
			MSRPD	mg/L		5.4%	≤20.0	
Copper	200.7	01/16/2025:200530AC (STK2530563-001)	MS	ug/L	800.0	93.0%	75-125	
			MSD	ug/L	800.0	102%	75-125	
			MSRPD	ug/L		9.4%	≤20.0	
Iron	200.7	01/16/2025:200530AC (STK2530563-001)	MS	ug/L	4000	87.4%	75-125	
			MSD	ug/L	4000	99.3%	75-125	
			MSRPD	ug/L		12.7%	≤20.0	
Magnesium	200.7	01/16/2025:200530AC (STK2530563-001)	MS	mg/L	12.00	92.5%	75-125	
			MSD	mg/L	12.00	105%	75-125	
			MSRPD	mg/L		7.6%	≤20.0	
Manganese	200.7	01/16/2025:200530AC (STK2530563-001)	MS	ug/L	800.0	92.8%	75-125	
			MSD	ug/L	800.0	103%	75-125	
			MSRPD	ug/L		10.8%	≤20.0	
Potassium	200.7	01/16/2025:200530AC (STK2530563-001)	MS	mg/L	12.00	91.3%	75-125	
			MSD	mg/L	12.00	103%	75-125	
			MSRPD	mg/L		8.7%	≤20.0	
Sodium	200.7	01/16/2025:200530AC (STK2530563-001)	MS	mg/L	12.00	85.8%	75-125	
			MSD	mg/L	12.00	97.7%	75-125	
			MSRPD	mg/L		5.3%	≤20.0	
Zinc	200.7	01/16/2025:200530AC (STK2530563-001)	MS	ug/L	800.0	85.2%	75-125	
			MSD	ug/L	800.0	96.1%	75-125	
			MSRPD	ug/L		12.0%	≤20.0	

Definition

DQO : Data Quality Objective - This is the criteria against which the quality control data is compared.

MS : Matrix Spikes - A random sample is spiked with a known amount of analyte. The recoveries are an indication of how that sample matrix affects analyte recovery.

MSD : Matrix Spike Duplicate of MS/MSD pair - A random sample duplicate is spiked with a known amount of analyte. The recoveries are an indication of how that sample matrix affects analyte recovery.

MSRPD : MS/MSD Relative Percent Difference (RPD) - The MS relative percent difference is an indication of precision for the preparation and analysis.

ND : Non-detect - Result was below the DQO listed for the analyte.

Quality Control - Organic

Constituent	Method	Date/ID	Type	Units	Conc.	QC Data	DQO	Note
Organic TOC 415.1	5310C	01/15/2025:200509AMM (SP 2500467-001)	Blank	mg/L		ND	<0.3	
			MS	mg/L	25.00	96.5%	75-125	
			MSD	mg/L	25.00	99.2%	75-125	
			MSRPD	mg/L		2.7%	≤23.0	

Definition

Blank : Method Blank - Prepared to verify that the preparation process is not contributing contamination to the samples.

MS : Matrix Spikes - A random sample is spiked with a known amount of analyte. The recoveries are an indication of how that sample matrix affects analyte recovery.

MSD : Matrix Spike Duplicate of MS/MSD pair - A random sample duplicate is spiked with a known amount of analyte. The recoveries are an indication of how that sample matrix affects analyte recovery.

MSRPD : MS/MSD Relative Percent Difference (RPD) - The MS relative percent difference is an indication of precision for the preparation and analysis.

Quality Control - Wet Chem

Constituent	Method	Date/ID	Type	Units	Conc.	QC Data	DQO	Note
Wet Chem								
Alkalinity (as CaCO ₃)	2320B	(SP 2500417-001)	Dup	mg/L		0.04%	10	
Bicarbonate	2320B	(SP 2500417-001)	Dup	mg/L		0%	10	
Carbonate	2320B	(SP 2500417-001)	Dup	mg/L		0%	10	
E. C.	2320B	(SP 2500417-001)	Dup	umhos/cm		0.03%	5	
Hydroxide	2320B	(SP 2500417-001)	Dup	mg/L		0%	10	
pH	2320B	(SP 2500417-001)	Dup	units		0.4%	4.80	
Solids, Total Dissolved	2540CE	01/14/2025:200433CTL	Blank	mg/L	991.1	ND	<20	
			LCS	mg/L		98.4%	90-110	
		(VI 2540216-003)	Dup	mg/L		4.78%	5	
		(VI 2540216-003)	Dup	mg/L		0.2%	5	
Chloride	300.0	01/29/2025:201011LDM	Blank	mg/L	25.00	ND	<1	
			LCS	mg/L		97.3%	90-110	
			MS	mg/L		87.8%	67-117	
			MSD	mg/L		88.9%	67-117	
		(CH 2570695-001)	MSRPD	mg/L		0.5%	≤7	
			MS	mg/L		87.3%	67-117	
			MSD	mg/L		87.8%	67-117	
			MSRPD	mg/L		0.2%	≤7	
Fluoride	300.0	01/29/2025:201011LDM	Blank	mg/L	2.500	ND	<0.1	
			LCS	mg/L		104%	90-110	
			MS	mg/L		101%	89-111	
			MSD	mg/L		101%	89-111	
		(CH 2570695-001)	MSRPD	mg/L		0.0%	≤9	
			MS	mg/L		99.3%	89-111	
			MSD	mg/L		100%	89-111	
			MSRPD	mg/L		0.6%	≤9	
Sulfate	300.0	01/29/2025:201011LDM	Blank	mg/L	50.00	ND	<0.5	
			LCS	mg/L		96.9%	90-110	
			MS	mg/L		97.2%	18-165	
			MSD	mg/L		97.8%	18-165	
		(CH 2570695-001)	MSRPD	mg/L		0.5%	≤7	
			MS	mg/L		96.4%	18-165	
			MSD	mg/L		96.8%	18-165	
			MSRPD	mg/L		0.3%	≤7	
Nitrate	4500NO3F	01/11/2025:200349AKB	Blank	mg/L	11.22	ND	<0.4	
			LCS	mg/L		98.2%	80-120	
			MS	mg/L		90.0%	66-125	
			MSD	mg/L		93.8%	66-125	
			MSRPD	mg/L		0.7%	≤30.4	
Nitrate Nitrogen	4500NO3F	01/11/2025:200349AKB	Blank	mg/L	11.22	ND	<0.4	
			LCS	mg/L		98.2%	80-120	
			MS	mg/L		90.0%	66-125	
			MSD	mg/L		93.8%	66-125	
			MSRPD	mg/L		0.7%	≤30.4	
Nitrite as Nitrogen	4500NO3F	01/11/2025:200459AKB	Blank	mg/L	1.218	ND	<0.2	
			LCS	mg/L		103%	80-120	
			MS	mg/L		105%	50-150	
			MSD	mg/L		104%	50-150	
			MSRPD	mg/L		1.3%	≤30	
MBAS (Screen)	5540C	01/11/2025:200454AKB	MS	mg/L	10.00	100%	90-110	

Quality Control - Wet Chem

Constituent	Method	Date/ID	Type	Units	Conc.	QC Data	DQO	Note
		(CH 2570004-001)	MSD	mg/L	10.00	100%	90-110	
			MSRPD	mg/L		0.0%	≤0.1	

Definition

Blank	: Method Blank - Prepared to verify that the preparation process is not contributing contamination to the samples.
Dup	: Duplicate Sample - A random sample with each batch is prepared and analyzed in duplicate. The relative percent difference is an indication of precision for the preparation and analysis.
LCS	: Laboratory Control Standard/Sample - Prepared to verify that the preparation process is not affecting analyte recovery.
MS	: Matrix Spikes - A random sample is spiked with a known amount of analyte. The recoveries are an indication of how that sample matrix affects analyte recovery.
MSD	: Matrix Spike Duplicate of MS/MSD pair - A random sample duplicate is spiked with a known amount of analyte. The recoveries are an indication of how that sample matrix affects analyte recovery.
MSRPD	: MS/MSD Relative Percent Difference (RPD) - The MS relative percent difference is an indication of precision for the preparation and analysis.



www.fglinc.com

CHAIN OF CUSTODY AND ANALYSIS REQUEST DOCUMENT

[illegible]

Corporate Offices & Laboratory
853 Corporation Street
Santa Paula, CA 93080
TEL: (805)392-2000
CA ELAP Certification No. 1573

Office & Laboratory
2500 Stagecoach Road
Stockton, CA 95215
TEL: (209)942-0182
CA ELAP Certification No. 1563

Office & Laboratory
563 E. Lindo Avenue
Chico, CA 95926
TEL: (530)343-5818
CA ELAP Certification No. 2670

Office & Laboratory
3442 Empresa Drive, Suite D
San Luis Obispo, CA 93401
TEL: (805)783-2940
CA ELAP Certification No. 2775

Office & Laboratory
9411 W. Goshen Avenue
Visalia, CA 93291
TEL: (559)734-9473
CA ELAP Certification No. 2810

2570004

Inter-Laboratory Condition Upon Receipt (Attach to COC) Sample Receipt at:

CC CH STK VI

1. Number of ice chests/packages received: 01 Shipping tracking #(s): _____

2. Temp IR Gun ID #: 24110

3. Were samples received on ice? Yes No Temps: 15.1°C / _____ / _____ / _____

Surface water SWTR bact samples: A sample that has a temperature upon receipt of >10° C, whether iced or not, should be flagged unless the time since sample collection has been less than two hours.

4. Do the number of bottles received agree with the COC? Yes No N/A

5. Were samples received intact? (i.e. no broken bottles, leaks etc.) Yes No

6. VOAs checked for Headspace? Yes No N/A

7. Were all analyses within holding times at time of receipt? Yes No PH, Only for analysis

8. Verify sample date, time and sampler name Yes No

Sign and date the COC, place in a ziplock and put in the same ice chest as the samples.

Sample Receipt Review completed by (initials): YDU

Sample Receipt at SP:

1. Number of ice chests/packages received: 1 Shipping tracking #(s): 525240000

2. Temp IR Gun ID #: U1

3. Were samples received on ice? Yes No Temps: 1 / _____ / _____ / _____

Acceptable is above freezing to 6°C. If many packages are received at one time check for tests/H.T.'s/rushes/

4. Do the number of bottles received agree with the COC? Yes No N/A

5. Were samples received intact? (i.e. no broken bottles, leaks etc.) Yes No

Sign and date the COC, obtain LIMS sample numbers, select methods/tests and print labels.

Sample Verification, Labeling and Distribution:

1. Were all requested analyses understood and acceptable? Yes No

2. Did bottle labels correspond with the client's ID's? Yes No

3. Were all bottles requiring sample preservation properly preserved? Yes No N/A FGL

[Exception: Oil & Grease, VOA and CrVI verified in lab]

4. VOAs checked for Headspace? Yes No N/A

5. Have rush or project due dates been checked and accepted? Yes No N/A

6. Were all analyses within holding times at time of receipt? Yes No

Attach labels to the containers and include a copy of the COC for lab delivery.

Sample Receipt, Login and Verification completed by (initials): U

Discrepancy Documentation:

Any items above which are "No" or do not meet specifications (i.e. temps) must be resolved.

1. Person Contacted: _____ Phone Number: _____

Initiated By: _____ Date: _____

Problem: _____

Resolution: _____

2. Person Contacted: _____

Initiated By: _____

Problem: _____

Resolution: _____

(7013516)
Silq Technologies
CH 2570004
iv 01/13/2025 07:38:58
CH 2570004