

Glycol Chiller GC-2 Repair Invoice - Sep 2026

From: Carolina Refrigeration Services, Inc.
1102 Patton Avenue, Asheville NC 28806
EIN 56-1290118 | HVAC License NC-19421

Bill to: Bates Brewing Company
Invoice #: CRS-INV-2026-09-118 | **Date:** 17 Sep 2026 | **Terms:** Net 15

Service summary: Glycol chiller GC-2 nuisance trip on high-pressure cutout 2026-09-12. On-site diagnosis confirmed fouled condenser coil + low refrigerant charge. Cleaned coil, leak-checked, topped 1.4 lb R-410A, calibrated HP/LP switches, verified 18 hr continuous run.

Line	Description	Qty	Unit	Amount
1	Diagnostic call-out (after hours)	1	\$185.00	\$185.00
2	Coil cleaning + chemical flush	1	\$320.00	\$320.00
3	R-410A refrigerant	1.4 lb	\$48.00	\$67.20
4	Labor — repair (3.5 hr @ \$135)	3.5	\$135.00	\$472.50
5	HP/LP switch calibration	1	\$95.00	\$95.00
			Subtotal	\$1,139.70
			NC sales tax (7%)	\$79.78
			TOTAL DUE	\$1,219.48

Warranty: 90 days on parts & labour from 17 Sep 2026. Next scheduled preventative service window: late January 2027.