

1. ALL EQUIPMENT, INSTRUMENT AND LINE NUMBERS ON THIS DRAWING HAVE THE PREFIX 8037 UNLESS OTHERWISE NOTED.

2. THE LETTERS 'Y' & 'O' ARE NOT USED IN THE EQUIPMENT NUMBERING SYSTEM.

3. FOR STANDARD P&ID LEGEND SEE THE FOLLOWING DRAWINGS:
— FOR PIPING & EQUIPMENT : DWG. NO. CP-0500N-FF-002
— FOR INSTRUMENTATION : DWG. NO. CP-0500N-FF-003

4. BACKWASH OF SECONDARY SOFTENERS TO BE CARRIED OUT AUTOMATICALLY BY PUSH BUTTON FURNISHED ON THE PANEL.

5. PSV'S FOR SOFTENING PACKAGE UNITS ZF-1203B THRU ZF-1203K TO BE TAGGED 1212B, 1212C.....1212K FOR PRIMARY SOFTENER A & 1213B, 1213C.....1213K FOR SECONDARY SOFTENER.

6. THE PDI ON ZF-1203A HAS BEEN DEMOLISHED

7. THE N4 ON ZF-1203A IS BLUNDED ONLY

8. THE FIT.1230 # ON ZF-1203 A HAS BEEN DEMOLISHED

9. PSV SIZE:
SOFTENER # 1203 A (PRIMARY: 1 1/2"x1 1/2"), (SECONDARY: 1 1/2"x1 1/2")

10. LINE NO. WW-541-B"-B1 TO BE USE FOR WATER SOFTENER ZF-1203 P, Q & R

1. ONLY 2 PACKAGED SOFTENER UNITS ARE TO BE IN "REGENERATION" AT A TIME.

DURI-WTPF03GS000-PRO-PID-IBU-0027-00

[illegible]