



K
J
I
H
G
F
E
D
C
B
A

K
J
I
H
G
F
E
D
C
B
A

8037.T.0801A
FREE WATER KNOCKOUT TANK 21,920 BBL
DIMENSION = 70'-0"DIA.x32'-0"H
TRIM = TE-T-01A & B-B1
SET PRESS. = 0.5 OZ/IN²

NOTES

1. ALL LINE & DRAWING NUMBERS ON THIS DRAWING HAVE THE PREFIX 403GS. ALL EQUIPMENT & INSTRUMENT ON THIS DRAWING HAVE THE PREFIX 8037 UNLESS OTHERWISE NOTED.
2. THE LETTERS "I" & "O" ARE NOT USED IN THE EQUIPMENT NUMBERING SYSTEM
3. DELETED
4. SET PRESSURE/VACCUM VENTS ON API TANK AT 0.5 OZ/IN² VAC, 0.5 OZ/IN² PRESS.
5. ALL API TANKS ON THIS DRAWING SHALL BE SPECIFIED FOR :
- OPERATION : 0.3 OZ/IN² PRESS. @ 135-200' F
- DESIGN : 1.73 OZ/IN² PRESS. -1.15 OZ/IN² VAC. @ 200' F
6. DELETED
7. LAP JOINT (LJ) FLANGES ARE INDICATED THUS
8. FWKO TANK T.0802A
2" VALVE = 32 VALVES TAG NO. START FROM 1501A UP TO 1532A
4" VALVE = 32 VALVES TAG NO. START FROM 1501B UP TO 1532B
9. INACTIVE

		22	27-04-20	RPGN	PUTM	PUTM	AOZL	UPDATE AS PER PSI V&V (ID #7092)
		21	10-08-20	RUS	SD	PUTM	TXPA	AS BUILT UPDATE AS PER PSI V&V (PID IMPROVEMENT) MOC # 307724
ICM-GB-J15127(A~G&J)	PID STANDARD LEGENDS	20	21-02-20	RPGN	PUTM	-	AOZL	UPDATE AS PER PSI V&V (ID #4541)
CP-403GS-EF-002	P & ID DIAGRAM OIL TREATING FACILITIES (SHT-2)	19	28-11-18	RO	AM	-	TZSX	AS-BUILT (PSI V&V AS PER MOC#481540)
CP-403GS-PF-004	P & ID DIAGRAM FLOW SPLITTER	18	07-09-17	ILH	ROS	-	RQS	UPDATE AS PER FIELD VARIFICATION (PSI V&V) MOC#307724
CP-403GS-EF-015	P & ID SLURRY PUMPS, SLURRY TANK & FEED PUMPS	17	16-12-15	HP	JX	-	BAY	AS BUILT PSM-PSI REMEDIATION PROJECT UNDER JOB NO.2445
DRAWING NO.	TITLE	NO	DATE	BY	DRAFT CHKD	ENGR CHKD	PSI COOR	

REFERENCE DRAWINGS

REVISION

PROJECT NO.	DRAWN:	ENGR:	DEPT:	DATE:
20/OE-PMF/RP-2011	YAS	RDL	KGK	12-JULY-1986



DURI-OTPF03GS000-PRO-PID-IBU-0007-00
PIPING & INSTRUMENT DIAGRAM
OIL TREATING FACILITIES
FREE WATER KNOCKOUT TANK A
CENTRAL GATHERING STATION DURI AREA-3
CP-403GS-EF-022-22

SIZE:	A1	SCALE:	NTS	REV:	22	SHEET:	1 OF 4
-------	----	--------	-----	------	----	--------	--------