



TAMIL NADU FIRE AND RESCUE SERVICES LICENCE

(Under section 13 of the Tamil Nadu Fire Service Act 1985 and

Tamil Nadu Fire Service Rule 1990 - Appendix-III)

Licence No: 29068/RFL/NMSB/2025

Dated: 12/12/2025

District Office,
Fire and Rescue Service,
Chennai District.

RENEWEL OF FIRE LICENSE

Ref: Letter from the **THEOBROMA FOODS PVT LTD**, Dated: 08/12/2025, Token No.350202

The Fire License is hereby renewed under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 RUNNING a RESTAURANT in the name of M/S.**THEOBROMA FOODS PVT LTD**, O.No:129, N.No:386, Purasaiwakkam High Road, Kellys, Chennai – 600 010 Consisting of **Ground + 2 Floors running at Ground Floor only** with the height of 9.5 meters and total built-up area in 600 Sq.mt within the jurisdiction of Chennai Corporation based on the inspection was done by The Station Officer Villivakkam on 09/12/2025. Subject to the condition noted thereon and such other conditions as may be prescribed. This licence is valid for **THREE YEARS** from the date of issue.

CONDITIONS

1. All fire fighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. The following fire & life safety system / arrangements provided in the building should be kept in the good working condition
 1. Portable fire extinguisher – 2 No's II.OHT capacity of 2000L Sump 9000L only used for fire fighting.
4. The staff should be trained in preliminary fire fighting as per G.O.No:713 Home (Police-17), Dated: 17.08.2005 with Fire and Rescue Services Department.
5. Mock drill should be periodically conducted.
6. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Services Department.
7. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Dos & Don'ts boards should be displayed.
8. Emergency fire exit, staircases and doors should not be obstructed.
9. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
10. All the electrical equipment, fitting, accessories and Wiring system should be maintained. As per IS 1646 : 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.

To:

THEOBROMA FOODS PVT LTD,

O.No:129, N.No:386, Purasaiwakkam High Road,

Kellys, Chennai – 600 010.

Signature valid

Signed by: Mr. M.Mangrassanna
Chennai Central District,
Northern Region / District Officer,
Home Department
Date:12-Dec-2025 21:34:11

