



2820 S. English Station Road - Louisville, KY 40299
Tel: (502) 357-0132 Fax (502) 357-0132

TEST NO. 22-022-1D

ISO 16890:2016 Air Filter Test Result Summary

Sections 2, 3 and 4

Page 1 of 4

Counter Information


Manufacturer TSI, Inc.
Model No. 3330

Test Conditions

Test Flow Rate (CFM) 1968
Test Aerosol Aerosolized KCl & DEHS
Temperature (Deg F) 70.0
Relative Humidity (%) 39.0
Barometer (in Hg) 29.32
Dust Type ISO Fine

Filter Description

Manufacturer Parker HVAC Filtration Division
Filter Model type dp
Part Number DP-M10-HC-242402
Dimensions 24" x 24" x 2"
Type of Media Synthetic
Media Area 17.2 Ft²
Construction Cardboard Frame
Filter/Media Electrostatic Charge No
Media Color White
Media Adhesive N/A
Sample Procurement New
Initial Filter Weight (g) 482
Final Device Weight (g) 620
Initial Arrestance (%) 77.5
Initial Pressure Drop ("w.c.) 0.23



DEHS Size .03 - 1.0 and KCL Size 1.0 - 10.0

Range (µm)	Geo. Mean	Initial Efficiency (%)	Discharged Efficiency (%)	Upstream Number of Particles	
				Pre	Post
0.3-0.4	0.35	1	2	199245	468831
0.4-0.55	0.47	2	2	147828	333441
0.55-0.7	0.62	3	5	78343	170524
0.7-1.0	0.84	9	11	74459	159886
1.0-1.3	1.14	31	35	23251	19418
1.3-1.6	1.44	40	45	13187	11134
1.6-2.0	1.88	52	57	29215	24616
2.0-3.0	2.57	66	70	14679	11513
3.0-4.0	3.46	77	79	5770	4078
4.0-5.5	4.69	84	83	2708	1938
5.5-7.0	6.2	86	86	626	459
7.0-10.0	8.37	88	89	295	218

Reporting Data

	ePM ₁	ePM _{2,5}	ePM ₁₀
Minimum	4%	20%	--
Average	4%	19%	60%
Reported	N/A*	N/A*	60%

* Any Reporting value of N/A shows the minimum efficiency is below 50% for that ePM value


Comments Tested For: Parker HVAC Filtration Division

Device Condition: New

Final Pressure Drop ("w.c.) 1.20"w.c. 0.80"w.c.
Total Dust Captured (gms) 138 103
Average Arrestance (%) 85.7 83.3

Test Operator Information Test Performed by: CR Approved By: [Signature] Completion Date: 4-Mar-22

ISO 16890-1										
Data Entry Table										
DEHS										
d_i	d_{i+1}	d_m	$\Delta \ln d_i$	E_i	$E_{D,i}$	$E_{A,i}$				
0.30	0.40	0.35	0.29	0.9%	1.8%	1.4%				
0.40	0.55	0.47	0.32	2.1%	2.3%	2.2%				
0.55	0.70	0.62	0.24	3.5%	4.7%	4.1%				
0.70	1.00	0.84	0.36	9.0%	10.5%	9.8%				
KCL										
1.00	1.30	1.14	0.26	30.8%	35.3%	33.1%				
1.30	1.60	1.44	0.21	40.0%	44.6%	42.3%				
1.60	2.20	1.88	0.32	51.9%	56.7%	54.3%				
2.20	3.00	2.57	0.31	66.2%	70.0%	68.1%				
3.00	4.00	3.46	0.29	76.5%	78.9%	77.7%				
4.00	5.50	4.69	0.32	83.5%	83.3%	83.4%				
5.50	7.00	6.20	0.24	86.1%	85.8%	86.0%				
7.00	10.00	8.37	0.36	88.2%	89.0%	88.6%				
ePM ₁ Calculations										
d_i	d_{i+1}	d_m	$\Delta \ln d_i$	$E_{A,i}$	q_{3u}	$q_{3u} * \Delta \ln d_i$	$E_{D,i} * q_{3u} * \Delta \ln d_i$	$E_{A,i} * q_{3u} * \Delta \ln d_i$	$E_{\min}(\text{PM}_{10})$	$E(\text{PM}_{10})$
0.30	0.40	0.35	0.29	1.4%	22.627%	0.065095	0.001198	0.000908	4%	4%
0.40	0.55	0.47	0.32	2.2%	19.891%	0.063343	0.001478	0.001414		
0.55	0.70	0.62	0.24	4.1%	15.837%	0.038193	0.001797	0.001564		
0.70	1.00	0.84	0.36	9.8%	11.522%	0.041097	0.004319	0.004008		
Sums:						0.207728	0.008792	0.007894		
ePM _{2.5} Calculations										
d_i	d_{i+1}	d_m	$\Delta \ln d_i$	$E_{A,i}$	q_{3u}	$q_{3u} * \Delta \ln d_i$	$E_{D,i} * q_{3u} * \Delta \ln d_i$	$E_{A,i} * q_{3u} * \Delta \ln d_i$	$E_{\min}(\text{PM}_{2.5})$	$E(\text{PM}_{2.5})$
0.30	0.40	0.35	0.29	1.4%	22.627%	0.065095	0.001198	0.000908	20%	19%
0.40	0.55	0.47	0.32	2.2%	19.891%	0.063343	0.001478	0.001414		
0.55	0.70	0.62	0.24	4.1%	15.837%	0.038193	0.001797	0.001564		
0.70	1.00	0.84	0.36	9.8%	11.522%	0.041097	0.004319	0.004008		
1.00	1.30	1.14	0.26	33.1%	8.503%	0.022309	0.007884	0.007382		
1.30	1.60	1.44	0.21	42.3%	7.618%	0.015817	0.007051	0.006692		
1.60	2.20	1.88	0.32	54.3%	8.022%	0.025546	0.014475	0.013862		
2.20	3.00	2.57	0.31	68.1%	9.984%	0.030966	0.021667	0.021083		
Sums:						0.302366	0.059870	0.056913		
ePM ₁₀ Calculations										
d_i	d_{i+1}	d_m	$\Delta \ln d_i$	$E_{A,i}$	q_{3r}	$q_{3r} * \Delta \ln d_i$	$E_{D,i} * q_{3r} * \Delta \ln d_i$	$E_{A,i} * q_{3r} * \Delta \ln d_i$	$E_{\min}(\text{PM}_{10})$	$E(\text{PM}_{10})$
0.30	0.40	0.35	0.29	1.4%	9.412%	0.027077	0.000498	0.000378	61%	60%
0.40	0.55	0.47	0.32	2.2%	8.395%	0.026733	0.000624	0.000597		
0.55	0.70	0.62	0.24	4.1%	7.432%	0.017924	0.000843	0.000734		
0.70	1.00	0.84	0.36	9.8%	7.014%	0.025016	0.002629	0.002439		
1.00	1.30	1.14	0.26	33.1%	7.628%	0.020013	0.007073	0.006622		
1.30	1.60	1.44	0.21	42.3%	8.833%	0.018340	0.008176	0.007759		
1.60	2.20	1.88	0.32	54.3%	10.804%	0.034406	0.019496	0.018671		
2.20	3.00	2.57	0.31	68.1%	13.726%	0.042573	0.029788	0.028986		
3.00	4.00	3.46	0.29	77.7%	16.708%	0.048067	0.037926	0.037351		
4.00	5.50	4.69	0.32	83.4%	19.542%	0.062233	0.051870	0.051931		
5.50	7.00	6.20	0.24	86.0%	21.671%	0.052261	0.044858	0.044929		
7.00	10.00	8.37	0.36	88.6%	23.143%	0.082545	0.073431	0.073129		
Sums:						0.457189	0.277213	0.273526		
Page 2 of 4										



Test No. 22-022-1D
Date: 04-Mar-22

**Data - Air Flow vs
Resistance (Clean
Device)**

Airflow (CFM)	Resistance (in WG)
0	0.00
492	0.04
984	0.09
1476	0.15
1968	0.23
2460	0.33

**Data - Dust Fed vs
Dust Weight
Arrestance**

Dust Fed (gms)	Arrestance (%)
0	
12	77.5
49	83.0
99	86.4
143	93.8

**Data - Dust Fed vs
Resistance**

Dust Fed (gms)	Res (in WG)
0	0.23
24	0.27
74	0.49
124	0.80
161	1.20

The interpretation of test reports

This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary. (For further details of procedures the full ISO 16890 document series shall be consulted). Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency ("mechanical efficiency") as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when at the same time there is no compensating increase of the mechanical efficiency. These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible "real life" behaviour. This brief review of the test procedures, including those for addressing the testing of electrostatic charged filters, is provided for those unfamiliar with the procedures of this series of ISO standards. It is intended to assist in understanding and interpreting the results in the test report/summary. (For further details of procedures the full ISO 16890 document series shall be consulted). Air filters may rely on the effects of passive static electric charges on the fibres to achieve high efficiencies, particularly in the initial stages of their working life. Environmental factors encountered in service may affect the action of these electric charges so that the initial efficiency may drop substantially after an initial period of service. This could be offset or countered by an increase in efficiency ("mechanical efficiency") as dust deposits build up. The reported, untreated and conditioned (discharged) efficiency shows the extent of the electrical charge effect on initial performance and indicates the potential loss of particle removal efficiency when the charge effect is completely removed and when at the same time there is no compensating increase of the mechanical efficiency. These test results should not be assumed to represent the filter performance in all possible environmental conditions or to represent all possible "real life" behaviour.