Field Verification Record

Record ALP-FVR-0008 Programme Alpha Witnessed on 24 November 2021
Witness: P. Ivanova (site QA)

Item results

PV-7533 Gate valve hydrostatic test at 1500 psi - PASS
RV-9032 Relief valve hydrostatic test at 300 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.