Field Verification Record

Record BOR-FVR-0008 Programme Borealis Witnessed on 31 March 2022
Witness: T. Haruna (site QA)

Item results

RV-2741 Relief valve hydrostatic test at 600 psi - PASS

PS-6413 Pressure switch hydrostatic test at 1500 psi - PASS

PV-5320 Gate valve hydrostatic test at 900 psi - PASS

HX-5828 Plate heat exchanger hydrostatic test at 600 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.