Field Verification Record

Record EMB-FVR-0004 Programme Ember Witnessed on 17 April 2024
Witness: A. Delacroix (site QA)

Item results

BV-2895 Ball valve hydrostatic test at 1500 psi - PASS
BV-8888 Ball valve hydrostatic test at 600 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.