Field Verification Record

Record EMB-FVR-0008 Programme Ember Witnessed on 08 June 2024
Witness: T. Haruna (site QA)

Item results

FL-2385 Weld-neck flange hydrostatic test at 300 psi - PASS
BV-8888 Ball valve hydrostatic test at 600 psi - PASS
HX-7438 Plate heat exchanger hydrostatic test at 150 psi - PASS
FL-1714 Weld-neck flange hydrostatic test at 600 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.