INSPECTION REPORT

Report No. ALP-INS-0003 Project: Alpha Date: 2023-07-14
Inspector: R. Okafor

Item results

PV-7043 Gate valve hydrostatic test at 900 psi - PASS
BV-7891 Ball valve hydrostatic test at 1500 psi - PASS
PV-5706 Gate valve hydrostatic test at 900 psi - PASS
PV-7533 Gate valve hydrostatic test at 1500 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.