INSPECTION REPORT

Report No. ALP-SCN-0001

Project: Alpha

Date: 2022-09-25

HX-8226 Plate heat exchanger hydrostatic test at 150 psi - PASS

RV-9032 Relief valve hydrostatic test at 300 psi - PASS

PV-6234 Gate valve hydrostatic test at 1500 psi - PASS