Field Verification Record

Record BOR-FVR-0004 Programme Borealis Witnessed on 14 January 2024
Witness: M. Lindqvist (site QA)

Item results

PV-5320 Gate valve hydrostatic test at 900 psi - PASS

PV-5595 Gate valve hydrostatic test at 1500 psi - PASS

HX-5828 Plate heat exchanger hydrostatic test at 600 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.