INSPECTION REPORT

Report No. BOR-INS-0005 Project: Borealis Date: 2024-07-07
Inspector: A. Delacroix

Item results

PV-4511 Gate valve hydrostatic test at 150 psi - PASS
PS-6413 Pressure switch hydrostatic test at 1500 psi - PASS
PS-2967 Pressure switch hydrostatic test at 1500 psi - PASS
HX-5828 Plate heat exchanger hydrostatic test at 600 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.