INSPECTION REPORT

Report No. EMB-SCN-0001

Project: Ember

Date: 2024-10-02

HX-7438 Plate heat exchanger hydrostatic test at 150 psi - PASS

BV-2073 Ball valve hydrostatic test at 300 psi - PASS

FL-8650 Weld-neck flange hydrostatic test at 2500 psi - PASS