INSPECTION REPORT

Report No. ALP-INS-0006 Project: Alpha Date: 2024-04-09
Inspector: P. Ivanova

Item results

FL-8494 Weld-neck flange hydrostatic test at 2500 psi - PASS
HX-8226 Plate heat exchanger hydrostatic test at 150 psi - PASS
PV-5706 Gate valve hydrostatic test at 900 psi - PASS
PV-7533 Gate valve hydrostatic test at 1500 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.