INSPECTION REPORT

Report No. ALP-INS-0002 Project: Alpha Date: 2022-02-03
Inspector: R. Okafor

Item results

RV-6577 Relief valve hydrostatic test at 150 psi - PASS
HX-8226 Plate heat exchanger hydrostatic test at 150 psi - PASS
FL-8494 Weld-neck flange hydrostatic test at 2500 psi - PASS
PV-6234 Gate valve hydrostatic test at 1500 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.