Field Verification Record

Record COB-FVR-0008 Programme Cobalt Witnessed on 26 September 2022
Witness: S. Mbeki (site QA)

Item results

PV-2439 Gate valve hydrostatic test at 600 psi - PASS

HX-5939 Plate heat exchanger hydrostatic test at 600 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.