Field Verification Record

Record DRF-FVR-0008 Programme Driftwood Witnessed on 11 December 2021
Witness: R. Okafor (site QA)

Item results

BV-5383 Ball valve hydrostatic test at 2500 psi - PASS
FL-9004 Weld-neck flange hydrostatic test at 1500 psi - PASS
HX-2507 Plate heat exchanger hydrostatic test at 2500 psi - PASS
BV-8492 Ball valve hydrostatic test at 300 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.