INSPECTION REPORT

Report No. EMB-INS-0007 Project: Ember Date: 2023-04-21
Inspector: R. Okafor

Item results

BV-2073 Ball valve hydrostatic test at 300 psi - PASS
FL-1714 Weld-neck flange hydrostatic test at 600 psi - PASS
FL-8650 Weld-neck flange hydrostatic test at 2500 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.