INSPECTION REPORT

Report No. BOR-SCN-0001

Project: Borealis

Date: 2023-03-01

PS-2967 Pressure switch hydrostatic test at 1500 psi - PASS

HX-5828 Plate heat exchanger hydrostatic test at 600 psi - PASS

PV-4511 Gate valve hydrostatic test at 150 psi - PASS