INSPECTION REPORT

Report No. COB-INS-0002 Project: Cobalt Date: 2022-11-16
Inspector: T. Haruna

Item results

PV-2439 Gate valve hydrostatic test at 600 psi - PASS
HX-5939 Plate heat exchanger hydrostatic test at 600 psi - PASS
PS-2981 Pressure switch hydrostatic test at 1500 psi - PASS
FL-8470 Weld-neck flange hydrostatic test at 600 psi - PASS
PV-9437 Gate valve hydrostatic test at 1500 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.