Field Verification Record

Record COB-FVR-0004 Programme Cobalt Witnessed on 05 July 2022
Witness: P. Ivanova (site QA)

Item results

HX-3799 Plate heat exchanger hydrostatic test at 150 psi - PASS

FL-5958 Weld-neck flange hydrostatic test at 1500 psi - PASS

PS-2981 Pressure switch hydrostatic test at 1500 psi - PASS

All items visually examined for leaks, weld defects and marking legibility.